



OFFLINE CELLULAR STORAGE STRUCTURE 1.2m DEEP WITH A MIN 15% COVER TO BE MAINTAINED BY A MANAGEMENT COMPANY.
 1.57.050 STORAGE VOLUME = 96m³
 BASED ON A 20% VOID RATIO
 STORAGE AREA 80m²
 MIN COVER LEVEL = 58.750
 SOFFIT OF CRATE = 58.250

SW6FC HYDRORAPE DETAILS

REFERENCE: MD-0090-5000-2100-5000
 DESIGN HEAD: 2.1m
 ORIFICE SIZE: 50mm
 DESIGN FLOW: 5.0 l/s
 INVERT LEVEL: 58.335m

TECHNICAL SPECIFICATION		
CONTROL POINT	HEAD (m)	FLOW (l/s)
PRIMARY DESIGN	2.100	5.000
FLUSH - FLO	0.397	4.000
ROCK - FLO	0.808	3.200
MEAN FLOW		3.9

RETAINER OR RE GRADING OR EXISTING CARRIAGEWAY WIDTH REDUCED TO 4.8M REQUIRED TO REAR OF PLOT 606Z DUE TO LEVEL DIFFERENCE.

PROPOSED FOOTWAY TO TIE INTO EXISTING.
 PROPOSED SERVICE STRIP TO TIE INTO EXISTING FOOTWAY.

PROPOSED LEVELS TO BATTER BACK TO EXISTING GROUND LEVEL AT A GRADIENT OF 1:3.

PRIVATE DRAINAGE TO BE CCTV SURVEYED PRIOR CONSTRUCTION. INVERT LEVELS OF SW6&FW2 TO BE SET UPON RECEIPT OF CCTV SURVEY RESULTS.

KEY

- EXISTING ADOPTED SURFACE WATER
- EXISTING ADOPTED FLOOD WATER
- PROPOSED ADOPTED SURFACE WATER
- PROPOSED ADOPTED FLOOD WATER
- PROPOSED FLOW CONTROL
- PROPOSED OVERFLOW
- PROPOSED CELLULAR STORAGE
- PROPOSED ADOPTED HIGHWAY GULLY
- PROPOSED PRIVATE SURFACE WATER MANHOLE
- PROPOSED PRIVATE SURFACE WATER PVC
- PROPOSED PRIVATE SW CATOPTH BY POLYPIPE OR SMOKE (WOOD/MS/STH)
- PROPOSED PRIVATE SW
- PROPOSED PRIVATE PERMEABLE OUTLET
- PROPOSED PRIVATE FLOOD WATER
- PROPOSED PRIVATE FLOOD WATER PVC
- PROPOSED PRIVATE SURFACE WATER (300)
- PROPOSED SW/PS/SP/SG/BC

- DRAINAGE SPECIFICATIONS**
- ADDITIONAL ETH EDITION, THE RELIANT BOTTLE/ROCK AND THE WATER AUTHORITY STANDARDS/REQUIREMENTS TO THE MEDIANAL, IN RESPECT OF SPECIFICATION AND KITEMARKED.
 - FILED DRAINAGE MUST BE FILLED AND CONSOLIDATED UNDER THE SUPERVISION AND TO THE SATISFACTION OF YOURSHE WATER BEFORE ANY OTHER WORKS ARE CARRIED OUT.
 - ALL ADOPTABLE LEVELS TO BE KITEMARKED CERTIFIED TO BS 4341 AND BS EN 12451.
 - PLASTIC CHANNELS IN MANHOLES AND IN TRENCHES MUST BE KITEMARKED WITH THE PROPER CLAYWARE CHANNEL IN MANHOLES. PLASTIC CHANNELS ARE DIFFICULT TO SET IN CONCRETE BECAUSE THEY ARE NOT RIGID AND THEY WILL BE DEFORMED BY THE WEIGHT OF THE CONCRETE.
 - THE WATER AUTHORITY IS NOT OBLIGED TO ACCEPT FILTER DRAINAGE DRAINAGE RUNOFF FROM THE PUBLIC SEWER NETWORK OR ACCEPTABLE DRAINAGE DRAINAGE RUNOFF FROM THE PUBLIC SEWER NETWORK. ALTERNATIVE METHODS OF DISPOSAL OF THE LAND DRAINAGE RUNOFF SHALL THEREFORE BE REQUIRED AND YOU WILL NEED TO CONSULT WITH THE LOCAL AUTHORITY LAND DRAINAGE SECTION REGARDING THE DISPOSAL OF THE FILTER DRAINAGE DRAINAGE RUNOFF.
 - 30 LITRE RESISTANT PIPES PROVIDED PROVIDING THAT SUCH PRECAUTIONS ARE NOT NECESSARY.
 - THE ADOPTABLE LEVELS SHALL BE A MINIMUM OF 150MM ABOVE THE FINISHED FLOOR LEVELS AND SERVICE MARGINS.
 - SEWERS MUST HAVE A MINIMUM CLEARANCE FROM TREES AND HEDGES. PLEASE ALSO REFER TO FIGURE 2.3 ON PAGE 31 IN 'SEWERS FOR ADDITION ETH EDITION FOR RESTRICTIONS ON TREE PLANTING ADJACENT TO SEWERS'.
 - SEWERS TO BE LAD IN CLASS 'S' BEDDING (NON GRANULAR BEDS AND SURROUND). WHERE DEPTH OF COVER TO TOP OF THE SEWER IS LESS THAN 1.0M PERMANENT AND HEDGES GRASS FROM BRAM IN A NON VERTICAL ACCESS AREAS THEN A CONCRETE SLAB SHOULD BE PROVIDED ABOVE GRANULAR BED AND SURROUND.
 - CLASS 2 BEDDING DETAIL SHALL BE PROVIDED WHERE COVER TO THE PIPE BARREL IS LESS THAN 1.0M IN VERTICAL OR 1.5M IN HORIZONTAL. DETAIL TO BE PROVIDED TO ALL ROAD GULLY CONNECTIONS AND WITHIN AREA OF DEEP FOOTING DRAINAGE.
 - WHERE CLASS 2 TRENCH BEDDING DETAIL IS USED, THE CONCRETE BED AND SURROUND SHALL BE BEDDING AND SHALL BE MANHOLE TO CONFORM TO THE REQUIREMENT OF WATER AUTHORITY SPECIFICATION 4.8.6 (TABLE A2).
 - THE COVER SIZE OF MANHOLES WITH MORE THAN ONE CONNECTION IN THEM MAY NEED TO BE INCREASED AN INCREMENT TO ACCOMMODATE THE CONNECTIONS AND BENCH.
 - ALL PRIVATE DRAINAGE WORKS SHALL BE CARRIED OUT ACCORDING WITH BUILDING REGULATIONS 2022 EDITION.
 - CONTRACTOR TO ESTABLISH POSITION SIZE AND DEPTH OF ALL EXISTING SEWERS AND SERVICES PRIOR TO COMMENCEMENT OF WORK.
 - THE CONTRACTOR SHALL ALLOW FOR THE PROTECTION, TEMPORARY AND PERMANENT SUPPORT AND TEMPORARY AND PERMANENT DIVERSION WORKS, AS NECESSARY TO ALL EXISTING SERVICES AND SEWER WORKS.
 - THE CONTRACTOR SHALL ALLOW FOR KEEPING SEWER TRENCHES AND EXCAVATIONS AS DRY AS PRACTICABLE BY PUMPING FROM TEMPORARY PUMPS AND DE-WATERING AS APPROPRIATE. THE POINT AND METHOD OF DISCHARGE TO BE AGREED WITH THE DRAINAGE AUTHORITY.
 - FOR PIPE SPECIFICATION PLEASE REFER TO ADDITIONAL NOTES.
 - WHERE CLAY PIPES AND FITTINGS ARE USED, ALL PIPES SHALL BE EXTRA STRENGTH TO BS 6841 AND SHALL BE KITEMARKED WITH THE RELEVANT PROVIDER OF BS EN 845 OR EQUIVALENT BS EN 845 PIPE CLOSING STRENGTH.
 - STRUCTURED MANHOLE PIPES TO BE USED FOR SURFACE WATER DRAINAGE, SUBJECT TO ADOPTING AUTHORITY APPROVAL.
 - PRECAST CONCRETE PRODUCTS SHALL COMPLY WITH THE RELEVANT PROVIDER OF BS EN 12451 AND KITEMARKED. CONCRETE PIPES TO BE CLASS 'S' UNLESS NOTED OTHERWISE.
 - GULLY GRATES AND FRAMES SHALL COMPLY WITH THE RELEVANT PROVIDER OF BS EN 12451 AND BE A NON-SKIDDING DESIGN WITH CAPTURE CHANGE ACCESS AND BE KITEMARKED. LOAD CLASS SHALL BE IN ACCORDANCE WITH THE REQUIREMENTS AND SPECIFICATION OF THE AUTHORITY APPROVAL. IN THE ABSENCE OF SUCH INFORMATION, THE REQUIREMENTS OF THE 'STREET WORKS REGULATIONS 1987 AND RELEVANT PROVISIONS OF BS EN 12451 SHALL APPLY FOR THE DESIGN OF OPENING HIGHWAYS JANE 1987, BOTH UNDER SECTION 11 OF THE NEW ROADS AND STREET WORKS ACT 1991.
 - ALL TRADITIONAL MANHOLE TOPS DOWN COVER TO MANUFACTURER SPECIFICATION.
 - ALL SYNCHRONIC DRAINAGE DOWN COVER TO MANUFACTURER SPECIFICATION.
 - ALL GULLY LEADS TO BE 300mm DIAMETER.
 - ALL REQUIREMENTS FOR DRAINAGE TO BE KITEMARKED AND RECORDED UPON COMPLETION OF WORKS.
 - ALL ROAD GULLIES TO BE CLEANED AND RECORDED UPON COMPLETION OF WORKS.
 - THE CONTRACTOR MUST ENSURE THAT ANY OF THE EXISTING DRAINAGE WORKS IS KEPT CLEAR OF SEWERS AND SHOULD ALLOW FOR SETTING THROUGH THE NEW EXISTING DRAINAGE UPON COMPLETION.
 - CONTRACTOR TO TAKE MEASURES TO PROTECT HIS OPERATIVES WITH RESPECT TO THE PRESENCE OF GAS IN SEWER TRENCHES AND MANHOLES THROUGH THE USE OF GAS MONITORING EQUIPMENT AND BREATHING APPARATUS AS REQUIRED.
 - CONTRACTOR TO AVOID FOR SEWER PRIVATE AND ROAD OPENING POINTS AS NECESSARY FROM THE APPROPRIATE AUTHORITIES. PRIOR TO COMMENCING WORKS.
 - ADDITIONAL PLASTIC DRAINAGE PIPES TO BE LAD IN MANHOLE IN CONTACT UNLESS THERE IS A SPECIFIC OPERATIONAL NEED TO LAY LONGER LENGTHS.
 - WHERE PLASTIC PIPES ARE INSTALLED PRIOR TO SETTING APPROVAL, THEN A LIGHT LINE CCTV SURVEY AND REPORT ARE REQUIRED PRIOR TO APPROVAL.

DRAINAGE SUMMARY

SURFACE WATER

- PERMEABLE PAVEMENT: 0.25% & 0.25% PLUS URBAN CREEP
- PRIVATE DRIVEWAYS TO BE OPEN GRADED POROUS ASPHALT
- SHARED DRIVEWAYS TO BE PERMEABLE GRAVEL, TO DEVELOPERS SPECIFICATION
- AS BORN DRIVEWAYS TO BE OPEN GRADED POROUS ASPHALT UNDER THE HIGHWAY BASED ON MICRO DRAINAGE CALCULATIONS
- ROAD AND DRIVEWAYS TO BE INSTALLED IN AN OFFLINE GEO CELLULAR STORAGE TANK
- VOLUME TRIP BASED ON MICRO DRAINAGE CALCULATIONS
- DRAINAGE TO DISCHARGE TO EXISTING SURFACE WATER MANHOLE OR ON FILL WITH DRAINAGE AT A RESTRICTED RATE OF 50 L/S DRAINAGE TO BE CCTV SURVEYED PRIOR TO COMMENCEMENT OF SETTING APPROVAL TO CONFIRM CONDITIONS INVERT LEVELS OF EXISTING DRAINAGE.

FLOOD WATER

- FLOOD WATER TO DISCHARGE AT AN UNRESTRICTED RATE OF 1.8M³ TO EXISTING UTILITIES FLOOD WATER MANHOLE EXIST ON FILL NEW DRIVE DRAINAGE TO BE CCTV SURVEYED PRIOR TO COMMENCEMENT OF SETTING APPROVAL TO CONFIRM CONDITIONS INVERT LEVELS OF EXISTING DRAINAGE
- ALL FLOODS ARE DRAIN VIA PRIVATE GRAVITY NETWORK TO PROPOSED ACCEPTABLE MANHOLE (W)

- DRAINAGE NOTES**
- ALL PIPES 300 UNLESS OTHERWISE STATED.
 - ALL PRIVATE TO ACCEPTABLE CONNECTIONS 150 UNLESS OTHERWISE STATED.
 - ALL PIPES IN TRAFFICED AREAS TO HAVE SAND COVERS & CONCRETE SURROUND.
 - ALL INTERNAL FLOOD DRAINAGE REQUIRES COOPERATION PRIOR TO CONSTRUCTION.
 - CONTRACTOR TO CONFIRM MANHOLE INVERT LEVEL OF PROPOSED CONNECTION POINT PRIOR TO CONSTRUCTION. ANY VARIATION MUST BE REPORTED TO ENGINEER.
 - THE INVERT LEVELS OF THE EXISTING SEWERS ARE TO BE VERIFIED PRIOR TO COMMENCEMENT OF ANY DRAINAGE WORKS. ANY DISCREPANCY MUST BE REPORTED TO THE ENGINEER.
 - EXISTING MANHOLES TO BE MODIFIED TO ACCOMMODATE THE PROPOSED LATERAL CONNECTIONS. CONTRACTOR TO ADVISE TO THE WATER AUTHORITY FOR THE SECTION 106 APPROVAL. TO MAKE THE CONNECTIONS. PIPES ARE TO BE LAD WITH COMMON INVERT LEVELS.
 - ALL EXISTING PIPES ARE TO BE CAPPED.
 - ALL EXISTING CONNECTIONS TO BE 20 DEGREES UNLESS OTHERWISE STATED. REFER TO MANHOLE SCHEDULE FOR FURTHER INFORMATION.
 - STONE FILLED LAND DRAINS REQUIRED IN BACK GARDENS WHERE FALLING TOWARDS PROPERTY.

- PRE-MATERIALS**
- 150-2250 UPVC PIPES TO BE BS KITEMARKED AND CERTIFIED TO BS 4341 & BS EN 12451
 - 300-600 CONCRETE PIPES TO BE BS KITEMARKED, CLASS 120 CONCRETE & CERTIFIED TO BS EN 12451
 - 300-600 CONCRETE STEEL REINFORCED PPE (AGAS/PA) TO BE BS KITEMARKED & CERTIFIED TO BS EN 12451

SUBJECT TO LOCAL AUTHORITY & WATER AUTHORITY APPROVAL

DRN/NO	REVISION	DATE	BY	CHKD	REV
06/20/20	LATCHUP DETAIL ADDED		AE	RWD	0
10/05/20	REVISED TO LATEST DRAINAGE PLAN		AE	RWD	1
10/05/20	FOOTWAY GRATED TO SERVICE STRIP		MS	AE	4
27/09/20	REVISED TO LATEST DRAINAGE PLAN		AE	RWD	3
10/05/20	REVISED SW AND PERMEABLE OUTLET DESIGN		AE	RWD	2
06/05/20	FIRST ISSUE		JS	AE	1

INFORMATION

NORTH EAST
 0191 258922

YORKSHIRE
 0148 90480

RWO
 CONSULTING ENGINEERS
 WWW.RWOCONSULTANTS.COM
 RW@RWOCONSULTANTS.COM

Client: GLEESON HOMES

Project: FELL VIEW DRIVE, EGREMONT

Plan: POROUS PAVING PLAN

DO NOT SCALE: Scale @ A2: 1:200 | Draw: AE | Check: RD | Date: 06/09/2019
 Job No: 18184 | Day No: D204 | Rev: 6