

Coast Consulting Engineers Ltd		Page 0
Suite 6, Vita House Fish Quay North Shields NE30 1JA	FLOSH MEADOWS CLEATOR	
Date 12/10/2021 File 211012 REVISED COMBINED...	Designed by RH Checked by PL	
Innovyze	Network 2020.1	

STORM SEWER DESIGN by the Modified Rational Method

Network Design Table for 180518 SW1.SWS

PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Section Type	Auto Design
1.000	41.957	0.420	99.9	0.049	5.00	0.0	0.600	o	150	Pipe/Conduit	
1.001	53.639	1.516	35.4	0.083	0.00	0.0	0.600	o	225	Pipe/Conduit	
1.002	31.512	0.770	40.9	0.096	0.00	0.0	0.600	o	225	Pipe/Conduit	
1.003	25.483	0.255	100.0	0.104	0.00	0.0	0.600	o	225	Pipe/Conduit	
1.004	17.652	0.177	100.0	0.035	0.00	0.0	0.600	o	300	Pipe/Conduit	
1.005	18.982	0.077	245.0	0.028	0.00	0.0	0.600	o	300	Pipe/Conduit	
1.006	13.655	0.192	71.1	0.029	0.00	0.0	0.600	o	375	Pipe/Conduit	
2.000	71.706	0.718	99.9	0.095	5.00	0.0	0.600	o	150	Pipe/Conduit	
2.001	37.730	0.314	120.2	0.195	0.00	0.0	0.600	o	225	Pipe/Conduit	
2.002	22.253	0.091	245.0	0.078	0.00	0.0	0.600	o	300	Pipe/Conduit	
2.003	33.218	0.136	245.0	0.065	0.00	0.0	0.600	o	375	Pipe/Conduit	
2.004	13.246	0.033	400.0	0.062	0.00	0.0	0.600	o	825	Pipe/Conduit	
2.005	14.105	0.035	400.0	0.042	0.00	0.0	0.600	o	825	Pipe/Conduit	
1.007	24.092	0.048	501.9	0.021	0.00	0.0	0.600	o	825	Pipe/Conduit	
1.008	21.726	0.041	529.9	0.029	0.00	0.0	0.600	o	825	Pipe/Conduit	
3.000	15.459	0.039	400.0	0.070	5.00	0.0	0.600	o	825	Pipe/Conduit	
1.009	13.858	0.082	170.0	0.000	0.00	0.0	0.600	o	225	Pipe/Conduit	

Network Results Table

PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)
1.000	0.00	5.70	64.855	0.049	0.0	0.0	0.0	1.01	17.8	0.0
1.001	0.00	6.10	64.360	0.132	0.0	0.0	0.0	2.21	87.7	0.0
1.002	0.00	6.36	62.844	0.228	0.0	0.0	0.0	2.05	81.5	0.0
1.003	0.00	6.68	62.074	0.332	0.0	0.0	0.0	1.31	52.0	0.0
1.004	0.00	6.87	61.744	0.367	0.0	0.0	0.0	1.57	111.1	0.0
1.005	0.00	7.19	61.568	0.395	0.0	0.0	0.0	1.00	70.7	0.0
1.006	0.00	7.29	61.415	0.424	0.0	0.0	0.0	2.15	237.6	0.0
2.000	0.00	6.19	62.776	0.095	0.0	0.0	0.0	1.01	17.8	0.0
2.001	0.00	6.72	61.983	0.290	0.0	0.0	0.0	1.19	47.4	0.0
2.002	0.00	7.09	61.594	0.368	0.0	0.0	0.0	1.00	70.7	0.0
2.003	0.00	7.57	61.428	0.433	0.0	0.0	0.0	1.15	127.4	0.0
2.004	0.00	7.72	60.843	0.495	0.0	0.0	0.0	1.48	790.2	0.0
2.005	0.00	7.88	60.809	0.537	0.0	0.0	0.0	1.48	790.2	0.0
1.007	0.00	8.18	60.773	0.982	0.0	0.0	0.0	1.32	704.7	0.0
1.008	0.00	8.46	60.725	1.011	0.0	0.0	0.0	1.28	685.7	0.0
3.000	0.00	5.17	61.323	0.070	0.0	0.0	0.0	1.48	790.2	0.0
1.009	0.00	8.69	60.684	1.081	0.0	0.0	0.0	1.00	39.8	0.0

Coast Consulting Engineers Ltd										Page 1	
Suite 6, Vita House Fish Quay North Shields NE30 1JA					FLOSH MEADOWS CLEATOR						
Date 12/10/2021					Designed by RH						
File 211012 REVISED COMBINED...					Checked by PL						
Innovyze					Network 2020.1						

STORM SEWER DESIGN by the Modified Rational Method

Network Design Table for 180518 SW1.SWS

PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Section Type	Auto Design
1.010	4.168	0.025	170.0	0.000	0.00	0.0	0.600	o	225	Pipe/Conduit	

Network Results Table

PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)
1.010	0.00	8.76	60.603	1.081	0.0	0.0	0.0	1.00	39.8	0.0

Free Flowing Outfall Details for 180518 SW1.SWS

Outfall Pipe Number	Outfall Name	C. Level (m)	I. Level (m)	Min I. Level (m)	D,L (mm)	W (mm)
1.010	C1	63.006	60.578	60.578	1350	0

Simulation Criteria for 180518 SW1.SWS

Volumetric Runoff Coeff	0.750	Additional Flow - % of Total Flow	0.000
Areal Reduction Factor	1.000	MADD Factor * 10m³/ha Storage	2.000
Hot Start (mins)	0	Inlet Coefficient	0.800
Hot Start Level (mm)	0	Flow per Person per Day (l/per/day)	0.000
Manhole Headloss Coeff (Global)	0.500	Run Time (mins)	60
Foul Sewage per hectare (l/s)	0.000	Output Interval (mins)	1
Number of Input Hydrographs	0	Number of Storage Structures	13
Number of Online Controls	3	Number of Time/Area Diagrams	0
Number of Offline Controls	0	Number of Real Time Controls	0

Synthetic Rainfall Details

Rainfall Model	FSR	Profile Type	Summer
Return Period (years)	2	Cv (Summer)	0.750
Region	England and Wales	Cv (Winter)	0.840
M5-60 (mm)	19.600	Storm Duration (mins)	30
Ratio R	0.223		

©1982-2020 Innovyze

Coast Consulting Engineers Ltd		Page 2
Suite 6, Vita House Fish Quay North Shields NE30 1JA	FLOSH MEADOWS CLEATOR	
Date 12/10/2021 File 211012 REVISED COMBINED...	Designed by RH Checked by PL	
Innovyze	Network 2020.1	

Online Controls for 180518 SW1.SWS

Hydro-Brake® Optimum Manhole: 3, DS/PN: 1.002, Volume (m³): 5.0

Unit Reference MD-SHE-0075-3400-2049-3400
Design Head (m) 2.049
Design Flow (l/s) 3.4
Flush-Flo™ Calculated
Objective Minimise upstream storage
Application Surface
Sump Available Yes
Diameter (mm) 75
Invert Level (m) 62.844
Minimum Outlet Pipe Diameter (mm) 100
Suggested Manhole Diameter (mm) 1200

Control Points	Head (m)	Flow (l/s)
Design Point (Calculated)	2.049	3.4
Flush-Flo™	0.327	2.5
Kick-Flo®	0.667	2.0
Mean Flow over Head Range	-	2.6

The hydrological calculations have been based on the Head/Discharge relationship for the Hydro-Brake® Optimum as specified. Should another type of control device other than a Hydro-Brake Optimum® be utilised then these storage routing calculations will be invalidated

Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)
0.100	2.0	1.200	2.7	3.000	4.1	7.000	6.0
0.200	2.4	1.400	2.8	3.500	4.4	7.500	6.2
0.300	2.5	1.600	3.0	4.000	4.6	8.000	6.4
0.400	2.5	1.800	3.2	4.500	4.9	8.500	6.6
0.500	2.4	2.000	3.4	5.000	5.2	9.000	6.8
0.600	2.3	2.200	3.5	5.500	5.4	9.500	7.0
0.800	2.2	2.400	3.7	6.000	5.6		
1.000	2.4	2.600	3.8	6.500	5.8		

Hydro-Brake® Optimum Manhole: 10, DS/PN: 2.002, Volume (m³): 3.8

Unit Reference MD-SHE-0075-3100-1610-3100
Design Head (m) 1.610
Design Flow (l/s) 3.1
Flush-Flo™ Calculated
Objective Minimise upstream storage
Application Surface
Sump Available Yes
Diameter (mm) 75
Invert Level (m) 61.594
Minimum Outlet Pipe Diameter (mm) 100
Suggested Manhole Diameter (mm) 1200

Coast Consulting Engineers Ltd			Page 3																																																																									
Suite 6, Vita House Fish Quay North Shields NE30 1JA		FLOSH MEADOWS CLEATOR																																																																										
Date 12/10/2021 File 211012 REVISED COMBINED...		Designed by RH Checked by PL																																																																										
Innovyze		Network 2020.1																																																																										
<u>Hydro-Brake® Optimum Manhole: 10, DS/PN: 2.002, Volume (m³): 3.8</u>																																																																												
<table><thead><tr><th>Control Points</th><th>Head (m)</th><th>Flow (l/s)</th></tr></thead><tbody><tr><td>Design Point (Calculated)</td><td>1.610</td><td>3.1</td></tr><tr><td>Flush-Flo™</td><td>0.330</td><td>2.6</td></tr><tr><td>Kick-Flo®</td><td>0.672</td><td>2.1</td></tr><tr><td>Mean Flow over Head Range</td><td>-</td><td>2.5</td></tr></tbody></table>					Control Points	Head (m)	Flow (l/s)	Design Point (Calculated)	1.610	3.1	Flush-Flo™	0.330	2.6	Kick-Flo®	0.672	2.1	Mean Flow over Head Range	-	2.5																																																									
Control Points	Head (m)	Flow (l/s)																																																																										
Design Point (Calculated)	1.610	3.1																																																																										
Flush-Flo™	0.330	2.6																																																																										
Kick-Flo®	0.672	2.1																																																																										
Mean Flow over Head Range	-	2.5																																																																										
The hydrological calculations have been based on the Head/Discharge relationship for the Hydro-Brake® Optimum as specified. Should another type of control device other than a Hydro-Brake Optimum® be utilised then these storage routing calculations will be invalidated																																																																												
<table><thead><tr><th>Depth (m)</th><th>Flow (l/s)</th><th>Depth (m)</th><th>Flow (l/s)</th><th>Depth (m)</th><th>Flow (l/s)</th><th>Depth (m)</th><th>Flow (l/s)</th></tr></thead><tbody><tr><td>0.100</td><td>2.1</td><td>1.200</td><td>2.7</td><td>3.000</td><td>4.1</td><td>7.000</td><td>6.1</td></tr><tr><td>0.200</td><td>2.5</td><td>1.400</td><td>2.9</td><td>3.500</td><td>4.4</td><td>7.500</td><td>6.3</td></tr><tr><td>0.300</td><td>2.6</td><td>1.600</td><td>3.1</td><td>4.000</td><td>4.7</td><td>8.000</td><td>6.5</td></tr><tr><td>0.400</td><td>2.6</td><td>1.800</td><td>3.3</td><td>4.500</td><td>5.0</td><td>8.500</td><td>6.7</td></tr><tr><td>0.500</td><td>2.5</td><td>2.000</td><td>3.4</td><td>5.000</td><td>5.2</td><td>9.000</td><td>6.9</td></tr><tr><td>0.600</td><td>2.3</td><td>2.200</td><td>3.6</td><td>5.500</td><td>5.5</td><td>9.500</td><td>7.1</td></tr><tr><td>0.800</td><td>2.2</td><td>2.400</td><td>3.7</td><td>6.000</td><td>5.7</td><td></td><td></td></tr><tr><td>1.000</td><td>2.5</td><td>2.600</td><td>3.9</td><td>6.500</td><td>5.9</td><td></td><td></td></tr></tbody></table>					Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	0.100	2.1	1.200	2.7	3.000	4.1	7.000	6.1	0.200	2.5	1.400	2.9	3.500	4.4	7.500	6.3	0.300	2.6	1.600	3.1	4.000	4.7	8.000	6.5	0.400	2.6	1.800	3.3	4.500	5.0	8.500	6.7	0.500	2.5	2.000	3.4	5.000	5.2	9.000	6.9	0.600	2.3	2.200	3.6	5.500	5.5	9.500	7.1	0.800	2.2	2.400	3.7	6.000	5.7			1.000	2.5	2.600	3.9	6.500	5.9		
Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)																																																																					
0.100	2.1	1.200	2.7	3.000	4.1	7.000	6.1																																																																					
0.200	2.5	1.400	2.9	3.500	4.4	7.500	6.3																																																																					
0.300	2.6	1.600	3.1	4.000	4.7	8.000	6.5																																																																					
0.400	2.6	1.800	3.3	4.500	5.0	8.500	6.7																																																																					
0.500	2.5	2.000	3.4	5.000	5.2	9.000	6.9																																																																					
0.600	2.3	2.200	3.6	5.500	5.5	9.500	7.1																																																																					
0.800	2.2	2.400	3.7	6.000	5.7																																																																							
1.000	2.5	2.600	3.9	6.500	5.9																																																																							
<u>Hydro-Brake® Optimum Manhole: 17 HB, DS/PN: 1.009, Volume (m³): 30.3</u>																																																																												
<table><tbody><tr><td>Unit Reference</td><td colspan="4">MD-SHE-0089-5000-2299-5000</td></tr><tr><td>Design Head (m)</td><td colspan="4">2.299</td></tr><tr><td>Design Flow (l/s)</td><td colspan="4">5.0</td></tr><tr><td>Flush-Flo™</td><td colspan="4">Calculated</td></tr><tr><td>Objective</td><td colspan="4">Minimise upstream storage</td></tr><tr><td>Application</td><td colspan="4">Surface</td></tr><tr><td>Sump Available</td><td colspan="4">Yes</td></tr><tr><td>Diameter (mm)</td><td colspan="4">89</td></tr><tr><td>Invert Level (m)</td><td colspan="4">60.684</td></tr><tr><td>Minimum Outlet Pipe Diameter (mm)</td><td colspan="4">150</td></tr><tr><td>Suggested Manhole Diameter (mm)</td><td colspan="4">1200</td></tr></tbody></table>					Unit Reference	MD-SHE-0089-5000-2299-5000				Design Head (m)	2.299				Design Flow (l/s)	5.0				Flush-Flo™	Calculated				Objective	Minimise upstream storage				Application	Surface				Sump Available	Yes				Diameter (mm)	89				Invert Level (m)	60.684				Minimum Outlet Pipe Diameter (mm)	150				Suggested Manhole Diameter (mm)	1200																				
Unit Reference	MD-SHE-0089-5000-2299-5000																																																																											
Design Head (m)	2.299																																																																											
Design Flow (l/s)	5.0																																																																											
Flush-Flo™	Calculated																																																																											
Objective	Minimise upstream storage																																																																											
Application	Surface																																																																											
Sump Available	Yes																																																																											
Diameter (mm)	89																																																																											
Invert Level (m)	60.684																																																																											
Minimum Outlet Pipe Diameter (mm)	150																																																																											
Suggested Manhole Diameter (mm)	1200																																																																											
<table><thead><tr><th>Control Points</th><th>Head (m)</th><th>Flow (l/s)</th></tr></thead><tbody><tr><td>Design Point (Calculated)</td><td>2.299</td><td>5.0</td></tr><tr><td>Flush-Flo™</td><td>0.384</td><td>3.8</td></tr><tr><td>Kick-Flo®</td><td>0.790</td><td>3.1</td></tr><tr><td>Mean Flow over Head Range</td><td>-</td><td>3.8</td></tr></tbody></table>					Control Points	Head (m)	Flow (l/s)	Design Point (Calculated)	2.299	5.0	Flush-Flo™	0.384	3.8	Kick-Flo®	0.790	3.1	Mean Flow over Head Range	-	3.8																																																									
Control Points	Head (m)	Flow (l/s)																																																																										
Design Point (Calculated)	2.299	5.0																																																																										
Flush-Flo™	0.384	3.8																																																																										
Kick-Flo®	0.790	3.1																																																																										
Mean Flow over Head Range	-	3.8																																																																										
The hydrological calculations have been based on the Head/Discharge relationship for the Hydro-Brake® Optimum as specified. Should another type of control device other than a Hydro-Brake Optimum® be utilised then these storage routing calculations will be invalidated																																																																												
<table><thead><tr><th>Depth (m)</th><th>Flow (l/s)</th><th>Depth (m)</th><th>Flow (l/s)</th><th>Depth (m)</th><th>Flow (l/s)</th><th>Depth (m)</th><th>Flow (l/s)</th></tr></thead><tbody><tr><td>0.100</td><td>2.7</td><td>0.300</td><td>3.8</td><td>0.500</td><td>3.8</td><td>0.800</td><td>3.1</td></tr><tr><td>0.200</td><td>3.6</td><td>0.400</td><td>3.8</td><td>0.600</td><td>3.7</td><td>1.000</td><td>3.4</td></tr></tbody></table>					Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	0.100	2.7	0.300	3.8	0.500	3.8	0.800	3.1	0.200	3.6	0.400	3.8	0.600	3.7	1.000	3.4																																																
Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)																																																																					
0.100	2.7	0.300	3.8	0.500	3.8	0.800	3.1																																																																					
0.200	3.6	0.400	3.8	0.600	3.7	1.000	3.4																																																																					
©1982-2020 Innovyze																																																																												

Coast Consulting Engineers Ltd		Page 5																																																																								
Suite 6, Vita House Fish Quay North Shields NE30 1JA	FLOSH MEADOWS CLEATOR																																																																									
Date 12/10/2021 File 211012 REVISED COMBINED...	Designed by RH Checked by PL																																																																									
Innovyze	Network 2020.1																																																																									
Storage Structures for 180518 SW1.SWS Cellular Storage Manhole: 1, DS/PN: 1.000 Invert Level (m) 63.655 Safety Factor 2.0 Infiltration Coefficient Base (m/hr) 0.00000 Porosity 0.95 Infiltration Coefficient Side (m/hr) 0.00000 <table><tr><th>Depth (m)</th><th>Area (m²)</th><th>Inf. Area (m²)</th><th>Depth (m)</th><th>Area (m²)</th><th>Inf. Area (m²)</th></tr><tr><td>0.000</td><td>51.8</td><td>0.0</td><td>0.521</td><td>0.0</td><td>0.0</td></tr><tr><td>0.520</td><td>51.8</td><td>0.0</td><td></td><td></td><td></td></tr></table> Cellular Storage Manhole: 2, DS/PN: 1.001 Invert Level (m) 64.360 Safety Factor 2.0 Infiltration Coefficient Base (m/hr) 0.00000 Porosity 0.95 Infiltration Coefficient Side (m/hr) 0.00000 <table><tr><th>Depth (m)</th><th>Area (m²)</th><th>Inf. Area (m²)</th><th>Depth (m)</th><th>Area (m²)</th><th>Inf. Area (m²)</th></tr><tr><td>0.000</td><td>207.0</td><td>0.0</td><td>0.521</td><td>0.0</td><td>0.0</td></tr><tr><td>0.520</td><td>207.0</td><td>0.0</td><td></td><td></td><td></td></tr></table> Cellular Storage Manhole: 4, DS/PN: 1.003 Invert Level (m) 62.074 Safety Factor 2.0 Infiltration Coefficient Base (m/hr) 0.00000 Porosity 0.95 Infiltration Coefficient Side (m/hr) 0.00000 <table><tr><th>Depth (m)</th><th>Area (m²)</th><th>Inf. Area (m²)</th><th>Depth (m)</th><th>Area (m²)</th><th>Inf. Area (m²)</th></tr><tr><td>0.000</td><td>129.5</td><td>0.0</td><td>0.521</td><td>0.0</td><td>0.0</td></tr><tr><td>0.520</td><td>129.5</td><td>0.0</td><td></td><td></td><td></td></tr></table> Cellular Storage Manhole: 6, DS/PN: 1.005 Invert Level (m) 61.568 Safety Factor 2.0 Infiltration Coefficient Base (m/hr) 0.00000 Porosity 0.95 Infiltration Coefficient Side (m/hr) 0.00000 <table><tr><th>Depth (m)</th><th>Area (m²)</th><th>Inf. Area (m²)</th><th>Depth (m)</th><th>Area (m²)</th><th>Inf. Area (m²)</th></tr><tr><td>0.000</td><td>25.9</td><td>0.0</td><td>0.521</td><td>0.0</td><td>0.0</td></tr><tr><td>0.520</td><td>25.9</td><td>0.0</td><td></td><td></td><td></td></tr></table> Cellular Storage Manhole: 7, DS/PN: 1.006 Invert Level (m) 61.415 Safety Factor 2.0 Infiltration Coefficient Base (m/hr) 0.00000 Porosity 0.95 Infiltration Coefficient Side (m/hr) 0.00000			Depth (m)	Area (m²)	Inf. Area (m²)	Depth (m)	Area (m²)	Inf. Area (m²)	0.000	51.8	0.0	0.521	0.0	0.0	0.520	51.8	0.0				Depth (m)	Area (m²)	Inf. Area (m²)	Depth (m)	Area (m²)	Inf. Area (m²)	0.000	207.0	0.0	0.521	0.0	0.0	0.520	207.0	0.0				Depth (m)	Area (m²)	Inf. Area (m²)	Depth (m)	Area (m²)	Inf. Area (m²)	0.000	129.5	0.0	0.521	0.0	0.0	0.520	129.5	0.0				Depth (m)	Area (m²)	Inf. Area (m²)	Depth (m)	Area (m²)	Inf. Area (m²)	0.000	25.9	0.0	0.521	0.0	0.0	0.520	25.9	0.0			
Depth (m)	Area (m²)	Inf. Area (m²)	Depth (m)	Area (m²)	Inf. Area (m²)																																																																					
0.000	51.8	0.0	0.521	0.0	0.0																																																																					
0.520	51.8	0.0																																																																								
Depth (m)	Area (m²)	Inf. Area (m²)	Depth (m)	Area (m²)	Inf. Area (m²)																																																																					
0.000	207.0	0.0	0.521	0.0	0.0																																																																					
0.520	207.0	0.0																																																																								
Depth (m)	Area (m²)	Inf. Area (m²)	Depth (m)	Area (m²)	Inf. Area (m²)																																																																					
0.000	129.5	0.0	0.521	0.0	0.0																																																																					
0.520	129.5	0.0																																																																								
Depth (m)	Area (m²)	Inf. Area (m²)	Depth (m)	Area (m²)	Inf. Area (m²)																																																																					
0.000	25.9	0.0	0.521	0.0	0.0																																																																					
0.520	25.9	0.0																																																																								
©1982-2020 Innovyze																																																																										

Coast Consulting Engineers Ltd			Page 6																																																																																												
Suite 6, Vita House Fish Quay North Shields NE30 1JA		FLOSH MEADOWS CLEATOR																																																																																													
Date 12/10/2021 File 211012 REVISED COMBINED...		Designed by RH Checked by PL																																																																																													
Innovyze		Network 2020.1																																																																																													
<u>Cellular Storage Manhole: 7, DS/PN: 1.006</u> <table><tr><th>Depth (m)</th><th>Area (m²)</th><th>Inf. Area (m²)</th><th>Depth (m)</th><th>Area (m²)</th><th>Inf. Area (m²)</th></tr><tr><td>0.000</td><td>25.9</td><td>0.0</td><td>0.521</td><td>0.0</td><td>0.0</td></tr><tr><td>0.520</td><td>25.9</td><td>0.0</td><td></td><td></td><td></td></tr></table> <u>Cellular Storage Manhole: 8, DS/PN: 2.000</u> Invert Level (m) 62.776 Safety Factor 2.0 Infiltration Coefficient Base (m/hr) 0.00000 Porosity 0.95 Infiltration Coefficient Side (m/hr) 0.00000 <table><tr><th>Depth (m)</th><th>Area (m²)</th><th>Inf. Area (m²)</th><th>Depth (m)</th><th>Area (m²)</th><th>Inf. Area (m²)</th></tr><tr><td>0.000</td><td>77.7</td><td>0.0</td><td>0.521</td><td>0.0</td><td>0.0</td></tr><tr><td>0.520</td><td>77.7</td><td>0.0</td><td></td><td></td><td></td></tr></table> <u>Cellular Storage Manhole: 9, DS/PN: 2.001</u> Invert Level (m) 61.983 Safety Factor 2.0 Infiltration Coefficient Base (m/hr) 0.00000 Porosity 0.95 Infiltration Coefficient Side (m/hr) 0.00000 <table><tr><th>Depth (m)</th><th>Area (m²)</th><th>Inf. Area (m²)</th><th>Depth (m)</th><th>Area (m²)</th><th>Inf. Area (m²)</th></tr><tr><td>0.000</td><td>388.5</td><td>0.0</td><td>0.521</td><td>0.0</td><td>0.0</td></tr><tr><td>0.520</td><td>388.5</td><td>0.0</td><td></td><td></td><td></td></tr></table> <u>Cellular Storage Manhole: 10, DS/PN: 2.002</u> Invert Level (m) 61.594 Safety Factor 2.0 Infiltration Coefficient Base (m/hr) 0.00000 Porosity 0.95 Infiltration Coefficient Side (m/hr) 0.00000 <table><tr><th>Depth (m)</th><th>Area (m²)</th><th>Inf. Area (m²)</th><th>Depth (m)</th><th>Area (m²)</th><th>Inf. Area (m²)</th></tr><tr><td>0.000</td><td>103.6</td><td>0.0</td><td>0.521</td><td>0.0</td><td>0.0</td></tr><tr><td>0.520</td><td>103.6</td><td>0.0</td><td></td><td></td><td></td></tr></table> <u>Cellular Storage Manhole: 11, DS/PN: 2.003</u> Invert Level (m) 61.428 Safety Factor 2.0 Infiltration Coefficient Base (m/hr) 0.00000 Porosity 0.95 Infiltration Coefficient Side (m/hr) 0.00000 <table><tr><th>Depth (m)</th><th>Area (m²)</th><th>Inf. Area (m²)</th><th>Depth (m)</th><th>Area (m²)</th><th>Inf. Area (m²)</th></tr><tr><td>0.000</td><td>181.4</td><td>0.0</td><td>0.521</td><td>0.0</td><td>0.0</td></tr><tr><td>0.520</td><td>181.4</td><td>0.0</td><td></td><td></td><td></td></tr></table>						Depth (m)	Area (m²)	Inf. Area (m²)	Depth (m)	Area (m²)	Inf. Area (m²)	0.000	25.9	0.0	0.521	0.0	0.0	0.520	25.9	0.0				Depth (m)	Area (m²)	Inf. Area (m²)	Depth (m)	Area (m²)	Inf. Area (m²)	0.000	77.7	0.0	0.521	0.0	0.0	0.520	77.7	0.0				Depth (m)	Area (m²)	Inf. Area (m²)	Depth (m)	Area (m²)	Inf. Area (m²)	0.000	388.5	0.0	0.521	0.0	0.0	0.520	388.5	0.0				Depth (m)	Area (m²)	Inf. Area (m²)	Depth (m)	Area (m²)	Inf. Area (m²)	0.000	103.6	0.0	0.521	0.0	0.0	0.520	103.6	0.0				Depth (m)	Area (m²)	Inf. Area (m²)	Depth (m)	Area (m²)	Inf. Area (m²)	0.000	181.4	0.0	0.521	0.0	0.0	0.520	181.4	0.0			
Depth (m)	Area (m²)	Inf. Area (m²)	Depth (m)	Area (m²)	Inf. Area (m²)																																																																																										
0.000	25.9	0.0	0.521	0.0	0.0																																																																																										
0.520	25.9	0.0																																																																																													
Depth (m)	Area (m²)	Inf. Area (m²)	Depth (m)	Area (m²)	Inf. Area (m²)																																																																																										
0.000	77.7	0.0	0.521	0.0	0.0																																																																																										
0.520	77.7	0.0																																																																																													
Depth (m)	Area (m²)	Inf. Area (m²)	Depth (m)	Area (m²)	Inf. Area (m²)																																																																																										
0.000	388.5	0.0	0.521	0.0	0.0																																																																																										
0.520	388.5	0.0																																																																																													
Depth (m)	Area (m²)	Inf. Area (m²)	Depth (m)	Area (m²)	Inf. Area (m²)																																																																																										
0.000	103.6	0.0	0.521	0.0	0.0																																																																																										
0.520	103.6	0.0																																																																																													
Depth (m)	Area (m²)	Inf. Area (m²)	Depth (m)	Area (m²)	Inf. Area (m²)																																																																																										
0.000	181.4	0.0	0.521	0.0	0.0																																																																																										
0.520	181.4	0.0																																																																																													
©1982-2020 Innovyze																																																																																															

Coast Consulting Engineers Ltd		Page 7																																																																								
Suite 6, Vita House Fish Quay North Shields NE30 1JA	FLOSH MEADOWS CLEATOR																																																																									
Date 12/10/2021 File 211012 REVISED COMBINED...	Designed by RH Checked by PL																																																																									
Innovyze	Network 2020.1																																																																									
Cellular Storage Manhole: 12, DS/PN: 2.004 Invert Level (m) 60.868 Safety Factor 2.0 Infiltration Coefficient Base (m/hr) 0.00000 Porosity 0.95 Infiltration Coefficient Side (m/hr) 0.00000 <table><tr><th>Depth (m)</th><th>Area (m²)</th><th>Inf. Area (m²)</th><th>Depth (m)</th><th>Area (m²)</th><th>Inf. Area (m²)</th></tr><tr><td>0.000</td><td>129.5</td><td>0.0</td><td>0.521</td><td>0.0</td><td>0.0</td></tr><tr><td>0.520</td><td>129.5</td><td>0.0</td><td></td><td></td><td></td></tr></table> Cellular Storage Manhole: 15, DS/PN: 1.008 Invert Level (m) 60.783 Safety Factor 2.0 Infiltration Coefficient Base (m/hr) 0.00000 Porosity 0.95 Infiltration Coefficient Side (m/hr) 0.00000 <table><tr><th>Depth (m)</th><th>Area (m²)</th><th>Inf. Area (m²)</th><th>Depth (m)</th><th>Area (m²)</th><th>Inf. Area (m²)</th></tr><tr><td>0.000</td><td>25.9</td><td>0.0</td><td>0.521</td><td>0.0</td><td>0.0</td></tr><tr><td>0.520</td><td>25.9</td><td>0.0</td><td></td><td></td><td></td></tr></table> Cellular Storage Manhole: 16, DS/PN: 3.000 Invert Level (m) 61.323 Safety Factor 2.0 Infiltration Coefficient Base (m/hr) 0.00000 Porosity 0.95 Infiltration Coefficient Side (m/hr) 0.00000 <table><tr><th>Depth (m)</th><th>Area (m²)</th><th>Inf. Area (m²)</th><th>Depth (m)</th><th>Area (m²)</th><th>Inf. Area (m²)</th></tr><tr><td>0.000</td><td>51.8</td><td>0.0</td><td>0.521</td><td>0.0</td><td>0.0</td></tr><tr><td>0.520</td><td>51.8</td><td>0.0</td><td></td><td></td><td></td></tr></table> Cellular Storage Manhole: 17 HB, DS/PN: 1.009 Invert Level (m) 60.684 Safety Factor 2.0 Infiltration Coefficient Base (m/hr) 0.00000 Porosity 0.95 Infiltration Coefficient Side (m/hr) 0.00000 <table><tr><th>Depth (m)</th><th>Area (m²)</th><th>Inf. Area (m²)</th><th>Depth (m)</th><th>Area (m²)</th><th>Inf. Area (m²)</th></tr><tr><td>0.000</td><td>77.7</td><td>0.0</td><td>0.521</td><td>0.0</td><td>0.0</td></tr><tr><td>0.520</td><td>77.7</td><td>0.0</td><td></td><td></td><td></td></tr></table>			Depth (m)	Area (m²)	Inf. Area (m²)	Depth (m)	Area (m²)	Inf. Area (m²)	0.000	129.5	0.0	0.521	0.0	0.0	0.520	129.5	0.0				Depth (m)	Area (m²)	Inf. Area (m²)	Depth (m)	Area (m²)	Inf. Area (m²)	0.000	25.9	0.0	0.521	0.0	0.0	0.520	25.9	0.0				Depth (m)	Area (m²)	Inf. Area (m²)	Depth (m)	Area (m²)	Inf. Area (m²)	0.000	51.8	0.0	0.521	0.0	0.0	0.520	51.8	0.0				Depth (m)	Area (m²)	Inf. Area (m²)	Depth (m)	Area (m²)	Inf. Area (m²)	0.000	77.7	0.0	0.521	0.0	0.0	0.520	77.7	0.0			
Depth (m)	Area (m²)	Inf. Area (m²)	Depth (m)	Area (m²)	Inf. Area (m²)																																																																					
0.000	129.5	0.0	0.521	0.0	0.0																																																																					
0.520	129.5	0.0																																																																								
Depth (m)	Area (m²)	Inf. Area (m²)	Depth (m)	Area (m²)	Inf. Area (m²)																																																																					
0.000	25.9	0.0	0.521	0.0	0.0																																																																					
0.520	25.9	0.0																																																																								
Depth (m)	Area (m²)	Inf. Area (m²)	Depth (m)	Area (m²)	Inf. Area (m²)																																																																					
0.000	51.8	0.0	0.521	0.0	0.0																																																																					
0.520	51.8	0.0																																																																								
Depth (m)	Area (m²)	Inf. Area (m²)	Depth (m)	Area (m²)	Inf. Area (m²)																																																																					
0.000	77.7	0.0	0.521	0.0	0.0																																																																					
0.520	77.7	0.0																																																																								
©1982-2020 Innovyze																																																																										

Coast Consulting Engineers Ltd

Page 8

Suite 6, Vita House
Fish Quay
North Shields NE30 1JA

FLOSH MEADOWS
CLEATOR

Date 12/10/2021
File 211012 REVISED COMBINED...

Designed by RH
Checked by PL

Innovyze

Network 2020.1

Micro Drainage

Summary of Critical Results by Maximum Level (Rank 1) for 180518 SW1.SWS

Simulation Criteria

Areal Reduction Factor 1.000

Additional Flow - % of Total Flow 0.000

Hot Start (mins) 0

MADD Factor * 10m³/ha Storage 2.000

Hot Start Level (mm) 0

Inlet Coefficient 0.800

Manhole Headloss Coeff (Global) 0.500

Flow per Person per Day (l/per/day) 0.000

Foul Sewage per hectare (l/s) 0.000

Number of Input Hydrographs 0

Number of Storage Structures 13

Number of Online Controls 3

Number of Time/Area Diagrams 0

Number of Offline Controls 0

Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model FSR

Ratio R 0.220

Region England and Wales Cv (Summer) 0.750

M5-60 (mm) 18.600 Cv (Winter) 0.840

Margin for Flood Risk Warning (mm) 300.0

Analysis Timestep 2.5 Second Increment (Extended)

DTS Status OFF

DVD Status OFF

Inertia Status OFF

Profile(s) Summer and Winter

Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440

Return Period(s) (years) 30

Climate Change (%) 0

WARNING: Half Drain Time has not been calculated as the structure is too full.

PN	US/MH Name	Storm	Return Period	Climate Change	First (X) Surge	First (Y) Flood	First (Z) Overflow	Overflow Act.	Water Level (m)
1.000	1	1440 Winter	30	+0%					64.876
1.001	2	240 Winter	30	+0%					64.535
1.002	3	30 Winter	30	+0%	30/15 Summer				64.684
1.003	4	1440 Winter	30	+0%					62.269
1.004	5	1440 Winter	30	+0%	30/720 Winter				62.263
1.005	6	1440 Winter	30	+0%	30/600 Winter				62.261
1.006	7	1440 Winter	30	+0%	30/480 Winter				62.258
2.000	8	30 Winter	30	+0%					62.877
2.001	9	1440 Winter	30	+0%	30/360 Winter				62.292
2.002	10	1440 Winter	30	+0%	30/30 Winter				62.289
2.003	11	1440 Winter	30	+0%	30/480 Winter				62.257
2.004	12	1440 Winter	30	+0%	30/360 Summer				62.257
2.005	13	1440 Winter	30	+0%	30/240 Winter				62.257
1.007	14	1440 Winter	30	+0%	30/240 Winter				62.257
1.008	15	1440 Winter	30	+0%	30/180 Winter				62.257
3.000	16	1440 Winter	30	+0%	30/960 Winter				62.257

©1982-2020 Innovyze

Coast Consulting Engineers Ltd		Page 9
Suite 6, Vita House Fish Quay North Shields NE30 1JA	FLOSH MEADOWS CLEATOR	
Date 12/10/2021 File 211012 REVISED COMBINED...	Designed by RH Checked by PL	
Innovyze	Network 2020.1	

Summary of Critical Results by Maximum Level (Rank 1) for 180518 SW1.SWS

PN	US/MH Name	Depth (m)	Surcharged Flooded		Flow / Overflow Cap. (l/s)	Half Drain Time (mins)	Pipe Flow (l/s)	Status	Level Exceeded
			Volume (m³)	Flow					
1.000	1	-0.129	0.000	0.05			0.8	OK	
1.001	2	-0.050	0.000	0.04		138	3.0	OK	
1.002	3	1.615	0.000	0.04			3.2	FLOOD RISK	
1.003	4	-0.030	0.000	0.11		291	5.4	OK	
1.004	5	0.219	0.000	0.06			6.2	SURCHARGED	
1.005	6	0.393	0.000	0.11		988	6.8	SURCHARGED	
1.006	7	0.468	0.000	0.04		1451	7.4	SURCHARGED	
2.000	8	-0.049	0.000	0.78		15	13.7	OK	
2.001	9	0.084	0.000	0.12		488	5.6	SURCHARGED	
2.002	10	0.395	0.000	0.04		1074	2.6	SURCHARGED	
2.003	11	0.454	0.000	0.03		1445	4.0	SURCHARGED	
2.004	12	0.589	0.000	0.01			4.2	SURCHARGED	
2.005	13	0.622	0.000	0.01			3.7	SURCHARGED	
1.007	14	0.659	0.000	0.02			9.4	SURCHARGED	
1.008	15	0.707	0.000	0.02			8.6	SURCHARGED	
3.000	16	0.109	0.000	0.00		1653	1.5	SURCHARGED	

Coast Consulting Engineers Ltd		Page 10
Suite 6, Vita House Fish Quay North Shields NE30 1JA	FLOSH MEADOWS CLEATOR	
Date 12/10/2021 File 211012 REVISED COMBINED...	Designed by RH Checked by PL	
Innovyze	Network 2020.1	

Summary of Critical Results by Maximum Level (Rank 1) for 180518 SW1.SWS

US/MH		Return Climate		First (X)	First (Y)	First (Z)	Overflow	Water
PN	Name	Storm	Period	Change	Surcharge	Flood	Overflow	Act. Level
								(m)
1.009	17 HB	1440 Winter	30	+0%	30/15 Summer			62.257
1.010	18	1440 Winter	30	+0%				60.661

US/MH		Surcharged	Flooded	Half Drain		Pipe	Level	
PN	Name	Depth (m)	Volume (m³)	Flow / Cap.	Overflow (l/s)	Time (mins)	Flow (l/s)	Status Exceeded
1.009	17 HB	1.348	0.000	0.12			4.2	SURCHARGED
1.010	18	-0.167	0.000	0.15			4.2	OK