

Copeland Borough Council
Development Control
The Copeland Centre Catherine Street
Whitehaven
Cumbria
CA28 7SJ

Our ref: NO/2024/116339/01-L01
Your ref: 4/24/2318/0B1
Date: 03 October 2024

Dear Sir/Madam

VARIATION OF CONDITIONS 2, 3, 4, 5, 6, 7 AND 18 (PLOT 5 ONLY) OF PLANNING APPROVAL 4/23/2082/0F1 - RESIDENTIAL DEVELOPMENT CONSISTING OF 8 DWELLINGS AND ASSOCIATED INFRASTRUCTURE.

LAND AT NORTH LANE, HAVERIGG

Thank you for consulting us on the above application, received 25 September 2024.

Environment Agency position

We have no objection to the proposed development but we wish to make the following informative comments:-

Foul drainage – advice to applicant

In addition to planning permission you may also require an Environmental Permit from the Environment Agency. Please note that the granting of planning permission does not guarantee the granting of an Environmental Permit. Upon receipt of a correctly filled in application form we will carry out an assessment. It can take up to 4 months before we are in a position to decide whether to grant a permit or not.

Domestic effluent discharged from a treatment plant/septic tank at 2 cubic metres or less to ground or 5 cubic metres or less to surface water in any 24 hour period must comply with General Binding Rules provided that no public foul sewer is available to serve the development and that the site is not within an inner Groundwater Source Protection Zone.

A soakaway used to serve a non-mains drainage system must be sited no less than 10 metres from the nearest watercourse, not less than 10 metres from any other foul soakaway and not less than 50 metres from the nearest potable water supply.

Environment Agency
Lutra House Walton Summit, Bamber Bridge, Preston, PR5 8BX.
Customer services line: 03708 506 506
www.gov.uk/environment-agency

Cont/d..

Where the proposed development involves the connection of foul drainage to an existing non-mains drainage system, the applicant should ensure that it is in a good state of repair, regularly de-sludged and of sufficient capacity to deal with any potential increase in flow and loading which may occur as a result of the development.

Where the existing non-mains drainage system is covered by a permit to discharge then an application to vary the permit will need to be made to reflect the increase in volume being discharged. It can take up to 13 weeks before we decide whether to vary a permit.

Further advice is available at: [Septic tanks and sewage treatment plants: what you need to do: Overview - GOV.UK \(www.gov.uk\)](https://www.gov.uk/guidance/septic-tanks-and-sewage-treatment-plants-what-you-need-to-do)

Environmental permit - advice to applicant

Stoup Dub Branch watercourse is designated main river and runs in open channel along the south-eastern boundary of the site.

It is noted that the Proposed Site Plan- Master drawing 22-15-P-32 Rev. B, indicates that access to the southern field is retained as part of the proposals, at present we cannot say that the access provision will be satisfactory to facilitate access for Environment Agency to undertake programmed aquatic vegetation management. We would normally require an 8m wide access for plant to allow for a 2m safety buffer from the top of the bank and sufficient room to manoeuvre medium plant equipment.

The Environmental Permitting (England and Wales) Regulations 2016 require a permit to be obtained for any activities which will take place:

- on or within 8 metres of a main river (16 metres if tidal)
- on or within 8 metres of a flood defence structure or culverted main river (16 metres if tidal)
- on or within 16 metres of a sea defence
- involving quarrying or excavation within 16 metres of any main river, flood defence (including a remote defence) or culvert
- in the floodplain of a main river if the activity could affect flood flow or storage and potential impacts are not controlled by a planning permission

For further guidance please visit <https://www.gov.uk/guidance/flood-risk-activities-environmental-permits> or contact our National Customer Contact Centre on 03708 506 506. The applicant should not assume that a permit will automatically be forthcoming once planning permission has been granted, and we advise them to consult with us at the earliest opportunity.

Yours faithfully

Miss Soraya Moghaddam
Planning Advisor

Direct e-mail clplanning@environment-agency.gov.uk