


A L Daines & Partners		Page 1
28 Castle Street Carlisle CA3 8TP	Nethertown Rd, St Bees Plot 1 soakaway	
Date 17/08/2021 13:21 File PLOT 1.MDX	Designed by SM Checked by	
Micro Drainage	Network 2020.1	

STORM SEWER DESIGN by the Modified Rational Method

Design Criteria for Storm

Pipe Sizes STANDARD Manhole Sizes STANDARD

FSR Rainfall Model - England and Wales

Return Period (years)	100
M5-60 (mm)	16.000
Ratio R	0.274
Maximum Rainfall (mm/hr)	50
Maximum Time of Concentration (mins)	30
Foul Sewage (l/s/ha)	0.000
Volumetric Runoff Coeff.	1.000
PIMP (%)	100
Add Flow / Climate Change (%)	40
Minimum Backdrop Height (m)	0.200
Maximum Backdrop Height (m)	1.500
Min Design Depth for Optimisation (m)	1.200
Min Vel for Auto Design only (m/s)	1.00
Min Slope for Optimisation (1:X)	500


Designed with Level Soffits

Simulation Criteria for Storm

Volumetric Runoff Coeff	1.000	Additional Flow - % of Total Flow	0.000
Areal Reduction Factor	1.000	MADD Factor * 10m ³ /ha Storage	2.000
Hot Start (mins)	0	Inlet Coefficient	0.800
Hot Start Level (mm)	0	Flow per Person per Day (l/per/day)	0.000
Manhole Headloss Coeff (Global)	0.500	Run Time (mins)	60
Foul Sewage per hectare (l/s)	0.000	Output Interval (mins)	1
Number of Input Hydrographs	0	Number of Storage Structures	1
Number of Online Controls	0	Number of Time/Area Diagrams	0
Number of Offline Controls	0	Number of Real Time Controls	0

Synthetic Rainfall Details

Rainfall Model	FSR	Profile Type	Summer
Return Period (years)	100	Cv (Summer)	1.000
Region	England and Wales	Cv (Winter)	1.000
M5-60 (mm)	16.000	Storm Duration (mins)	30
Ratio R	0.274		


A L Daines & Partners		Page 2
28 Castle Street Carlisle CA3 8TP	Nethertown Rd, St Bees Plot 1 soakaway	
Date 17/08/2021 13:21 File PLOT 1.MDX	Designed by SM Checked by	
Micro Drainage	Network 2020.1	

Storage Structures for Storm

Cellular Storage Manhole: S2, DS/PN: S1.001

Invert Level (m) 36.800
 Infiltration Coefficient Base (m/hr) 0.05510
 Infiltration Coefficient Side (m/hr) 0.05510
 Safety Factor 2.0
 Porosity 0.95

Depth (m)	Area (m ²)	Inf. Area (m ²)	Depth (m)	Area (m ²)	Inf. Area (m ²)
0.000	27.0	27.0	0.401	0.0	36.6
0.400	27.0	36.6			

A L Daines & Partners		Page 3
28 Castle Street Carlisle CA3 8TP	Nethertown Rd, St Bees Plot 1 soakaway	
Date 17/08/2021 13:21 File PLOT 1.MDX	Designed by SM Checked by	
Micro Drainage	Network 2020.1	

1 year Return Period Summary of Critical Results by Maximum Level (Rank 1) for Storm

Simulation Criteria

Areal Reduction Factor 1.000 Additional Flow - % of Total Flow 0.000
Hot Start (mins) 0 MADD Factor * 10m³/ha Storage 2.000
Hot Start Level (mm) 0 Inlet Coefficient 0.800
Manhole Headloss Coeff (Global) 0.500 Flow per Person per Day (l/per/day) 0.000
Foul Sewage per hectare (l/s) 0.000

Number of Input Hydrographs 0 Number of Storage Structures 1
Number of Online Controls 0 Number of Time/Area Diagrams 0
Number of Offline Controls 0 Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model FSR Ratio R 0.274
Region England and Wales Cv (Summer) 0.850
M5-60 (mm) 16.000 Cv (Winter) 0.950


Margin for Flood Risk Warning (mm) 300.0 DVD Status OFF
Analysis Timestep Fine Inertia Status OFF
DTS Status ON

Profile(s)

Profile(s) Summer and Winter
Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360
Return Period(s) (years) 1, 30, 100
Climate Change (%) 0, 40, 40

PN	US/MH Name	Storm	Return Period	Climate Change	First (X) Surchage	First (Y) Flood	First (Z) Overflow	Overflow Act.	Water Level (m)
S1.000	S1	15 Winter	1	+0%					37.649
S1.001	S2	240 Winter	1	+0%					36.863

PN	US/MH Name	Surcharged Depth (m)	Flooded Volume (m ³)	Flow / Cap. (l/s)	Overflow (l/s)	Half Drain Time (mins)	Pipe Flow (l/s)	Level Status	Exceeded
S1.000	S1	-0.101	0.000	0.23			2.1	OK	
S1.001	S2	-0.887	0.000	0.00		120	0.0	OK	

A L Daines & Partners		Page 4
28 Castle Street Carlisle CA3 8TP	Nethertown Rd, St Bees Plot 1 soakaway	
Date 17/08/2021 13:21 File PLOT 1.MDX	Designed by SM Checked by	
Micro Drainage	Network 2020.1	

30 year Return Period Summary of Critical Results by Maximum Level (Rank 1) for Storm

Simulation Criteria

Areal Reduction Factor 1.000 Additional Flow - % of Total Flow 0.000
Hot Start (mins) 0 MADD Factor * 10m³/ha Storage 2.000
Hot Start Level (mm) 0 Inlet Coefficient 0.800
Manhole Headloss Coeff (Global) 0.500 Flow per Person per Day (l/per/day) 0.000
Foul Sewage per hectare (l/s) 0.000

Number of Input Hydrographs 0 Number of Storage Structures 1
Number of Online Controls 0 Number of Time/Area Diagrams 0
Number of Offline Controls 0 Number of Real Time Controls 0

Synthetic Rainfall Details


Rainfall Model FSR Ratio R 0.274
Region England and Wales Cv (Summer) 0.850
M5-60 (mm) 16.000 Cv (Winter) 0.950

Margin for Flood Risk Warning (mm) 300.0 DVD Status OFF
Analysis Timestep Fine Inertia Status OFF
DTS Status ON

Profile(s) Summer and Winter
Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360
Return Period(s) (years) 1, 30, 100
Climate Change (%) 0, 40, 40

PN	US/MH Name	Storm	Return Period	Climate Change	First (X) Surge	First (Y) Flood	First (Z) Overflow	Overflow Act.	Water Level (m)
S1.000	S1	15 Winter	30	+40%					37.702
S1.001	S2	360 Winter	30	+40%					37.086

PN	US/MH Name	Surcharged Depth (m)	Flooded Volume (m ³)	Flow / Cap. (l/s)	Overflow (l/s)	Half Drain Time (mins)	Pipe Flow (l/s)	Status	Level Exceeded
S1.000	S1	-0.048	0.000	0.77			7.0	FLOOD RISK	
S1.001	S2	-0.664	0.000	0.00		324	0.0	OK	

A L Daines & Partners		Page 5
28 Castle Street Carlisle CA3 8TP	Nethertown Rd, St Bees Plot 1 soakaway	
Date 17/08/2021 13:21 File PLOT 1.MDX	Designed by SM Checked by	
Micro Drainage	Network 2020.1	

100 year Return Period Summary of Critical Results by Maximum Level (Rank 1) for Storm

Simulation Criteria

Areal Reduction Factor 1.000 Additional Flow - % of Total Flow 0.000
Hot Start (mins) 0 MADD Factor * 10m³/ha Storage 2.000
Hot Start Level (mm) 0 Inlet Coefficient 0.800
Manhole Headloss Coeff (Global) 0.500 Flow per Person per Day (l/per/day) 0.000
Foul Sewage per hectare (l/s) 0.000

Number of Input Hydrographs 0 Number of Storage Structures 1
Number of Online Controls 0 Number of Time/Area Diagrams 0
Number of Offline Controls 0 Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model FSR Ratio R 0.274
Region England and Wales Cv (Summer) 0.850
M5-60 (mm) 16.000 Cv (Winter) 0.950

Margin for Flood Risk Warning (mm) 300.0 DVD Status OFF
Analysis Timestep Fine Inertia Status OFF
DTS Status ON

Profile(s) Summer and Winter
Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360
Return Period(s) (years) 1, 30, 100
Climate Change (%) 0, 40, 40

PN	US/MH Name	Storm	Return Period	Climate Change	First (X) Surcharge	First (Y) Flood	First (Z) Overflow	Overflow Act.	Water Level (m)
S1.000	S1	15 Winter	100	+40%					37.723
S1.001	S2	360 Winter	100	+40%					37.199

PN	US/MH Name	Surcharged Depth (m)	Flooded Volume (m ³)	Flow / Cap. (l/s)	Overflow (l/s)	Half Drain Time (mins)	Pipe Flow (l/s)	Status	Level Exceeded
S1.000	S1	-0.027	0.000	0.99			9.0	FLOOD RISK	
S1.001	S2	-0.551	0.000	0.00		360	0.0	OK	