


A L Daines & Partners		Page 1
28 Castle Street Carlisle CA3 8TP	Nethertown Rd, St Bees Plot 1 soakaway	
Date 31/03/2022 16:09 File Plot 1 rev A.MDX	Designed by SM Checked by	
Micro Drainage	Network 2020.1.3	

STORM SEWER DESIGN by the Modified Rational Method

Design Criteria for Storm



Pipe Sizes STANDARD Manhole Sizes STANDARD

FSR Rainfall Model - England and Wales

Return Period (years)	100	PIMP (%)	100
M5-60 (mm)	16.000	Add Flow / Climate Change (%)	40
Ratio R	0.274	Minimum Backdrop Height (m)	0.200
Maximum Rainfall (mm/hr)	50	Maximum Backdrop Height (m)	1.500
Maximum Time of Concentration (mins)	30	Min Design Depth for Optimisation (m)	1.200
Foul Sewage (l/s/ha)	0.000	Min Vel for Auto Design only (m/s)	1.00
Volumetric Runoff Coeff.	1.000	Min Slope for Optimisation (1:X)	500


Designed with Level Soffits

Network Design Table for Storm

PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Section Type	Auto Design
S1.000	5.000	0.013	384.6	0.017	5.00	0.0	0.600	o	150	Pipe/Conduit	
S1.001	5.000	0.013	384.6	0.000	0.00	0.0	0.600	o	150	Pipe/Conduit	


Network Results Table

PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)
S1.000	50.00	5.16	37.600	0.017	0.0	0.0	1.2	0.51	9.0	4.3
S1.001	50.00	5.33	37.600	0.017	0.0	0.0	1.2	0.51	9.0	4.3

A L Daines & Partners		Page 2
28 Castle Street Carlisle CA3 8TP	Nethertown Rd, St Bees Plot 1 soakaway	
Date 31/03/2022 16:09 File Plot 1 rev A.MDX	Designed by SM Checked by	
Micro Drainage	Network 2020.1.3	

Area Summary for Storm

Pipe Number	PIMP Type	PIMP Name	PIMP (%)	Gross Area (ha)	Imp. Area (ha)	Pipe Total (ha)
1.000	-	-	100	0.017	0.017	0.017
1.001	-	-	100	0.000	0.000	0.000
				Total	Total	Total
				0.017	0.017	0.017


A L Daines & Partners		Page 3
28 Castle Street Carlisle CA3 8TP	Nethertown Rd, St Bees Plot 1 soakaway	
Date 31/03/2022 16:09 File Plot 1 rev A.MDX	Designed by SM Checked by	
Micro Drainage	Network 2020.1.3	

Storage Structures for Storm

Cellular Storage Manhole: S2, DS/PN: S1.001

Invert Level (m) 36.800 Safety Factor 2.0
 Infiltration Coefficient Base (m/hr) 0.05510 Porosity 0.95
 Infiltration Coefficient Side (m/hr) 0.05510

Depth (m)	Area (m ²)	Inf. Area (m ²)	Depth (m)	Area (m ²)	Inf. Area (m ²)
0.000	27.0	27.0	0.401	0.0	36.6
0.400	27.0	36.6			

A L Daines & Partners		Page 4
28 Castle Street Carlisle CA3 8TP	Nethertown Rd, St Bees Plot 1 soakaway	
Date 31/03/2022 16:09 File Plot 1 rev A.MDX	Designed by SM Checked by	
Micro Drainage	Network 2020.1.3	

1 year Return Period Summary of Critical Results by Maximum Level (Rank 1)
for Storm

Simulation Criteria

Areal Reduction Factor 1.000 Additional Flow - % of Total Flow 0.000
Hot Start (mins) 0 MADD Factor * 10m³/ha Storage 2.000
Hot Start Level (mm) 0 Inlet Coefficient 0.800
Manhole Headloss Coeff (Global) 0.500 Flow per Person per Day (l/per/day) 0.000
Foul Sewage per hectare (l/s) 0.000

Number of Input Hydrographs 0 Number of Storage Structures 1
Number of Online Controls 0 Number of Time/Area Diagrams 0
Number of Offline Controls 0 Number of Real Time Controls 0

Synthetic Rainfall Details


Rainfall Model FSR Ratio R 0.274
Region England and Wales Cv (Summer) 0.850
M5-60 (mm) 16.000 Cv (Winter) 0.950

Margin for Flood Risk Warning (mm) 300.0 DVD Status OFF
Analysis Timestep Fine Inertia Status OFF
DTS Status ON

Profile(s) Summer and Winter
Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360
Return Period(s) (years) 1, 30, 100
Climate Change (%) 0, 40, 40

PN	US/MH Name	Storm	Return Period	Climate Change	First (X) Surcharge	First (Y) Flood	First (Z) Overflow	Overflow Act.	Water Level (m)
S1.000	S1	15 Winter	1	+0%					37.646
S1.001	S2	240 Winter	1	+0%					36.855

PN	US/MH Name	Depth (m)	Volume (m ³)	Flow / Cap. (l/s)	Overflow (l/s)	Half Drain Time (mins)	Pipe Flow (l/s)	Status	Level Exceeded
S1.000	S1	-0.104	0.000	0.21			1.9	OK	
S1.001	S2	-0.895	0.000	0.00		116	0.0	OK	

A L Daines & Partners		Page 5
28 Castle Street Carlisle CA3 8TP	Nethertown Rd, St Bees Plot 1 soakaway	
Date 31/03/2022 16:09 File Plot 1 rev A.MDX	Designed by SM Checked by	
Micro Drainage	Network 2020.1.3	

30 year Return Period Summary of Critical Results by Maximum Level (Rank 1)
for Storm

Simulation Criteria

Areal Reduction Factor 1.000 Additional Flow - % of Total Flow 0.000
Hot Start (mins) 0 MADD Factor * 10m³/ha Storage 2.000
Hot Start Level (mm) 0 Inlet Coefficient 0.800
Manhole Headloss Coeff (Global) 0.500 Flow per Person per Day (l/per/day) 0.000
Foul Sewage per hectare (l/s) 0.000

Number of Input Hydrographs 0 Number of Storage Structures 1
Number of Online Controls 0 Number of Time/Area Diagrams 0
Number of Offline Controls 0 Number of Real Time Controls 0

Synthetic Rainfall Details


Rainfall Model FSR Ratio R 0.274
Region England and Wales Cv (Summer) 0.850
M5-60 (mm) 16.000 Cv (Winter) 0.950

Margin for Flood Risk Warning (mm) 300.0 DVD Status OFF
Analysis Timestep Fine Inertia Status OFF
DTS Status ON

Profile(s) Summer and Winter
Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360
Return Period(s) (years) 1, 30, 100
Climate Change (%) 0, 40, 40

PN	US/MH Name	Storm	Return Period	Climate Change	First (X) Surcharge	First (Y) Flood	First (Z) Overflow	Overflow Act.	Water Level (m)
S1.000	S1	15 Winter	30	+40%					37.694
S1.001	S2	360 Winter	30	+40%					37.048

PN	US/MH Name	Depth (m)	Volume (m ³)	Flow / Cap. (l/s)	Overflow (l/s)	Half Drain Time (mins)	Pipe Flow (l/s)	Status	Level Exceeded
S1.000	S1	-0.056	0.000	0.69			6.3	OK	
S1.001	S2	-0.702	0.000	0.00		300	0.0	OK	

A L Daines & Partners		Page 6
28 Castle Street Carlisle CA3 8TP	Nethertown Rd, St Bees Plot 1 soakaway	
Date 31/03/2022 16:09 File Plot 1 rev A.MDX	Designed by SM Checked by	
Micro Drainage	Network 2020.1.3	

100 year Return Period Summary of Critical Results by Maximum Level (Rank 1) for Storm

Simulation Criteria

Areal Reduction Factor 1.000 Additional Flow - % of Total Flow 0.000
Hot Start (mins) 0 MADD Factor * 10m³/ha Storage 2.000
Hot Start Level (mm) 0 Inlet Coefficient 0.800
Manhole Headloss Coeff (Global) 0.500 Flow per Person per Day (l/per/day) 0.000
Foul Sewage per hectare (l/s) 0.000

Number of Input Hydrographs 0 Number of Storage Structures 1
Number of Online Controls 0 Number of Time/Area Diagrams 0
Number of Offline Controls 0 Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model FSR Ratio R 0.274
Region England and Wales Cv (Summer) 0.850
M5-60 (mm) 16.000 Cv (Winter) 0.950

Margin for Flood Risk Warning (mm) 300.0 DVD Status OFF
Analysis Timestep Fine Inertia Status OFF
DTS Status ON

Profile(s) Summer and Winter
Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360
Return Period(s) (years) 1, 30, 100
Climate Change (%) 0, 40, 40

PN	US/MH Name	Storm	Return Period	Climate Change	First (X) Surge	First (Y) Flood	First (Z) Overflow	Water Level (m)
S1.000	S1	15 Winter	100	+40%				37.712
S1.001	S2	360 Winter	100	+40%				37.146

PN	US/MH Name	Surcharged Depth (m)	Flooded Volume (m ³)	Flow / Overflow Cap. (l/s)	Half Drain Time (mins)	Pipe Flow (l/s)	Level Exceeded
S1.000	S1	-0.038	0.000	0.88		8.0	FLOOD RISK
S1.001	S2	-0.604	0.000	0.00	336	0.0	OK