





HEALTH & SAFETY NOTES: 1) Excavation works should be carried out carefully by hand. 2) A C.A.T. (Cable Avoidance Tool) survey should be carried out to locate any possible services. Hand dig trial holes to locate services as necessary. 3) Ensure that individuals lift within their own capabilities & employ appropriate handling techniques to do this. SELF LOCKING CATCH AS ALTERNATIVE TO AUTOLATCH 1600 (GATE WIDTH) AS DIRECTED BY CCC STAFF (BETWEEN POSTS) **AUTO LATCH** OFFSET BOTTOM CROOK WITH LEVER LEFT OF TOP CROOK BY APPROX. 30mm TO MAKE GATE SELF CLOSE

G.L.V

"ROCK" POSTS INTO

PLACE OR INSTALL IN

CONCRETE WHERE

SPECIFIED

The gate and new fencing will be installed by a local forcing contractor.

ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE STATED

- 1.TOP & BOTTOM RAIL TO BE MORTICED FULL WIDTH WITH 13mm DIA. OAK DOWELS. OTHERS HALF MORTICED TO STILES & BOLTED TO RAILS. BRACES TO BE MORTICED TO STILES & BOLTED TO RAILS.
- 2. GATES TO BE EUROPEAN LARCH. POSTS TO BE SOFTWOOD FACTORY PRESSURE IMPREGNATED WITH "TANOLITH" OR EQUIVALENT TO BS4072 (TO BE UNDERTAKEN II ACCORDANCE WITH BS5268). ALL CUTS TO BE SIMILARLY TREATED
- 3.GATES TO BE FITTED WITH CAPITIVE HINGE SET AS DETAILED. BOTTOM FITTING ADJUSTABLE. GATES MUST BE SELF CLOSING BY OFFSETTING THE CROOKS.
- 4. GATE TO BE FITTED WITH SPECIALISED GATE FITTING EASY LATCH TYPE KIT (3rc RAIL FITTING) OR, IF SPECIFIED, AN AUTO LATCH WITH LEVER UNLESS OTHERWISE
- 5. ALL METAL FITTINGS & SCREWS TO BE GALVANISED TO BS729
- 6. GATES TO OPEN AS DETAILED ON DRAWING
- 7. GATES AND INSTALLATION TO COMPLY WITH BS5709.
- 8. GATES TO BE SITED ON LEVEL GROUND.
- 9. CONCRETE TO BE ST2 MIX AS PER BS5328. MIX RATIO 1 CEMENT; 3 SAND;6 20mm AGGREGATE. 50 - 75mm SLUMP

DESCRIPTION OF TIMBER MATERAILS HANGING POST SHUTTING POST HANGING STILE SHUTTING STILE TOP RAIL UNDER RAILS

SIZE(mm)

200 X 200 X 2200LG. 175 X 175 X 2200LG. 100 X 75 100 X 75 TAPERING TO 75 X 75

75 X 25 75 X 75

BRACES HOUSED IN TOP RAIL

County Council

CLIMBRIA COLINITY COLINICII

BRIDLEGATE Title:

500

CONC. TO BE ST2 MIX AS

PER BS5328. MIX RATIO 1

CEMENT; 3 SAND; 6 20mm

AGGREGATE. 50 - 75 SLUMP

	Drawing No. Job Log.			
	Scale: NTS			
	Drawn	D.CLARE	Date: FEB 08	Rev NOV 14
	Checked	*	-	

Cumbria County Council The Parkhouse Building Kingmoor Business Park Carlisle Cumbria