

**TWEDDELL
& SLATER**

CONSULTING
CIVIL & STRUCTURAL
ENGINEERS

Unit 2, Mereside
Greenbank Road
Eden Business Park
Gilwilly, Penrith
Cumbria, CA11 9FB

**PROPOSED NEW HOUSING DEVELOPMENT
MORESBY PARKS – CUMBRIA
5TH APRIL 2022**

**OPERATION AND MAINTENANCE PLAN
SURFACE WATER DRAINAGE SYSTEM**

April 5th, 2022

DIRECTORS

E. Slater BSc (Hons) CEng MStrucE

S. C. Mair BSc (Hons) CEng MStrucE MICE

R. J. Gibson BEng (Hons) CEng MStrucE

Tel 01768 865400 **Fax** 01768 865002

Email mail@tsce.uk.com

www.tsce.uk.com

1. INTRODUCTION

It is proposed that the entire surface water system on site will be adopted by United Utilities (UU) therefore will be under the maintenance of UU. This will include the actual detention basin.

Volume Control

The detention basin has been designed such that it will not be surcharged in events up to 100 years recurrence. The discharge rate is to be restricted by a Hydro brake controlling the discharge rate to 8.1 l/s.

Structural Integrity

The proposed surface water drainage systems has been designed to Building Regulations to ensure the structural integrity under the anticipated loading conditions over the design life. This includes the cover to pipes that has been designed in accordance with the manufacture's requirements and specification.

2.0 GENERAL DRAINAGE SYSTEM

MAINTENANCE SCHEDULE	REQUIRED ACTION	RECOMMENDED FREQUENCY
Ongoing Monitoring United Utilities	Inspect/check all upstream drainage inlets, outlets, vents and gullies to ensure that they are in good condition and operating as designed.	Annually and after large storm events
Remedial Actions United Utilities	Repair/rehabilitation of inlets, outlets, overflows and vents. Removal of oil and grease. Replacement of malfunctioning parts.	As required

3.0 DETENTION BASIN

MAINTENANCE SCHEDULE	REQUIRED ACTION	RECOMMENDED FREQUENCY
Ongoing Monitoring /Maintenance Basin United Utilities	Inspect and identify any areas upstream and downstream of the basin that are not operating correctly (i.e. road gullies, interceptor, filter drains). If required, take remedial action.	Monthly for first three months, then six monthly thereafter.
	Remove debris from basin (may cause risks to performance).	Monthly for first three months, then six monthly thereafter (and after large storm events).

MAINTENANCE SCHEDULE	REQUIRED ACTION	RECOMMENDED FREQUENCY
	Visual inspection of basin, De-silt as required. A maintenance track will be installed right around the pond. Excavator to be used to remove sediment with care not to damage the base of the pond. Access via maintenance strip and 1 in 4 side slopes.	Monthly for first three months, then six monthly thereafter (and after large storm events).
	Remove sediment from interceptor, chambers, road gullies and jet associated pipework.	Annually, or as required.

4.0 HYDRO BRAKE CHAMBER

MAINTENANCE SCHEDULE	REQUIRED ACTION	RECOMMENDED FREQUENCY
Ongoing Monitoring/Maintenance – Hydro Brake Chamber United Utilities	The hydro brake control is to be applied by Hydro International and their recommendations for maintenance are appended to this report. Ongoing monitoring to inspect chamber for blockages.	Inspect monthly for 3 months and thereafter at 6 monthly intervals.
Ongoing Monitoring General Drainage System United Utilities	Inspect/check all upstream drainage inlets, outlets, vents and gullies to ensure that they are in good condition and operating as designed.	Annually and after large storm events
Remedial Actions United Utilities	Repair/rehabilitation of inlets, outlets, overflows and vents. Removal of oil and grease. Replacement of malfunctioning parts.	As required

Tweddell & Slater Ltd Unit 2 Mereside Greenbank Road
Eden Business Park Penrith Cumbria CA11 9FB
AKP April 2022