
From: Environmental Health
Sent: 28 August 2024 15:26
To: Development Control
Cc: Christie Burns
Subject: PLANNING APP 4/24/2253/0F1 - BOLT HOW, HOLMROOK

Siting of timber chalet for farm worker on existing hardstanding

Thank you for the above consultation.
There are no objections from Environmental Health to this development.

As the timber chalet is proposed to be used in connection to employment, the applicants should note that a Fire Risk Assessment, under provisions of the Regulatory Reform (Fire Safety) Order 2005 should be carried out, and that the Electricity at Work Regulations 1989 may also apply in that any electrical equipment is maintained in a safe condition, and should be inspected and tested accordingly (see HSE Advice 'Maintaining Portable Electrical Equipment').

Regards

Environmental Health
Public Health & Protection | Cumberland Council
Whitehaven Commercial Park, Moresby Parks, Whitehaven, Cumbria, CA28 8YD

T. 0300 373 3730

cumberland.gov.uk

