

From: Environmental Health
Sent: 01 May 2026 15:24
To: Development Control
Cc: Christie Burns
Subject: 4/26/2112/0B1 - LAND ADJ TO 21 SCURGILL TERRACE. EGREMONT

Variation of condition 2 (plans)

Thank you for the above planning consultation.

There are no objections to this proposal from Environmental Health.
With respects to areas of soft landscaping, it may be necessary for a clean soil cover system / no dig barrier to be installed due to historical soil contamination as detailed in the original planning application.
This work should be overseen and validated by a competent geo-environmental practitioner.

Regards

Environmental Health
Public Health & Protection | Cumberland Council
Whitehaven Commercial Park, Moresby Parks, Whitehaven, Cumbria, CA28 8YD

T. 0300 373 3730

cumberland.gov.uk

