

From: Environmental Health
Sent: 07 November 2025 16:21
To: Development Control
Cc: Demi Crawford
Subject: PLANNING APP 4/25/2362/0F1

Construction of a new 465 sqm agricultural building to provide a covered slurry store

Thank you for the above planning consultation.

There are no objections to this proposed development from Environmental Health. The covered manure store should help to reduce manure run-off that can potentially increase pollution levels to water courses and the River Duddon estuary. The CPRE's Dark Skies Map for England shows this location to be less affected by artificial light pollution, and so any external artificial light provision should be sensitive to this. Planners may wish to consider whether a condition on this is required:

- Artificial Lighting (External)

Artificial light to the development must conform to requirements to meet the Obtrusive Light Limitations for Exterior Lighting Installations for Environmental Zone E2 contained within the Institute of Light Engineers Guidance Notes for the Reduction of Obtrusive Lighting GN01:2021. Reason: To safeguard the amenities of nearby residential occupiers and reduce light pollution.

Regards

Environmental Health
Public Health & Protection | Cumberland Council
Whitehaven Commercial Park, Moresby Parks, Whitehaven, Cumbria, CA28 8YD

T. 0300 373 3730

cumberland.gov.uk

