

From: Environmental Health
Sent: 19 May 2026 14:40
To: Development Control
Cc: Christie Burns
Subject: 4/26/2126/0F1 - GRASS VERGE AT HORN HILL, MOOR ROAD, MILLOM

Installation of a 12m monopole which will support 1no. omni antenna at a mean height of 13.83m along with ancillary equipment thereto including GPS module, 1no. collinear antenna and 1no. cabinet together with ground works to facilitate the development including retaining walls, access steps and fencing.

Thank you for the above planning consultation and confirmation from the developer that there should be no detrimental cumulative effects from this proposed development alongside another similar development that was approved in 2024 (planning application ref 4/24/2384/0F1) at this location.

The applicant has included a Declaration of ICNIRP Compliance and advice as regards safety of non-ionizing radiation from the development. The development should not interfere with existing radio and television coverage in the area or with other electrical equipment, though further advice / redress on this matter is provided by Ofcom, the regulator for communications services.

The developer should note that there is a 150 / 250mm surface water highway drain under the grass verge marked on Council mapping, when groundworks are undertaken. Planners may wish to impose a condition regarding construction working hours, notwithstanding any traffic / health and safety concerns, in order to limit any noise disturbance to nearby residents.

Regards

Environmental Health
Public Health & Protection | Cumberland Council
Whitehaven Commercial Park, Moresby Parks, Whitehaven, Cumbria, CA28 8YD

T. 0300 373 3730

cumberland.gov.uk

