

Oliver Hoban

From: David Bechelli
Sent: 27 April 2023 16:43
To: Sarah Papaleo
Cc: Development Control
Subject: FW: 4/23/2088/0F1 - LAND AT HARRAS ROAD, HARRAS PARK, WHITEHAVEN
Attachments: 4-23-2088-01.doc

Hi Sarah,

I forgot to add that with this, the Flood Risk Assessment & Drainage Strategy will need to be updated to reflect the climate change allowance has increase from 40% to 50%.

Regards

Dave

David Bechelli

Flood and Coastal Defence Engineer - Environmental Health & Land Charges
Public Health & Protection | Cumberland Council
Whitehaven Commercial Park, Moresby Parks, Whitehaven, Cumbria, CA28 8YD



cumberland.gov.uk

