



GENERAL NOTES

- SETTING OUT SHALL BE UNDERTAKEN USING ONLY THE INFORMATION GIVEN. DISTANCES SHOULD NOT BE SCALED FROM THIS DRAWING.
- ALL SEWERS SHALL BE CONSTRUCTED IN ACCORDANCE WITH SEWERS FOR ADOPTION 6TH EDITION AND UNITED UTILITIES DETAILS & GUIDELINES.
- THE MINIMUM GRAVITY PIPE DIAMETER UNDER ADOPTABLE HIGHWAYS SHALL BE 150MM
- IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO VERIFY ALL INFORMATION GIVEN WITH REGARDS TO EXISTING SERVICES AND DRAINAGE CONNECTIONS ETC. PRIOR TO COMMENCING THE WORKS. THE RATES SHALL INCLUDE FOR HAND DIG AROUND SERVICES WHERE NECESSARY. THE CONTRACTOR SHALL ADHERE TO THE CDM REGULATIONS AT ALL TIMES
- THE OUTSIDES OF ALL SEWERS SHALL BE A MINIMUM OF 1.0M FROM KERB LINES AND THE OUTSIDE OF MANHOLES SHALL BE A MINIMUM OF 0.5M FROM KERB LINES
- EXISTING FLOWS IN WATERCOURSES, SEWERS AND LAND DRAINS SHALL BE MAINTAINED AT ALL TIMES 7. ONLY TRAINED PERSONNEL SHALL BE PERMITTED TO ENTER CONFINED SPACES
- ALL MATERIALS TO BEAR THE RELEVANT B.S. KITEMARK AND COMPLY FULLY WITH THE SPECIFICATIONS. ALL CONCRETE & CONCRETE PRODUCTS MUST USE SULPHATE RESISTANT CEMENT UNLESS THE SITE INVESTIGATION REPORT PROVES THAT SULPHATE ATTACK FROM SOILS AND GROUNDWATER WILL NOT OCCUR TO WITHSTAND A CLASS
- ALL OPENING NOTICES ETC. AS REQUIRED UNDER HIGHWAYS ACTS ETC. ARE TO BE OBTAINED PRIOR TO COMMENCEMENT OF WORKS. ALL WORKS ARE TO BE INSPECTED BY L.A., NABC OR THE NETWORK OPERATOR AS APPLICABLE.
- WHERE "ULTRA RIB" UPVC PIPES (OR SIMILAR APPROVED) ARE USED IN ADOPTABLE DRAINAGE THEY SHALL STILL BE HANDLED AND LAID IN ACCORDANCE WITH THE SPECIFICATION AND GUIDANCE ISSUED BY THE HIGH PERFORMANCE PIPE ASSOCIATION.
- A CLASS S BED AND SURROUND MUST BE USED FOR SUCH PIPES. TRENCH BACKFILL IN HIGHWAYS TO WITHIN 1M OF HIGHWAY SHALL, AS DIRECTED BY THE HIGHWAY AUTHORITY BE A SUITABLE GRANULAR MATERIAL ALL IN ACCORDANCE WITH SEWERS FOR ADOPTION CL 4.3.4.12. SLAB LEVELS SHALL NOT BE VARIED WITHOUT REFERENCE TO THE ENGINEER FOR GUIDANCE
- DOMESTIC DRAINAGE SHALL BE TO BUILDING REGULATIONS APPROVED DOCUMENT H.110MM U.P.V.C. PIPES LAID TO THE FOLLOWING MINIMUM FALLS UNLESS OTHERWISE SHOWN.  

|                   |          |
|-------------------|----------|
| FOUL              | S.W.     |
| HEAD RUN 1 IN 40  | 1 IN 60  |
| ELSEWHERE 1 IN 80 | 1 IN 100 |
- POLYPROPYLENE INSPECTION CHAMBERS TO BE PROVIDED TO ALL PRIVATE DRAINAGE LESS THAN 1.10m DEEP. WHERE PRIVATE DRAINAGE RUNS ARE DEEPER THAN 1.10m, REDUCED ACCESS CHAMBERS TO BE PROVIDED.
- WHEREVER PLASTIC PIPES ARE TO BE USED FOR THE CONSTRUCTION OF ADOPTABLE DRAINAGE, STRUCTURED WALL PLASTIC PIPES MUST BE USED WHICH MUST COMPLY WITH BS EN 13476-1 AND WIS 4-35-01

LEGEND

- |  |                                                                                      |
|--|--------------------------------------------------------------------------------------|
|  | PROPOSED SURFACE WATER SEWER MANHOLE                                                 |
|  | PROPOSED FOUL WATER SEWER MANHOLE                                                    |
|  | PROPOSED COMBINED WATER SEWER MANHOLE                                                |
|  | EXISTING SURFACE WATER MANHOLE                                                       |
|  | EXISTING COMBINED WATER MANHOLE                                                      |
|  | PROPOSED FOUL 1050MM PCC DRAG OUT MH (TO BE AGREED WITH UU FIELD INSPECTOR)          |
|  | PROPOSED SURFACE WATER 1050MM PCC DRAG OUT MH (TO BE AGREED WITH UU FIELD INSPECTOR) |
|  | PROPOSED FOUL WATER SEWER                                                            |
|  | PROPOSED SURFACE WATER SEWER                                                         |
|  | PROPOSED COMBINED SEWER                                                              |
|  | PROPOSED SURFACE WATER DRAIN WITH 450mm INSPECTION CHAMBER                           |
|  | PROPOSED FOUL WATER DRAIN WITH 450mm INSPECTION CHAMBER                              |
|  | HIGHWAY GULLY                                                                        |
|  | FINISHED FLOOR LEVEL                                                                 |
|  | ACO CHANNEL (OR SIMILAR)                                                             |

S.W DRAINAGE STRATEGY PRELIMINARY  
SUBJECT TO ACCEPTANCE BY UNITED  
UTILITIES OF DISCHARGE RATES & OUTFALL  
LOCATION - SYSTEM BASED ON 51/S FOR  
1 IN 100 YR RETURN PERIOD + 40% CLIMATE CHANGE

|                                                                      |             |                                     |            |               |          |
|----------------------------------------------------------------------|-------------|-------------------------------------|------------|---------------|----------|
| P03                                                                  | 24.02.2021  | AMENDED TO LATEST LAYOUT            | JCM        | JLS           | JLS      |
| P02                                                                  | 02.03.20    | AMENDED TO LATEST LAYOUT            | JCM        | JLS           | JLS      |
| P01                                                                  | 09.12.19    | INITIAL ISSUE                       | JCM        | JLS           | JLS      |
| REV                                                                  | DATE        | DESCRIPTION                         | BY         | CHK           | APP      |
| DRAWING STATUS:                                                      |             |                                     |            |               |          |
| PRELIMINARY                                                          |             |                                     |            |               |          |
| CLIENT:                                                              |             |                                     |            |               |          |
| BIG LOCAL                                                            |             |                                     |            |               |          |
| ARCHITECT:                                                           |             |                                     |            |               |          |
| HLP ARCHITECTS                                                       |             |                                     |            |               |          |
| PROJECT:                                                             |             |                                     |            |               |          |
| DISTINGTON<br>BIG LOCAL                                              |             |                                     |            |               |          |
| TITLE:                                                               |             |                                     |            |               |          |
| OUTLINE DRAINAGE<br>PLAN                                             |             |                                     |            |               |          |
| STATUS:                                                              | PROJECT No: | PROJECT                             | ORIGINATOR | VOL/ISS/LEVEL | TYPE     |
| S2                                                                   | 218-252     | DIS - AJP - ZZ - 00 - DR - C - 1000 | P03        |               |          |
| SCALE @ A1:                                                          | DESIGNED:   | DRAWN:                              | CHECKED:   | APPROVED:     | DATE     |
| 1:250                                                                | JCM         | JCM                                 | JLS        | JLS           | DEC 2019 |
| alan johnston partnership LLP                                        |             |                                     |            |               |          |
| CONSULTING STRUCTURAL & CIVIL ENGINEERS                              |             |                                     |            |               |          |
| 1 Dale Street, Liverpool L2 2ET                                      |             |                                     |            |               |          |
| Tel: 0151 227 1462 Fax: 0151 225 1187 E-Mail: Mail@ajpsstructurg.com |             |                                     |            |               |          |