

APPENDIX C -  
PERCOLATION TEST RESULTS



Environmental Engineering

GEO2021-4903: Land Adjacent to Thornlea, Carleton, Egremont, Cumbria – Exploratory Hole Location Plan



Website: [www.geoenvironmentalengineering.com](http://www.geoenvironmentalengineering.com)  
Email: [info@geoenvironmentalengineering.com](mailto:info@geoenvironmentalengineering.com)

Telephone: 08456 768 895 / 07883 440 186

**GEO2021-4903: Land Adjacent to Thornlea, Carleton, Egremont, Cumbria – TP01**

| Depth From (m)                                                                                        | Depth To (m) | Strata Description                                                                                                                                                                                                                                  | Legend                                                                                                                                                      | Testing / Samples |
|-------------------------------------------------------------------------------------------------------|--------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------|
| 0.00                                                                                                  | 0.18         | TOPSOIL: Dark grey brown sandy gravelly LOAM with occasional clinker.                                                                                                                                                                               |                                                                           | 0.10 - J          |
| 0.18                                                                                                  | 0.87         | Brown slightly silty very sandy fine to coarse sub-rounded GRAVEL with many cobbles.                                                                                                                                                                |                                                                           |                   |
| 0.87                                                                                                  | 1.50         | Brown slightly silty gravelly medium SAND.                                                                                                                                                                                                          |                                                                           |                   |
| 1.50                                                                                                  | 2.00         | Brown slightly silty very sandy fine to coarse sub-rounded GRAVEL and COBBLES of mixed lithology. Occasional boulders.                                                                                                                              |                                                                           |                   |
|                                                                                                       |              | End of trial hole at 2.00m due to complete collapse.<br>Groundwater Ingress at 1.50m bgl.<br>Standing groundwater at 1.50m bgl on completion.<br>Complete collapse of trial pit at 2.00m bgl.<br>Trial hole backfilled with arisings on completion. |                                                                                                                                                             |                   |
| <b>Engineer:</b> J.Brock<br><b>Site Works Date:</b> 17/08/2021<br><b>Plant:</b> Tracked 360 Excavator |              |                                                                                                                                                                                                                                                     | <b>Log Notes:</b><br>HSV = Hand Shear Vane (kN/m <sup>2</sup> )<br>LP = Limited Penetration (HSV/CBR)<br>B = Bulk Bag, J = Amber Glass Jar, T = Plastic Tub |                   |



**GEO2021-4903: Land Adjacent to Thornlea, Carleton, Egremont, Cumbria – TP02**

| Depth From (m) | Depth To (m) | Strata Description                                                                                                                                                                                            | Legend                                                                             | Testing / Samples |
|----------------|--------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------|-------------------|
| 0.00           | 0.24         | MADE GROUND: Dark brown silty sandy fine to coarse angular to sub-rounded GRAVEL of mixed aggregate with occasional brick, clinker and asphalt.                                                               |  | 0.10 - J          |
| 0.24           | 0.90         | Brown slightly silty very sandy fine to coarse sub-rounded GRAVEL with many cobbles.                                                                                                                          |  |                   |
| 0.90           | 1.20         | Brown slightly silty gravelly medium SAND.                                                                                                                                                                    |  |                   |
| 1.20           | 1.50         | Brown slightly silty very sandy fine to coarse sub-rounded GRAVEL and COBBLES of mixed lithology. Occasional boulders.                                                                                        |  |                   |
|                |              | End of trial hole at 1.50m – Soil Infiltration Test Completed.<br>Groundwater ingress at 1.50m bgl.<br>Standing groundwater at 1.50m bgl on completion.<br>Trial hole backfilled with arisings on completion. |                                                                                    |                   |

**Engineer:** J.Brock

**Site Works Date:** 17/08/2021

**Plant:** Tracked 360 Excavator

**Dimensions:** 2.10m x 0.90m

**Log Notes:**

HSV = Hand Shear Vane (kN/m<sup>2</sup>)

LP = Limited Penetration (HSV/CBR)

B = Bulk Bag, J = Amber Glass Jar, T = Plastic Tub



**Website:** [www.geoenvironmentalengineering.com](http://www.geoenvironmentalengineering.com)

**Email:** [info@geoenvironmentalengineering.com](mailto:info@geoenvironmentalengineering.com)

**Telephone:** 08456 768 895 / 07883 440 186

**GEO2021-4903: Land Adjacent to Thornlea, Carleton, Egremont, Cumbria – TP03**

| Depth From (m)                                                                                        | Depth To (m) | Strata Description                                                                                                                                                                                                    | Legend                                                                                                                                                      | Testing / Samples |
|-------------------------------------------------------------------------------------------------------|--------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------|
| 0.00                                                                                                  | 0.38         | MADE GROUND: Grey brown silty very sandy fine to coarse sub-rounded GRAVEL of mixed lithology with occasionally concrete/slag.                                                                                        |                                                                           | 0.20 - J          |
| 0.38                                                                                                  | 2.00         | Brown slightly silty very sandy fine to coarse sub-rounded GRAVEL and COBBLES of mixed lithology. Occasional boulders.                                                                                                |                                                                           | 1.00 - J          |
|                                                                                                       |              | End of trial hole at 2.00m.<br>Groundwater ingress at 1.40m bgl.<br>Standing groundwater at 1.40m bgl on completion.<br>Trial pit collapsing during excavation.<br>Trial hole backfilled with arisings on completion. |                                                                                                                                                             |                   |
| <b>Engineer:</b> J.Brock<br><b>Site Works Date:</b> 17/08/2021<br><b>Plant:</b> Tracked 360 Excavator |              |                                                                                                                                                                                                                       | <b>Log Notes:</b><br>HSV = Hand Shear Vane (kN/m <sup>2</sup> )<br>LP = Limited Penetration (HSV/CBR)<br>B = Bulk Bag, J = Amber Glass Jar, T = Plastic Tub |                   |



**GEO2021-4903: Land Adjacent to Thornlea, Carleton, Egremont, Cumbria – TP04**

| Depth From (m)                                                                                        | Depth To (m) | Strata Description                                                                                                                                                | Legend                                                                                                                                                      | Testing / Samples |
|-------------------------------------------------------------------------------------------------------|--------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------|
| 0.00                                                                                                  | 0.22         | MADE GROUND: Brown silty sandy gravelly LOAM with occasional clinker.                                                                                             |                                                                                                                                                             | 0.10 - J          |
| 0.22                                                                                                  | 0.41         | MADE GROUND: Blue grey fused SLAG. Strong sulphurous odour. Difficult to excavate.                                                                                |                                                                                                                                                             |                   |
| 0.41                                                                                                  | 1.80         | Brown slightly silty, very sandy fine to coarse sub-rounded GRAVEL and COBBLES of mixed lithology. Occasional boulders. Occasional pockets of very gravelly sand. |                                                                                                                                                             | 1.00 - J          |
|                                                                                                       |              | End of trial hole at 1.80m.<br>Trial Pit dry and stable on completion.<br>Trial hole backfilled with arisings on completion.                                      |                                                                                                                                                             |                   |
| <b>Engineer:</b> J.Brock<br><b>Site Works Date:</b> 17/08/2021<br><b>Plant:</b> Tracked 360 Excavator |              |                                                                                                                                                                   | <b>Log Notes:</b><br>HSV = Hand Shear Vane (kN/m <sup>2</sup> )<br>LP = Limited Penetration (HSV/CBR)<br>B = Bulk Bag, J = Amber Glass Jar, T = Plastic Tub |                   |



**GEO2021-4903: Land Adjacent to Thornlea, Carleton, Egremont, Cumbria – TP05**

| Depth From (m) | Depth To (m) | Strata Description                                                                                                                   | Legend                                                                             | Testing / Samples |
|----------------|--------------|--------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------|-------------------|
| 0.00           | 0.50         | MADE GROUND: Grey brown sandy fine to coarse angular GRAVEL of mixed aggregate, slag and concrete. Plastic pipe at surface.          |  | 0.10 - J          |
| 0.50           | 1.10         | Grey brown very silty gravelly SAND.                                                                                                 |  |                   |
| 1.10           | 1.70         | Brown slightly silty, very sandy fine to coarse sub-rounded GRAVEL and COBBLES of mixed lithology. Ceramic field drain at 1.10m bgl. |  |                   |
|                |              | End of trial hole at 1.70m.<br>Trial Pit dry and stable on completion.<br>Trial hole backfilled with arisings on completion.         |                                                                                    |                   |

**Engineer:** J.Brock

**Site Works Date:** 17/08/2021

**Plant:** Tracked 360 Excavator

**Log Notes:**

HSV = Hand Shear Vane (kN/m<sup>2</sup>)

LP = Limited Penetration (HSV/CBR)

B = Bulk Bag, J = Amber Glass Jar, T = Plastic Tub



**Website:** [www.geoenvironmentalengineering.com](http://www.geoenvironmentalengineering.com)

**Email:** [info@geoenvironmentalengineering.com](mailto:info@geoenvironmentalengineering.com)

**Telephone:** 08456 768 895 / 07883 440 186

**GEO2021-4903: Land Adjacent to Thornlea, Carleton, Egremont, Cumbria – TP06**

| Depth From (m)                                                                                                                             | Depth To (m) | Strata Description                                                                                                                                        | Legend                                                                                                                                                      | Testing / Samples |
|--------------------------------------------------------------------------------------------------------------------------------------------|--------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------|
| 0.00                                                                                                                                       | 0.40         | MADE GROUND: Grey brown sandy fine to coarse angular GRAVEL of mixed aggregate, slag and concrete.                                                        |                                                                           | 0.10 - J          |
| 0.40                                                                                                                                       | 1.80         | Brown slightly silty, very sandy fine to coarse sub-rounded GRAVEL and COBBLES of mixed lithology. Occasional boulders.                                   |                                                                           |                   |
|                                                                                                                                            |              | End of trial hole at 1.80m – Soil Infiltration Test Completed.<br>Groundwater ingress at 1.45m bgl.<br>Trial hole backfilled with arisings on completion. |                                                                                                                                                             |                   |
| <b>Engineer:</b> J. Brock<br><b>Site Works Date:</b> 17/08/2021<br><b>Plant:</b> Tracked 360 Excavator<br><b>Dimensions:</b> 2.00m x 1.00m |              |                                                                                                                                                           | <b>Log Notes:</b><br>HSV = Hand Shear Vane (kN/m <sup>2</sup> )<br>LP = Limited Penetration (HSV/CBR)<br>B = Bulk Bag, J = Amber Glass Jar, T = Plastic Tub |                   |



**GEO2021-4903: Land Adjacent to Thornlea, Carleton, Egremont, Cumbria – TP07**

| Depth From (m)                                                                                        | Depth To (m) | Strata Description                                                                                                           | Legend                                                                                                                                                      | Testing / Samples |
|-------------------------------------------------------------------------------------------------------|--------------|------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------|
| 0.00                                                                                                  | 0.20         | MADE GROUND: Grey brown loamy soil with occasional ash (former bonfire).                                                     |                                                                           | 0.10 - J          |
| 0.20                                                                                                  | 1.30         | Brown slightly silty, very sandy fine to coarse sub-rounded GRAVEL and COBBLES of mixed lithology. Occasional boulders.      |                                                                           |                   |
| 1.30                                                                                                  | 2.10         | Brown silty gravelly medium SAND                                                                                             |                                                                           |                   |
|                                                                                                       |              | End of trial hole at 2.10m.<br>Trial Pit dry and stable on completion.<br>Trial hole backfilled with arisings on completion. |                                                                                                                                                             |                   |
| <b>Engineer:</b> J.Brock<br><b>Site Works Date:</b> 17/08/2021<br><b>Plant:</b> Tracked 360 Excavator |              |                                                                                                                              | <b>Log Notes:</b><br>HSV = Hand Shear Vane (kN/m <sup>2</sup> )<br>LP = Limited Penetration (HSV/CBR)<br>B = Bulk Bag, J = Amber Glass Jar, T = Plastic Tub |                   |



**GEO2021-4903: Carleton, Egremont, Cumbria – Soil Infiltration Test Results**

**TP02 – Test 1**

| Duration (mins) | Water Level (m bgl) |
|-----------------|---------------------|
| 0               | 0.66                |
| 11              | 0.66                |
| 36              | 0.65                |
| 72              | 0.65                |
| 128             | 0.64                |
| 199             | 0.63                |

**TP06 – Test 1**

| Duration (mins) | Water Level (m bgl) |
|-----------------|---------------------|
| 0               | 0.83                |
| 13              | 0.88                |
| 58              | 0.98                |
| 130             | 1.07                |
|                 |                     |
|                 |                     |

**TP06 – Test 2**

| Duration (mins) | Water Level (m bgl) |
|-----------------|---------------------|
| 0               | 0.73                |
| 137             | 0.98                |
|                 |                     |
|                 |                     |
|                 |                     |

**SOIL INFILTRATION TEST CALCULATION SHEET**

SITE: **Thornlea, Carleton, Egremont**  
 JOB NO: **2021-4903**  
 TRIAL PIT: **TP06**  
 TEST NO.: **1**

GROUND CONDITIONS: See Trial Pit Logs for Details

**TEST HOLE SIZE:**

Width **1000** mm  
 Length **2000** mm  
 Depth of hole **1800** mm  
 Change Water Level **240** mm

**MONITORING RESULTS:**

| Recorded Time |         |         | Total Time<br>(secs) | Depth of water<br>(mm) |
|---------------|---------|---------|----------------------|------------------------|
| Hours         | Minutes | Seconds |                      |                        |
| 0             | 0       | 0       | 0                    | 830                    |
| 0             | 13      | 0       | 780                  | 880                    |
| 0             | 58      | 0       | 3480                 | 980                    |
| 0             | 130     | 0       | 7800                 | 1070                   |

**PERCOLATION TEST RESULTS AND SOIL INFILTRATION ASSESSMENT**

TEST NO.: **1**

**SOIL INFILTRATION RATE ASSESSMENT:**

Vol. Outflowing between 75% and 25% effective depth:

$V_{p75-25} = 0.24 \text{ m}^3$

Mean surface area (pit sides to 50% effective depth + base of pit):

$A_{p50} = 2.72 \text{ m}^2$

Time for the outflow between 75% and 25% effective depth:

$t_{p75-25} = 3900 \text{ secs}$

Soil Infiltration rate:

$f = 2.3E-05 \text{ m/s}$

**SOIL INFILTRATION TEST CALCULATION SHEET**

**SITE:** Thornlea, Carleton, Egremont  
**JOB NO:** 2021-4903  
**TRIAL PIT:** TP06  
**TEST NO.:** 2

**GROUND CONDITIONS:** See Trial Pit Logs for Details

**TEST HOLE SIZE:**

Width 1000 mm  
 Length 2000 mm  
 Depth of hole 1800 mm  
 Change Water Level 250 mm

**MONITORING RESULTS:**

| Recorded Time |         |         | Total Time<br>(secs) | Depth of water<br>(mm) |
|---------------|---------|---------|----------------------|------------------------|
| Hours         | Minutes | Seconds |                      |                        |
| 0             | 0       | 0       | 0                    | 730                    |
| 0             | 137     | 0       | 8220                 | 980                    |

**PERCOLATION TEST RESULTS AND SOIL INFILTRATION ASSESSMENT**

**TEST NO.:** 2

**SOIL INFILTRATION RATE ASSESSMENT:**

**Vol. Outflowing between 75% and 25% effective depth:**

$V_{p75-25} = 0.25 \text{ m}^3$

**Mean surface area (pit sides to 50% effective depth + base of pit):**

$A_{p50} = 2.75 \text{ m}^2$


**Time for the outflow between 75% and 25% effective depth:**

$t_{p75-25} = 4110 \text{ secs}$

**Soil Infiltration rate:**

$f = 2.2E-05 \text{ m/s}$

APPENDIX D -  
EA FLOOD MAP FOR PLANNING AND LONG-TERM FLOOD RISK



## Flood map for planning

Your reference

**Carleton**

Location (easting/northing)


**301702/509230**

Scale

**1:2500**

Created

**23 Feb 2022 16:17**



Selected point



Flood zone 3



Flood zone 3: areas benefiting from flood defences



Flood zone 2



Flood zone 1



Flood defence



Main river



Flood storage area



Page 2 of 2



Extent of flooding from rivers or the sea

● High ● Medium ● Low ● Very low ⊕ Location you selected



Extent of flooding from surface water

- High
- Medium
- Low
- Very low
- Location you selected

APPENDIX E -  
ATTENUATION TANK SIZE CALCULATION

**Design Settings**

|                       |                   |                                      |               |
|-----------------------|-------------------|--------------------------------------|---------------|
| Rainfall Methodology  | FSR               | Maximum Time of Concentration (mins) | 30.00         |
| Return Period (years) | 100               | Maximum Rainfall (mm/hr)             | 50.0          |
| Additional Flow (%)   | 40                | Minimum Velocity (m/s)               | 1.00          |
| FSR Region            | England and Wales | Connection Type                      | Level Soffits |
| M5-60 (mm)            | 20.000            | Minimum Backdrop Height (m)          | 0.200         |
| Ratio-R               | 0.300             | Preferred Cover Depth (m)            | 1.200         |
| CV                    | 1.000             | Include Intermediate Ground          | ✓             |
| Time of Entry (mins)  | 2.00              | Enforce best practice design rules   | x             |

**Nodes**

| Name        | Area<br>(ha) | T of E<br>(mins) | Cover<br>Level<br>(m) | Diameter<br>(mm) | Depth<br>(m) |
|-------------|--------------|------------------|-----------------------|------------------|--------------|
| S1          | 0.006        | 2.00             | 101.850               | 1200             | 0.700        |
| S2          | 0.005        | 2.00             | 101.850               | 1200             | 0.742        |
| S3          | 0.005        | 2.00             | 101.850               | 1200             | 0.830        |
| S4          | 0.005        | 2.00             | 101.850               | 1200             | 0.859        |
| S5          | 0.005        | 2.00             | 101.850               | 1200             | 1.088        |
| S6          | 0.005        | 2.00             | 101.850               | 1200             | 2.095        |
| S7          | 0.005        | 2.00             | 101.850               | 1200             | 2.140        |
| S8          | 0.005        | 2.00             | 101.850               | 1200             | 2.573        |
| Tank Inlet  |              |                  | 101.500               |                  | 2.373        |
| Tank Outlet |              |                  | 100.800               |                  | 1.733        |
| S9          |              |                  | 100.750               | 1200             | 1.698        |
| COM1        |              |                  | 100.600               | 1200             | 1.600        |

**Links**

| Name  | US<br>Node  | DS<br>Node  | Length<br>(m) | ks (mm) /<br>n | US IL<br>(m) | DS IL<br>(m) | Fall<br>(m) | Slope<br>(1:X) | Dia<br>(mm) | T of C<br>(mins) | Rain<br>(mm/hr) |
|-------|-------------|-------------|---------------|----------------|--------------|--------------|-------------|----------------|-------------|------------------|-----------------|
| 1.000 | S1          | S2          | 4.250         | 0.600          | 101.150      | 101.108      | 0.042       | 100.0          | 150         | 2.07             | 50.0            |
| 1.001 | S2          | S3          | 8.760         | 0.600          | 101.108      | 101.020      | 0.088       | 100.0          | 150         | 2.22             | 50.0            |
| 1.002 | S3          | S4          | 2.903         | 0.600          | 101.020      | 100.991      | 0.029       | 100.0          | 150         | 2.26             | 50.0            |
| 1.003 | S4          | S5          | 22.859        | 0.600          | 100.991      | 100.762      | 0.229       | 100.0          | 150         | 2.64             | 50.0            |
| 1.004 | S5          | S6          | 10.250        | 0.600          | 100.762      | 99.755       | 1.007       | 10.2           | 150         | 2.70             | 50.0            |
| 1.005 | S6          | S8          | 4.775         | 0.600          | 99.755       | 99.277       | 0.478       | 10.0           | 150         | 2.72             | 50.0            |
| 2.000 | S7          | S8          | 4.325         | 0.600          | 99.710       | 99.277       | 0.433       | 10.0           | 150         | 2.02             | 50.0            |
| 1.006 | S8          | Tank Inlet  | 1.500         | 0.600          | 99.277       | 99.127       | 0.150       | 10.0           | 150         | 2.73             | 50.0            |
| 1.007 | Tank Inlet  | Tank Outlet | 12.000        | 0.600          | 99.127       | 99.067       | 0.060       | 200.0          | 400         | 2.83             | 50.0            |
| 1.008 | Tank Outlet | S9          | 1.500         | 0.600          | 99.067       | 99.052       | 0.015       | 100.0          | 150         | 2.86             | 50.0            |

| Name  | Vel<br>(m/s) | Cap<br>(l/s) | Flow<br>(l/s) | US<br>Depth<br>(m) | DS<br>Depth<br>(m) | Σ Area<br>(ha) | Σ Add<br>Inflow<br>(l/s) | Pro<br>Depth<br>(mm) | Pro<br>Velocity<br>(m/s) |
|-------|--------------|--------------|---------------|--------------------|--------------------|----------------|--------------------------|----------------------|--------------------------|
| 1.000 | 1.005        | 17.8         | 1.5           | 0.550              | 0.592              | 0.006          | 0.0                      | 30                   | 0.613                    |
| 1.001 | 1.005        | 17.8         | 2.8           | 0.592              | 0.680              | 0.011          | 0.0                      | 40                   | 0.734                    |
| 1.002 | 1.005        | 17.8         | 4.0           | 0.680              | 0.709              | 0.016          | 0.0                      | 49                   | 0.818                    |
| 1.003 | 1.005        | 17.8         | 5.3           | 0.709              | 0.938              | 0.021          | 0.0                      | 56                   | 0.877                    |
| 1.004 | 3.176        | 56.1         | 6.6           | 0.938              | 1.945              | 0.026          | 0.0                      | 34                   | 2.126                    |
| 1.005 | 3.206        | 56.7         | 7.8           | 1.945              | 2.423              | 0.031          | 0.0                      | 38                   | 2.270                    |
| 2.000 | 3.206        | 56.7         | 1.3           | 1.990              | 2.423              | 0.005          | 0.0                      | 16                   | 1.314                    |
| 1.006 | 3.204        | 56.6         | 10.4          | 2.423              | 2.223              | 0.041          | 0.0                      | 44                   | 2.458                    |
| 1.007 | 1.975        | 4739.6       | 10.4          | 1.973              | 1.333              | 0.041          | 0.0                      | 7                    | 0.232                    |
| 1.008 | 1.005        | 17.8         | 10.4          | 1.583              | 1.548              | 0.041          | 0.0                      | 82                   | 1.042                    |

Links

| Name  | US<br>Node | DS<br>Node | Length<br>(m) | ks (mm) /<br>n | US IL<br>(m) | DS IL<br>(m) | Fall<br>(m) | Slope<br>(1:X) | Dia<br>(mm) | T of C<br>(mins) | Rain<br>(mm/hr) |
|-------|------------|------------|---------------|----------------|--------------|--------------|-------------|----------------|-------------|------------------|-----------------|
| 1.009 | S9         | COM1       | 5.156         | 0.600          | 99.052       | 99.000       | 0.052       | 100.0          | 150         | 2.94             | 50.0            |

| Name  | Vel<br>(m/s) | Cap<br>(l/s) | Flow<br>(l/s) | US<br>Depth<br>(m) | DS<br>Depth<br>(m) | Σ Area<br>(ha) | Σ Add<br>Inflow<br>(l/s) | Pro<br>Depth<br>(mm) | Pro<br>Velocity<br>(m/s) |
|-------|--------------|--------------|---------------|--------------------|--------------------|----------------|--------------------------|----------------------|--------------------------|
| 1.009 | 1.005        | 17.8         | 10.4          | 1.548              | 1.450              | 0.041          | 0.0                      | 82                   | 1.042                    |

Simulation Settings

|                      |                   |                               |      |
|----------------------|-------------------|-------------------------------|------|
| Rainfall Methodology | FSR               | Drain Down Time (mins)        | 240  |
| FSR Region           | England and Wales | Additional Storage (m³/ha)    | 20.0 |
| M5-60 (mm)           | 20.000            | Check Discharge Rate(s)       | ✓    |
| Ratio-R              | 0.300             | 1 year (l/s)                  | 0.4  |
| Summer CV            | 1.000             | 30 year (l/s)                 | 0.9  |
| Winter CV            | 1.000             | 100 year (l/s)                | 1.0  |
| Analysis Speed       | Detailed          | Check Discharge Volume        | ✓    |
| Skip Steady State    | x                 | 100 year +40% 360 minute (m³) | 52   |

Storm Durations

15 | 30 | 60 | 120 | 180 | 240 | 360

| Return Period<br>(years) | Climate Change<br>(CC %) | Additional Area<br>(A %) | Additional Flow<br>(Q %) |
|--------------------------|--------------------------|--------------------------|--------------------------|
| 1                        | 40                       | 10                       | 0                        |
| 30                       | 40                       | 10                       | 0                        |
| 100                      | 40                       | 10                       | 0                        |

Pre-development Discharge Rate

|                              |            |                        |      |
|------------------------------|------------|------------------------|------|
| Site Makeup                  | Greenfield | Growth Factor 30 year  | 1.95 |
| Greenfield Method            | IH124      | Growth Factor 100 year | 2.48 |
| Positively Drained Area (ha) | 0.097      | Betterment (%)         | 0    |
| SAAR (mm)                    | 1154       | QBar                   | 0.8  |
| Soil Index                   | 4          | Q 1 year (l/s)         |      |
| SPR                          | 0.47       | Q 30 year (l/s)        |      |
| Region                       | 10         | Q 100 year (l/s)       |      |
| Growth Factor 1 year         | 0.85       |                        |      |

Pre-development Discharge Volume

|                              |            |                       |       |
|------------------------------|------------|-----------------------|-------|
| Site Makeup                  | Greenfield | Return Period (years) | 100   |
| Greenfield Method            | FSR/FEH    | Climate Change (%)    | 40    |
| Positively Drained Area (ha) | 0.097      | Storm Duration (mins) | 360   |
| Soil Index                   | 4          | Betterment (%)        | 0     |
| SPR                          | 0.47       | PR                    | 0.548 |
| CWI                          | 125.385    | Runoff Volume (m³)    | 52    |

**Node S9 Online Hydro-Brake® Control**

|                          |        |                         |                                |
|--------------------------|--------|-------------------------|--------------------------------|
| Flap Valve               | x      | Objective               | (HE) Minimise upstream storage |
| Replaces Downstream Link | ✓      | Sump Available          | ✓                              |
| Invert Level (m)         | 99.052 | Product Number          | CTL-SHE-0050-8000-0400-8000    |
| Design Depth (m)         | 0.400  | Min Outlet Diameter (m) | 0.075                          |
| Design Flow (l/s)        | 0.8    | Min Node Diameter (mm)  | 1200                           |

**Approval Settings**

|             |   |                       |     |                               |     |
|-------------|---|-----------------------|-----|-------------------------------|-----|
| Node Size   | x | Backdrops             | x   | Return Period (years)         | 100 |
| Node Losses | x | Full Bore Velocity    | x   | Discharge Rates               | ✓   |
| Link Size   | x | Proportional Velocity | x   | 1 year (l/s)                  | 0.8 |
| Link Length | x | Surcharged Depth      | x   | 30 year (l/s)                 | 0.8 |
| Coordinates | x | Flooding              | ✓   | 100 year (l/s)                | 0.8 |
| Crossings   | x | Return Period (years) | 100 | Discharge Volume              | ✓   |
| Cover Depth | x | Time to Half Empty    | ✓   | 100 year +40% 360 minute (m³) | 52  |

**Approval Results**

The network has been designed for a 1 in 100 year storm using FSR rainfall  
It contains 12 nodes (1 outfall) and 11 links  
The total impermeable area is 0.041 ha  
1 online control has been defined  
No additional storage is present  
Simulations have been completed using FSR summer and winter storms from 15 to 1440 minute duration

The node size test has not been completed

The node losses test has not been completed

The link size test has not been completed

The link length test has not been completed

The coordinates test has not been completed

The crossings test has not been completed

The cover depth test has not been completed

The backdrops test has not been completed

The full bore velocity test has not been completed

The proportional velocity test has not been completed

The surcharged depth test has not been completed

No nodes flood during the 100 year return period

No infiltrating structures failed to half empty in 1440 minutes during the 100 year return period

No outfalls have a discharge rate greater than 0.8l/s during the 1 year return period

No outfalls have a discharge rate greater than 0.8l/s during the 30 year return period

|                                                                                                                |                       |                                                                                           |        |
|----------------------------------------------------------------------------------------------------------------|-----------------------|-------------------------------------------------------------------------------------------|--------|
| <b>TWEDDELL<br/>&amp; SLATER</b><br><small>STORMWATER<br/>DESIGN &amp; INFRASTRUCTURAL<br/>ENGINEERING</small> | Tweddell & Slater Ltd | File: Outline DS - 23.02.22.pfd<br>Network: Storm Network<br>Simon Johnston<br>23/02/2022 | Page 4 |
|----------------------------------------------------------------------------------------------------------------|-----------------------|-------------------------------------------------------------------------------------------|--------|

No outfalls have a discharge rate greater than 0.8l/s during the 100 year return period

No outfalls have a discharge volume greater than 52m<sup>3</sup> during the 100 year 360 minute storm

**Results for 1 year +40% CC +10% A Critical Storm Duration. Lowest mass balance: 98.95%**

| Node Event        | US Node     | Peak (mins) | Level (m) | Depth (m) | Inflow (l/s) | Node Vol (m³) | Flood (m³) | Status |
|-------------------|-------------|-------------|-----------|-----------|--------------|---------------|------------|--------|
| 15 minute summer  | S1          | 9           | 101.187   | 0.037     | 2.1          | 0.0493        | 0.0000     | OK     |
| 15 minute summer  | S2          | 9           | 101.157   | 0.049     | 3.9          | 0.0622        | 0.0000     | OK     |
| 15 minute summer  | S3          | 9           | 101.090   | 0.070     | 5.7          | 0.0883        | 0.0000     | OK     |
| 15 minute summer  | S4          | 9           | 101.064   | 0.073     | 7.4          | 0.0915        | 0.0000     | OK     |
| 15 minute summer  | S5          | 9           | 100.803   | 0.041     | 9.0          | 0.0506        | 0.0000     | OK     |
| 15 minute summer  | S6          | 9           | 99.800    | 0.045     | 10.6         | 0.0530        | 0.0000     | OK     |
| 15 minute summer  | S7          | 9           | 99.728    | 0.018     | 1.8          | 0.0218        | 0.0000     | OK     |
| 15 minute summer  | S8          | 9           | 99.339    | 0.062     | 14.1         | 0.0733        | 0.0000     | OK     |
| 180 minute summer | Tank Inlet  | 164         | 99.197    | 0.070     | 4.2          | 0.0000        | 0.0000     | OK     |
| 180 minute summer | Tank Outlet | 144         | 99.196    | 0.129     | 4.0          | 0.0000        | 0.0000     | OK     |
| 180 minute summer | S9          | 144         | 99.197    | 0.145     | 2.4          | 0.1635        | 0.0000     | OK     |
| 15 minute summer  | COM1        | 1           | 99.000    | 0.000     | 0.8          | 0.0000        | 0.0000     | OK     |

| Link Event (Outflow) | US Node     | Link         | DS Node     | Outflow (l/s) | Velocity (m/s) | Flow/Cap | Link Vol (m³) | Discharge Vol (m³) |
|----------------------|-------------|--------------|-------------|---------------|----------------|----------|---------------|--------------------|
| 15 minute summer     | S1          | 1.000        | S2          | 2.1           | 0.504          | 0.118    | 0.0177        |                    |
| 15 minute summer     | S2          | 1.001        | S3          | 3.9           | 0.607          | 0.221    | 0.0568        |                    |
| 15 minute summer     | S3          | 1.002        | S4          | 5.6           | 0.681          | 0.316    | 0.0239        |                    |
| 15 minute summer     | S4          | 1.003        | S5          | 7.2           | 1.173          | 0.404    | 0.1413        |                    |
| 15 minute summer     | S5          | 1.004        | S6          | 8.8           | 2.117          | 0.157    | 0.0426        |                    |
| 15 minute summer     | S6          | 1.005        | S8          | 10.5          | 1.850          | 0.185    | 0.0271        |                    |
| 15 minute summer     | S7          | 2.000        | S8          | 1.8           | 0.527          | 0.032    | 0.0177        |                    |
| 15 minute summer     | S8          | 1.006        | Tank Inlet  | 13.9          | 4.392          | 0.246    | 0.0055        |                    |
| 15 minute summer     | Tank Inlet  | 1.007        | Tank Outlet | 13.3          | 0.105          | 0.003    | 3.6110        |                    |
| 30 minute summer     | Tank Outlet | 1.008        | S9          | 3.0           | 0.365          | 0.170    | 0.0197        |                    |
| 30 minute summer     | S9          | Hydro-Brake® | COM1        | 0.8           |                |          |               | 6.0                |

**Results for 30 year +40% CC +10% A Critical Storm Duration. Lowest mass balance: 98.95%**

| Node Event        | US<br>Node  | Peak<br>(mins) | Level<br>(m) | Depth<br>(m) | Inflow<br>(l/s) | Node<br>Vol (m³) | Flood<br>(m³) | Status     |
|-------------------|-------------|----------------|--------------|--------------|-----------------|------------------|---------------|------------|
| 15 minute summer  | S1          | 9              | 101.214      | 0.064        | 5.1             | 0.0841           | 0.0000        | OK         |
| 15 minute summer  | S2          | 9              | 101.190      | 0.082        | 9.4             | 0.1051           | 0.0000        | OK         |
| 15 minute summer  | S3          | 9              | 101.156      | 0.136        | 13.7            | 0.1716           | 0.0000        | OK         |
| 15 minute summer  | S4          | 9              | 101.124      | 0.133        | 17.7            | 0.1679           | 0.0000        | OK         |
| 15 minute summer  | S5          | 9              | 100.828      | 0.066        | 21.4            | 0.0816           | 0.0000        | OK         |
| 15 minute summer  | S6          | 9              | 99.833       | 0.078        | 25.6            | 0.0919           | 0.0000        | OK         |
| 15 minute summer  | S7          | 9              | 99.738       | 0.028        | 4.3             | 0.0331           | 0.0000        | OK         |
| 360 minute summer | S8          | 360            | 99.381       | 0.104        | 7.1             | 0.1217           | 0.0000        | OK         |
| 360 minute summer | Tank Inlet  | 360            | 99.379       | 0.252        | 7.3             | 0.0000           | 0.0000        | OK         |
| 360 minute summer | Tank Outlet | 360            | 99.379       | 0.312        | 8.1             | 0.0000           | 0.0000        | SURCHARGED |
| 360 minute summer | S9          | 352            | 99.379       | 0.327        | 2.0             | 0.3698           | 0.0000        | SURCHARGED |
| 15 minute summer  | COM1        | 1              | 99.000       | 0.000        | 0.8             | 0.0000           | 0.0000        | OK         |

| Link Event<br>(Outflow) | US<br>Node  | Link         | DS<br>Node  | Outflow<br>(l/s) | Velocity<br>(m/s) | Flow/Cap | Link<br>Vol (m³) | Discharge<br>Vol (m³) |
|-------------------------|-------------|--------------|-------------|------------------|-------------------|----------|------------------|-----------------------|
| 15 minute summer        | S1          | 1.000        | S2          | 5.1              | 0.600             | 0.287    | 0.0361           |                       |
| 15 minute summer        | S2          | 1.001        | S3          | 9.4              | 0.702             | 0.529    | 0.1167           |                       |
| 15 minute summer        | S3          | 1.002        | S4          | 13.4             | 0.802             | 0.753    | 0.0484           |                       |
| 15 minute summer        | S4          | 1.003        | S5          | 17.1             | 1.417             | 0.965    | 0.2748           |                       |
| 15 minute summer        | S5          | 1.004        | S6          | 21.3             | 2.547             | 0.379    | 0.0856           |                       |
| 15 minute summer        | S6          | 1.005        | S8          | 25.4             | 2.289             | 0.448    | 0.0529           |                       |
| 15 minute summer        | S7          | 2.000        | S8          | 4.3              | 0.637             | 0.076    | 0.0329           |                       |
| 15 minute summer        | S8          | 1.006        | Tank Inlet  | 33.8             | 5.031             | 0.598    | 0.0125           |                       |
| 15 minute summer        | Tank Inlet  | 1.007        | Tank Outlet | 32.7             | 0.138             | 0.007    | 9.5663           |                       |
| 15 minute summer        | Tank Outlet | 1.008        | S9          | 2.8              | 0.511             | 0.156    | 0.0264           |                       |
| 15 minute summer        | S9          | Hydro-Brake® | COM1        | 0.8              |                   |          |                  | 10.4                  |

**Results for 100 year +40% CC +10% A Critical Storm Duration. Lowest mass balance: 98.95%**

| Node Event        | US Node     | Peak (mins) | Level (m) | Depth (m) | Inflow (l/s) | Node Vol (m³) | Flood (m³) | Status     |
|-------------------|-------------|-------------|-----------|-----------|--------------|---------------|------------|------------|
| 15 minute summer  | S1          | 10          | 101.251   | 0.101     | 6.7          | 0.1332        | 0.0000     | OK         |
| 15 minute summer  | S2          | 10          | 101.247   | 0.139     | 11.6         | 0.1777        | 0.0000     | OK         |
| 15 minute summer  | S3          | 9           | 101.217   | 0.197     | 15.9         | 0.2494        | 0.0000     | SURCHARGED |
| 15 minute summer  | S4          | 9           | 101.183   | 0.192     | 19.4         | 0.2413        | 0.0000     | SURCHARGED |
| 15 minute summer  | S5          | 9           | 100.832   | 0.070     | 23.6         | 0.0862        | 0.0000     | OK         |
| 15 minute summer  | S6          | 9           | 99.840    | 0.085     | 29.0         | 0.1003        | 0.0000     | OK         |
| 15 minute summer  | S7          | 9           | 99.742    | 0.032     | 5.5          | 0.0374        | 0.0000     | OK         |
| 720 minute summer | S8          | 495         | 99.487    | 0.210     | 4.9          | 0.2466        | 0.0000     | SURCHARGED |
| 720 minute summer | Tank Inlet  | 495         | 99.487    | 0.360     | 4.9          | 0.0000        | 0.0000     | OK         |
| 720 minute summer | Tank Outlet | 495         | 99.487    | 0.420     | 3.0          | 0.0000        | 0.0000     | SURCHARGED |
| 720 minute summer | S9          | 495         | 99.487    | 0.435     | 2.0          | 0.4919        | 0.0000     | SURCHARGED |
| 15 minute summer  | COM1        | 1           | 99.000    | 0.000     | 0.8          | 0.0000        | 0.0000     | OK         |

| Link Event (Outflow) | US Node     | Link         | DS Node     | Outflow (l/s) | Velocity (m/s) | Flow/Cap | Link Vol (m³) | Discharge Vol (m³) |
|----------------------|-------------|--------------|-------------|---------------|----------------|----------|---------------|--------------------|
| 15 minute summer     | S1          | 1.000        | S2          | 6.1           | 0.619          | 0.343    | 0.0630        |                    |
| 15 minute summer     | S2          | 1.001        | S3          | 10.4          | 0.719          | 0.586    | 0.1517        |                    |
| 15 minute summer     | S3          | 1.002        | S4          | 13.9          | 0.827          | 0.780    | 0.0511        |                    |
| 15 minute summer     | S4          | 1.003        | S5          | 18.1          | 1.391          | 1.022    | 0.2932        |                    |
| 15 minute summer     | S5          | 1.004        | S6          | 23.5          | 2.590          | 0.419    | 0.0939        |                    |
| 15 minute summer     | S6          | 1.005        | S8          | 28.9          | 2.314          | 0.510    | 0.0595        |                    |
| 15 minute summer     | S7          | 2.000        | S8          | 5.5           | 0.667          | 0.097    | 0.0375        |                    |
| 15 minute summer     | S8          | 1.006        | Tank Inlet  | 39.8          | 4.989          | 0.702    | 0.0181        |                    |
| 15 minute winter     | Tank Inlet  | 1.007        | Tank Outlet | 40.6          | 0.146          | 0.009    | 12.5961       |                    |
| 15 minute winter     | Tank Outlet | 1.008        | S9          | 3.7           | 0.566          | 0.209    | 0.0264        |                    |
| 720 minute summer    | S9          | Hydro-Brake® | COM1        | 0.8           |                |          |               | 60.0               |