Donna Khan

Dear Donna,

Ref: Drainage Statement - Unit 15A-H

Further to your email and its content regarding a Drainage Statement requirement for the refurbishment of Unit 15A-H at Leconfield Industrial Estate, we would advise as follows:

1. Existing Drainage

The existing drainage for Unit 15A-H comprises a network of surface water and foul water drains to the front of the building. The existing rainwater pipes drain to the surface water drain noted. Existing internal toilets, sink and waste outlets drain to the existing foul sewer noted. The exact route of rainwater pipes and foul outlets to sewer connections are indicative on plan and are to be confirmed via CCTV drainage survey.

The existing surface water drain previously noted ultimately discharges to Nor Beck culverted watercourse.

The existing foul water sewer previously noted ultimately discharges to a 675mm diameter United Utilities combined sewer west of Unit 15A-H.

2. Proposed Drainage

Unit 15A-H is to be re-furbished and re-clad externally. As part of the works any internal rainwater pipes are to be moved externally and boxed out in new positions. The new rainwater pipes are to utilise the existing sewers previously noted.



& Partners

Consulting Engineers

Building Surveyors

Wellington House Wellington Court Preston Farm Business Park Stockton-on-Tees TS18 3TA

Directors:

J Conway BSc CEng MICE
IR Walker BEng CEng MICE MinstLM
N Baines BSc CEng MIStructE
PA Winship BEng CEng MICE
S Graham MEng CEng MIStructE
M Ramsay BSc CEng MIStructE
J Creber BEng CEng MIStructE
BH Roe HNC
S Ramshaw HNC

Associate Directors:

A Crosby BSc MA MRICS CBUILD MCABE R Walton BEng MSc CEng MICE T Cutter Meng CEng MICE S Clark BEng C Nixon BSc D Hedley AaPS







Yours Sincerely

Written by	Signed	Date
James Herbert – Design Engineer		29/04/2022
Approved by	Signed	Date
Jim Conway - Director		29/04/2022