

Oliver Hoban

From: Environmental Health
Sent: 20 November 2025 14:32
To: Development Control
Cc: Christopher Harrison
Subject: PLANNING APP 4/25/2272/0F1 - PRESTON STREET, WHITEHAVEN

Proposed car wash and valeting facility including retention of existing cabin building on existing garage and car sales site

Thank you for the above planning consultation and the additional information dated November 2025.

The proposed 2 m high Perspex screen is acceptable to Environmental Health.
The proposed site welfare facilities are basic though are acceptable. Portable heating may be required during wet / cold weather for staff use so that a reasonable temperature is provided within the site welfare cabin and that wet clothes can be dried. Note that the enforcing authority for this proposed premises would be the HSE.
In principle, the revised drainage arrangements for the car wash effluent are also acceptable with a drain interceptor being provided before discharge to a combined public sewer. However United Utilities advice on this matter would be required.

Regards

Environmental Health
Public Health & Protection | Cumberland Council
Whitehaven Commercial Park, Moresby Parks, Whitehaven, Cumbria, CA28 8YD

T. 0300 373 3730

cumberland.gov.uk

