

Oliver Hoban

From: Sarah Papaleo
Sent: 15 April 2024 15:16
To: Development Control
Subject: FW: 4/24/2087/0F1 - Utopia House, Lowca

Hi,

Can I please have this on the website and MIS as a consultation response? Thank you!

Please note that the advice in this email is given in good faith on the basis of the information available at the present time. The advice may be subject to revision following further examination or consultation, or where additional information comes to light, and is therefore not binding on any future recommendation which may be made to the Council or any formal decision by the Council.

Kind regards,

Sarah Papaleo MRTPI
Senior Planning Officer
Development Management
Cumberland Council

From: Kevan Buck
Sent: Monday, April 15, 2024 3:00 PM
To: Sarah Papaleo
Subject: RE: 4/24/2087/0F1 - Utopia House, Lowca

Afternoon Sarah

Thank you for the information on the inverters.

The inverters are quiet (less than 30 db) and should not cause disturbance to the nearest noise-sensitive property.

No further comments from Environmental Health.

Regards

Kevan Buck
Environmental Health Officer - Environmental Health
Public Health & Protection | Cumberland Council
Whitehaven Commercial Park, Moresby Parks, Whitehaven, Cumbria, CA28 8YD

cumberland.gov.uk