

Oliver Hoban

From: Environmental Health
Sent: 07 May 2026 16:17
To: Development Control
Cc: Christie Burns
Subject: 4/26/2117/0B1 - SPAR, 1 MAIN STREET, FRIZINGTON

Variation of conditions 2 (approved plans), 12 (boundary treatment) and 13 (acoustic fencing) of planning application 4/24/2313/0B1 – Variation of conditions 4, 5, 6, 7, 8 and 9 of planning approval 4/22/2200/0F1

Thank you for the above planning consultation.

There are no objections to the proposed amendments from Environmental Health. The acoustic fencing should be imperforate and incorporate suitable gravel boards to seal the gap at the base of the fence with the ground level.

Regards

Environmental Health
Public Health & Protection | Cumberland Council
Whitehaven Commercial Park, Moresby Parks, Whitehaven, Cumbria, CA28 8YD

T. 0300 373 3730

cumberland.gov.uk

