

Oliver Hoban

From: Environmental Health
Sent: 02 January 2025 12:05
To: Development Control
Cc: Christopher Harrison
Subject: PLANNING APP 4/24/2401/0F1 -FORMER JOHN PAUL JONES PH, DUKE STREET, WHITEHAVEN

Demolition of former John Paul Jones Public House

Thank you for the above planning consultation.

There are no objections to this proposal from Environmental Health.

The proposed hours of work (Monday to Friday 08.00 – 17.00) are acceptable to Environmental Health and may be included in a condition if planning approval is granted.

Water suppression and dust mitigation measures should be employed during the demolition works, and Environmental Health would request that no crushing of waste materials is carried out on this site.

If heras fencing is erected around the site perimeter, debris mesh netting should also be provided to prevent the escape of any wind-blown debris (such as lightweight cavity wall insulation material) produced during the demolition process.

Regards

Environmental Health
Public Health & Protection | Cumberland Council
Whitehaven Commercial Park, Moresby Parks, Whitehaven, Cumbria, CA28 8YD

T. 0300 373 3730

cumberland.gov.uk

