

**Oliver Hoban**

---

**From:** Environmental Health  
**Sent:** 06 January 2025 11:42  
**To:** Development Control  
**Subject:** PLANNING APP 4/24/2358/0F1 - 1 ROWNTREE GARDENS, EGREMONT

Installation of an air source heat pump on the front of the property, solar panels on the roof

Thank you for the submission of the MCS020 noise calculation as requested.  
This is satisfactory and Environmental Health duly has no objections to this proposal.

Please note that there can be tonal noise associated with the air source heat pump, and the unit should be maintained in good order otherwise noise issues can result. In such circumstances, the statutory nuisance provisions of the Environmental Protection Act 1990 may apply.

Regards

Environmental Health  
Public Health & Protection | Cumberland Council  
Whitehaven Commercial Park, Moresby Parks, Whitehaven, Cumbria, CA28 8YD

T. 0300 373 3730

[cumberland.gov.uk](https://cumberland.gov.uk)

