

Christie Burns

From: Stuart Woodall
Sent: 08 December 2023 10:47
To: Christie Burns
Subject: RE : Planning App 4/23/2174/0F1 - Change of Use from Existing Shop to Mixed Use, 10-11 South Parade, Seascale
Attachments: UVS1369-03C B Regs v2024-Layout1.pdf

CAUTION: External email, think before you click!
Please report any suspicious email to our [IT Helpdesk](#)

Hi Christie

Mittons Refrigeration from Carlisle have completed the design for the kitchen, details of the fan is attached alongside the acoustic rating of the fan which Environmental Health will need to assess the proposal. The finish will be galvanised.

The 450 dia plate fan ratings are:-
36Kw
SC 3.6
FLC 1.6
dBa 61@ 3 mtrs.

Stuart Woodall RIBA

Chartered Architects
Green Swallow North Limited
Swallow Barn
Blindcrake
Cumbria
CA13 0QP