

Christie Burns

From: Stuart Woodall
Sent: 03 April 2024 13:45
To: Christie Burns
Subject: RE: Planning App 4/23/2174/0F1 - Change of Use from Existing Shop to Mixed Use, 10-11 South Parade, Seascale
Attachments: unnamed document.pdf

CAUTION: External email, think before you click!
Please report any suspicious email to our [IT Helpdesk](#)

Hi Christie

I have attached details of the cladding brochure for the external wall.

The fan extract I have been advised is 450mm diameter as per the technical specification.

With regards the Fire Door to the side elevation - the can be conditioned for this purpose

Stuart Woodall RIBA

Chartered Architects
Green Swallow North Limited
Swallow Barn
Blindcrake
Cumbria
CA13 0QP