

**Oliver Hoban**

---

**From:** Environmental Health  
**Sent:** 27 November 2024 11:49  
**To:** Development Control  
**Subject:** PLANNING APP 4/24/2358/0F1 - 1 ROWNTREE GARDENS, EGREMONT

Installation of an air source heat pump to be installed at front of property, solar panels on roof

Thank you for the above planning consultation.

In principle, Environmental Health has no objections to this development. However, a MCS020 Noise Assessment has not been submitted with the application. This is required in order to demonstrate that the installation of the ASHP will meet the minimum planning standard of a noise output of 42 dBA within one metre of the nearest neighbouring residential door or window opening. In order to protect residential amenity therefore, a MCS020 noise assessment should be submitted by the applicant's MCS contractor.

Regards

Environmental Health  
Public Health & Protection | Cumberland Council  
Whitehaven Commercial Park, Moresby Parks, Whitehaven, Cumbria, CA28 8YD

T. 0300 373 3730

[cumberland.gov.uk](https://cumberland.gov.uk)

