

Route	to	this	nag	10
HOULE	CO	11117	Pu.	_

->Matrix->Matrix>Cell D3

Restart *

Print Form

Householder and other minor extensions in Flood Zones 2 and 3

This guidance is for domestic extensions and non-domestic extensions where the additional (cotaring created by the development does not exceed 250 sq. metres, it should NOT be applied if an additional dwelling is being created, e.g. a self-contained annex, in this instance consult the Environment Agency

We recommend that:

Figuring Authorities:

- Refer the applicant to the standing advice pages on the Environment Agency website or provide them with
 a copy of this page for them to include as part of the planning application submission.
- Check the planning application to ensure that one or other of the mitigation measures from the table below has been incorporated.

Applicants:

Complete the table below and include it with the planning application submission. The table, together with the supporting evidence, will form the Flood Risk Assessment (FRA) and will act as an assurance to the Local Planning Authority (LPA) that flood risk issues have been adequately addressed.

Applicant to choose one or other of the flood mitigation measures below	Applicant to provide the LEA with the supporting Information detailed below as part of their FRA	Applicant to indicate their choice in the box below. Enter 'yes' or 'no'
Either; Floor levels within the processed development will be set no lower than existing levels AND, flood proofing of the proposed development has been incorporated where appropriate.	Details of any flood proofing / resilience and resistance techniques, to be included in accordance with 'Improving the flood performance of new buildings' CLG (2007)	YES P.TO
Floor levels within the extension will be set 300mm above the known or modelled 1 in 100 annual probability river flood (1%) or 1 in 200 annual probability sea flood (0.5%) in any year. This flood level is the extent of the Flood Zones	This must be demonstrated by a plan that shows finished floor levels relative to the known or modelled flood level. All levels should be stated in relation to Ordinance Datum ¹	No

Subterranean/basement extensions

Due to the risk of rapid inundation by floodwater basements should be avoided in areas at risk of flooding. The LPA may hold additional guidance for basement extensions.

Self-contained basement dwellings are 'highly vulnerable' development and should not be permitted in Flood Zone 3. We are fundamentally opposed to these developments.

Continued...

¹ Ordnance Datum or the abbreviation 'OD' is the mean level of the sea at Newlyn in Cornwall from which heights above sea level are taken. The contour lines on Ordnance Survey maps measure heights above OD for example, though these are not accurate enough for a flood risk assessment..

- · FLOOR LEVEL OF EXTENSION TO BE IN SAME PLANE AS EXISTING HOUSE FLOOR.
 - . THERE IS NO INCREASE IN DRAINED SURFACE WATER AS THE WHOLE REAR YARD IS ROOFED, & CONTRETED.
 - · APPLICANT PROVIDED WITH COPY OF ENVIRONMENT AGENCY GUIDFON FLOOD DAMAGE LIMITATION, TO INCORPORATE INTO WORKS, & E.A. FLOODLINE TEL NO 0845, 988. 1188

FLOOD RISK MEMBURES

- ALL NEW ELECTRICAL SWITCHES & SUCKETS TO BE LOCATED MIN 450(18)
 ABOVE FLOOD LEVEZ (AS PER BUILDING REG'S REQUIREMENT & AS PER
 NOTE 8 ON PLAN NO 1678)
- · ANY AIR BRICKS IN FRONT ELEVATION TO TIMBER FLOOR SECTION TO BE SEALED OFF IN TIMES OF POSSIBLE FLOODING.
- " FLOOD BOARDS TO BE MADE + STORED READY FOR USE FOR ALL DOORS INTO BUILDING. (OR FLOOD RESILIENT DOORSETS INSTALLED)
- · GROWNO FLOOR W.C, SHOWER BATH · YARO GULLES TO BE PLUGGED / COVERED WITH WEIGHTED PLUG/SANDBAGS ETC, TO REDUCE BACK FLOW FROM THE SEWER SYSTEM, OR WHERE PRACTICAL, NOW-RETURN VALUES FITTED.
- · INSPECTION CHAMBERS COVERED WITH SCREW OCUN TYPE COVERS;
- · APPLICANT TO CONSIDER REGISTERING WITH E.A. AUTOMATIC FLOOD WARNING SYSTEM.
- · ANY CONTAMINATES . EG PAINTS . OILS, PESTIBIDES, CLEANING PRODUCTS,
 TO BE STORED AT A HIGHER LEVEL IN STORE ROOM .