




S BED & SURR



DESIGN NOTE
APPROVAL TO BE IN PLACE WITH UNITED UTILITIES BEFORE CONNECTION IS MADE TO THE PUBLIC SEWER SYSTEM











- No dimensions are to be measured from this drawing.
- All levels shown are in metres unless otherwsie shown. 3. This drawing is to be read in conjunction with all relevant Architects,
- Planning and Infrastructure Design drawings. 4. The position and levels of all existing drains are to be confirmed on site prior to the commencement of the works and any discrepancies
- reported immediately to the engineer. 5. All private drainage is to constructed in accordance with th latest
- and to BSEN752 (Building Drainage). 6. All adoptable drainage is to be in accordance with the requirements of

edition of the Building Regulations Part H (Drainage & Waste Disposal)

- Sewers for Adoption 6th Edition and the Sewerage Undertaker/Council.
- . All connections to existing public sewers are to be made to the satisfaction of the Sewerage Undertaker and the Local Authority.
- . Existing drains being abandoned are to be dealt with in the following
- i) Within 1.0m of proposed ground levels, drains are to be
- ii) Deeper than 1.0m of proposed ground levels drains are to be grouted with a 1:10 cement:sand:mix.
- Any existing gully connections being abandoned are to be sealed with
- a concrete plug not less than 300mm thick at a level of 1.0m below
- 10. Concrete protection of pipework is to be provided as follows:i) All pipework within pedestrian / soft areas with a cover less than 600mm.
- ii) All pipework beneath areas subject to vehicular overrun with a cover less than 1.2m.
- 11. All pipework within manholes are to be laid soffit to soffit.
- 12. Any gradients of drains are indicative only and The Contractor shall install drains to the invert levels shown for each manhole.
- 13. Any co-ordinate information regarding manholes is to the centre of the
- 14. Cover levels of the manholes are provisional and subject to adjustment to suit the finished ground levels.
- 15. The use of short radius bends for changes in direction is not permitted,
- only long radius bends or 2 No. are to be used. 16. Connections to carrier drains are to be 'Y' junctions.
- 17. Manhole covers and frames are to be in accordance with BS EN 124
- Vehicular areas : Class D400 double triangular 150mm (min) deep ductile iron cover & frame with three-point cover seating. Pedestrian areas only: Class B125 double triangular 100mm (min) deep ductile iron cover & frame with

and the following criteria:-

- 18. Heavy duty cover slabs are to be used with Class D400 frames.
- 19. Gully gratings and channel covers are to be in accordance with BS EN
- i) Areas subject to vehicular overrun: Class D400 minimum. Class F900 within service yard.
- ii) Areas not subject to vehicular overrun: Class C250
- 20. Gully gratings are to be double triangular ductile iron with a non-rock design and a 100mm deep frame.
- 21. Outside of sewers to be 1.0m (min) from kerb line.
- 22. Outside of manholes to be 0.5m (min) from kerb line.
- 23. All non-adoptable foul and surface water pipes to be 100 diameter unless noted otherwise.
- 24. Proposed 225mm diameter inspection chambers to be laid at a maximum depth of 600mm below GL.
- 25. Proposed 450mm diameter inspection chambers to be laid at a
- maximum depth of 3000mm below GL.
- 26. Installation of all pipework, manholes, gullies & channels etc are to be laid to manufacturers specification.



INITIAL ISSUE

Ivy Mills CUMBRIA

LONGITUDINAL SECTIONS 1 OF 2

H=1:100 V=1:500 @ A1 Date CML 06.01.22 GHC-HA-H-13-01 C

06.01.22 CML

Site Infrastructure Services Ltd

 C
 AMENDED TO NEW LAYOUT
 13.05.22
 CML

 B
 AMENDED TO UU COMMENTS DATED 17.02.22
 18.02.22
 CML

 A
 DISCHARGE RATES REVISED
 26.01.22
 CML

PROVISIONAL Subject to UU Approval

UNDER NO CIRCUMSTANCES SHALL ANY PROPOSED LEVELS BE AMENDED WITHOUT THE PRIOR CONSULTATION WITH SITE INFRASTRUCTURE SERVICES LTD

ALL COVER & INVERT LEVEL INFORMATION HAS BEEN TAKEN

FROM AVAILABLE TOPOGRAPHICAL SURVEY DATA OR UNITED

UTILITY RECORDS AND CCTV REPORT. EXISTING PUBLIC FOUL

AND SURFACE WATER SEWERS ARE TO BE ABOVE GROUND

PROBED, ROUTED AND INTERNALLY SURVEYED WITH ALL INFORMATION PASSED TO SITE INFRASTRUCTURE SERVICES LTD FOR REVIEW PRIOR TO COMMENCEMENT ON SITE