

## Richard Lindsay

---

**From:** Moultrie, James M  
**Sent:** 14 July 2020 13:29  
**To:** Richard Lindsay  
**Subject:** RE: Crossfield Road

Hello Richard,

The arrangement shows the required visibility splay and is therefore acceptable.

Regards

James

### James Moultrie

Assistant Development Management Officer  
Flood & Development Management  
Economy & Infrastructure | Cumbria County Council  
Parkhouse Building | Baron Way | Carlisle | CA6 4SJ

[www.gov.uk/floodsdestroy](http://www.gov.uk/floodsdestroy)

**DO YOU KNOW WHAT TO DO?**



**From:** Richard Lindsay  
**Sent:** 14 July 2020 11:01  
**To:** Moultrie, James M

**Subject:** FW: Crossfield Road

Hi James

See attached revised and updated plans showing the central access to the site and the visibility splays to both sides north and south which easily achieve the 19.8m x 2.4m you requested.

The corner piece of wall on the SW corner of the plot( owned by me client) will be reduced in height to enable the visibility to comply with requirements.

Hope all this is acceptable and I look forward to hearing from you.

Kind Regards

Richard