

PT

Telford, Paul

Inbox - Exchange 31 January 2023 at 11:05

RE: 5702 Mr J. Korwin-Granford - Land at Green Close, Seascale - Pre-Planning Enquiry Ref: PAA/22/0133

To: Michael Podmore

Mike

Another thing that came to my attention after I sent the email was the condition of the pipe shown in the survey, we would recommend that certain sections of the pipe/culvert should be replaced during construction phase as wouldn't want to get the development site complete then the system fails.

Regards

Paul Telford

**Development Management Officer | Flood & Development Management
Economy & Environment | Cumbria County Council |
Parkhouse Building | Baron Way | Carlisle | CA6 4SJ**

m : 07901515964

e : www.cumbria.gov.uk

Please be aware that I work flexible hours, so whilst this is a convenient time for me to send this email to you – I do not expect a response from you outside your normal working hours.