

## Oliver Hoban

---

**From:** PlanningGatewayOne  
**Sent:** 01 December 2023 09:13  
**To:** Development Control  
**Subject:** RE: 4/21/2432/0F1 - FORMER MARCHON CHEMICAL FACTORY, HIGH ROAD, WHITEHAVEN

**CAUTION: External email, think before you click!**  
Please report any suspicious email to our [IT Helpdesk](#)

Dear Sir/Madam,

Thank you for your email in relation to the above application.

HSE is the statutory consultee for planning applications that involve or may involve a relevant building.

Relevant building is defined as:

- contains two or more dwellings or educational accommodation and
- meets the height condition of 18m or more in height, or 7 or more storeys

“Dwellings” includes flats, and “educational accommodation” means residential accommodation for the use of students boarding at a boarding school or in later stages of education (for definitions see article 9A (9) of the Town and Country Planning Development Management (England) Procedure Order 2015 as amended by article 4 of the 2021 Order.

However, from the information you have provided for this planning application, it does not appear to fall under the remit of planning gateway one because the purpose of a relevant building has not been met.

Further information is available on the HSE website [here](#).

Once again thank you for your email, if you require further advice with regards to this application, please do not hesitate to contact the planning gateway one team quoting our your number in all future correspondence.

Kind Regards

**Ethan Fakir**

**Operational Support,  
Building Safety and Construction Division**

Health And Safety Executive, Redgrave Court, Merton Road, Bootle, Merseyside, Liverpool, L20 7HS

☎: ✉: [PlanningGatewayOne@hse.gov.uk](mailto:PlanningGatewayOne@hse.gov.uk)

## Building Safety eBulletin

Keep up-to-date with  
the work of the Building  
Safety Regulator

[Subscribe Now](#)

