








Key to Surface Finishes
Outside Opencast Mine

- 


ADOPTED ACCESS ROAD:
45mm HRA, 55mm Binder course, 90mm Base course,
300mm DFT Type 1 Sub-base (Min. CBR > 5%)
- 


ADOPTED 2m FOOTWAY:
30mm Dense graded macadam surface course,
50mm Binder course, 150mm DFT Type 1 Sub-base
(increases to 225mm at driveway cross-overs)
- 

PRIVATE ACCESS ROAD:
80mm concrete block paving to Architect's details &
colour, 30mm sand laying course, 125mm DBM base,
300mm DFT Type 1 Sub-base (Min. CBR > 5%)
- 

PRIVATE DRIVEWAY:
60mm concrete block paving to Architect's details & colour,
30mm sand laying course, 150mm DFT Type 1 Sub-base
(Min. CBR > 5%)
- 


PRIVATE FOOTWAY/FOOTPATH:
30mm Dense graded macadam surface course, 50mm
Binder course, 150mm DFT Type 1 Sub-base
(increases to 225mm at driveway cross-overs)


- 


Adopted Lighting Column: Refer to SHD Lighting Design & Specification
- 


Private Lighting Column: Refer to SHD Lighting Design & Specification


Key to Surface Finishes
Within Opencast Mine

- 

ADOPTED ACCESS ROAD:
45mm HRA, 55mm Binder course, 90mm Base course,
160mm DFT Type 1 Sub-base on Tensar Geogrid or
similar approved on 200mm 6F2/6F5 on Tensar
Geogrid or similar approved (Min. CBR > 2%)
- 

ADOPTED 2m FOOTWAY:
30mm Dense graded macadam surface course, 50mm
Binder course, 160mm DFT Type 1 Sub-base on
Tensar Geogrid or similar approved on 200mm
6F2/6F5 on Tensar Geogrid or similar approved
- 

PRIVATE ACCESS ROAD:
80mm concrete block paving to Architect's details &
colour, 30mm sand laying course, 125mm DBM base,
160mm DFT Type 1 Sub-base on Tensar Geogrid or
similar approved on 200mm 6F2/6F5 on Tensar
Geogrid or similar approved (Min. CBR > 2%)
- 

PRIVATE DRIVEWAY:
60mm concrete block paving to Architect's details &
colour, 30mm sand laying course, 125mm DBM base,
160mm DFT Type 1 Sub-base on Tensar Geogrid or
similar approved on 200mm 6F2/6F5 on Tensar
Geogrid or similar approved (Min. CBR > 2%)
- 

PRIVATE FOOTWAY/FOOTPATH:
30mm Dense graded macadam surface course, 50mm
Binder course, 160mm DFT Type 1 Sub-base on
Tensar Geogrid or similar approved on 200mm
6F2/6F5 on Tensar Geogrid or similar approved



Rev	Description	Date	Revised by	Checked by	Approved
Issue Purpose:					
Planning					
Do not scale from this drawing					
<div><div><div>NS</div><div>1 32548</div></div></div>		Scale @ A1: 1:500	First Issue: 03/05/24	Office of Origin: Kendal	
		Drawn by: MWG	Checked by: TM	Approved: TM	
		Project No: K40340	Drawing No: 12	Rev:	
		BIM No:			

R G PARKINS
Kendal | 01539 729393 Lancaster | 01524 32548

Client: **Washington Homes**
Project: **Harras Dyke Farm, Whitehaven**
Drawing Title: **External Works Plan Full Site**