

ADDITIONAL FOUL WATER DRAINAGE NOTES:

- LOCATION OF ALL EXISTING DRAINAGE TO BE CONFIRMED ON SITE PRIOR TO COMMENCEMENT OF WORKS AS IT IS APPROXIMATELY
- TRANSLATED FROM SURVEY DRAWING. ALL DRAINAGE AT MANHOLES/ACCESS CHAMBERS TO CONNECT WITH SOFFITS LEVEL UNLESS OTHERWISE NOTED. MANHOLE INVERT LEVELS SHOWN ON PLAN ARE THAT OF LOWEST OUTGOING PIPE.
- ALL FOUL DRAINAGE TO BE 100mm DIA. UNLESS OTHERWISE
- NOTED. ALL INTERNAL 100mm DIA. SOIL VENT PIPE CONNECTIONS TO BE LAID AT FALLS NOT LESS THAN 1:40 TO SUIT CONNECTION INTO MAIN NETWORK OR 1:80 IF AT LEAST 1 WC IS CONNECTED. ALL TOILET/SVP FOUL BRANCH CONNECTIONS TO BE MADE USING OBLIQUE 45° CONNECTION IN THE DIRECTION OF FLOW OF THE
- MAIN LINE. FOR INTERNAL FOUL CONNECTIONS WITHOUT A TOILET/SVP WHERE OBLIQUE CONNECTIONS ARE NOT POSSIBLE 87.5° CURVED SQUARE BRANCH CONNECTIONS TO BE USED IN DIRECTION OF FLOW OF
- MAIN LINE.
- FOUL RODDING POINTS SHOULD BE PROVIDED, ABOVE SPILLOVER LEVEL OF CONNECTED APPLIANCES, IN DISCHARGE STACKS TO GIVE ACCESS TO ANY LENGTH OF PIPE WHICH CANNOT BE REACHED FROM ANY OTHER PART OF THE NETWORK.
- ALL DRAINAGE WITHIN 300mm OF UNDERSIDE OF STRUCTURAL SLAB TO HAVE FULL GEN 3 CONCRETE BED AND SURROUND. ALL INTERNAL MANHOLE & INSPECTION CHAMBERS TO HAVE SCREW
- DOWN DOUBLE SEAL ACCESS COVERS.
- ALL INTERNAL & EXTERNAL FOUL WATER INSPECTION CHAMBERS SITUATED IN AREAS WITHOUT VEHICULAR ACCESS TO BE TYPE 3 CHAMBERS WITH 150mm DOT TYPE 1 SURROUND UNLESS NOTED OTHERWISE.
- ALL EXTERNAL FOUL WATER INSPECTION CHAMBERS SITUATED IN AREAS WITH VEHICULAR ACCESS TO BE TYPE 3 CHAMBERS WITH GEN 3 CONCRETE SURROUND UNLESS NOTED OTHERWISE. ALL TYPE 3 INSPECTION CHAMBERS WHERE DEPTH TO INVERT OF
- CHAMBER IS > 1m SHALL HAVE COVER FRAME WITH ACCESS RESTRICTED TO 350mm DIA. OR 300x300mm SQUARE. ALL EXTERNAL FOUL WATER MANHOLES TO BE MIN. 1200mm DIA. WIDE WALL (125mm THICK) TYPE 2 PRECAST CONCRETE CHAMBERS
- UNLESS NOTED OTHERWISE. MANHOLE COVER LEVELS ARE SUBJECT TO CONFIRMATION OF FINAL EXTERNAL & INTERNAL LEVELS.
- THE LOAD CLASS OF ALL COVERS, GRATINGS, GULLIES, CHANNELS & FRAMES TO CHAMBERS TO SUIT THEIR LOCATION AS FOLLOWS (REFER TO MANHOLE SCHEDULE FOR CONFIRMATION):
  - A15 INTERNAL LOCATIONS
  - B125 EXTERNAL WITH PEDESTRIAN ACCESS ONLY C250 – EXTERNAL LIGHTLY TRAFFICKED AREAS
  - D400 MAIN ROADS/HIGHWAYS
- E600 HGV/LOADING BAY AREAS GRATINGS IN PEDESTRIAN AREAS TO HAVE HEEL SAFE ANTI-SLIP COVERS.
- REFERENCE SHOULD BE MADE TO ARCHITECT & M&E ENGINEERS DRAWINGS FOR ABOVE GROUND DRAINAGE DETAILS & SET-OUT. ALL EXISTING DRAINAGE THAT IS MADE REDUNDANT AS A RESULT
- OF THE WORKS TO BE GRUBBED UP AND REMOVED.
- THE LAYOUT OF PIPELINES, MANHOLES ETC. IS DESIGNED TO SUIT THE PERMANENT CASE. ADDITIONAL LOADS OVER & ABOVE THOSE DESIGNED FOR MAY ARISE DURING THE CONSTRUCTION PROCESS. THE CONTRACTOR SHALL PROVIDE ANY NECESSARY TEMPORARY PROTECTION TO ENSURE THAT PIPELINES, MANHOLES ETC. ARE
- NOT DAMAGED DURING THE CONSTRUCTION PHASE.

## LEGEND.

----- EXISTING FOUL SEWERS NEW BRANCH FOUL SEWERS ----- NEW MAIN FOUL SEWERS CONCRETE ENCASED FW SEWER () <u>FXX</u> NEW FOUL MANHOLE ---- EXISTING FOUL RISING MAIN ---- FOUL RISING MAIN ----- NEW TRADE EFFLUENT SEWERS  $\square$  <u>TEXX</u> NEW TRADE EFFLUENT MANHOLE ----- EXISTING COMBINED SEWERS ----- NEW COMBINED SEWERS NEW COMBINED MANHOLE SOIL VENT PIPE (RODDABLE ACCESS) INTERNAL GULLY (TRAPPED & RODDABLE) STUB STACK VERTICAL BACK DROP INTERNAL CHANNEL DRAIN POINT RODDING EYE

THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL RELEVANT ARCHITECTS AND ENGINEERS DRAWINGS AND SPECIFICATIONS.

General Notes

- ALL DRAINAGE TO BE TO THE SATISFACTION OF THE LOCAL AUTHORITY 2. BUILDING CONTROL AND MAIN DRAINAGE SECTIONS ON MATTERS INVOLVING PUBLIC SEWERS.
- ALL PIPEWORK, BENDS AND JUNCTIONS TO BE EXTRA STRENGTH 3. VITRIFIED CLAY TO BS 65:1991, BS EN 295 OR PVCu TO BS EN 1401 TO BE AGREED WITH RELEVANT AUTHORITY.
- INVERT LEVELS ON EXISTING DRAINS & OUTFALLS TO BE CHECKED PRIOR TO COMMENCEMENT OF WORKS.
- TRENCH WIDTHS GENERALLY:- AS SMALL AS PRACTICABLE BUT NOT LESS THAN PIPE DIAMETER +300mm OR LARGER IF SPECIFIED. TRENCH SIDES MUST BE VERTICAL FROM BOTTOM UP TO 300mm ABOVE CROWN OF PIPE.
- WHERE DRAINAGE PIPES HAVE LESS THAN 1.2m COVER IN TRAFFICKED 6. AREAS AND LESS THAN 600mm UNDER LANDSCAPED AREAS PIPES SHALI HAVE A FULL CLASS Z CONCRETE SURROUND. CONCRETE PROTECTION TO BE DISCONTINUED AT EACH PIPE JOINT WITH COMPRESSIBLE MATERIAL. ALL OTHER FLEXIBLE PIPES TO HAVE CLASS S GRANULAR BEDDING DETAIL UNLESS OTHERWISE NOTED. ALL OTHER RIGID PIPES TO HAVE CLASS B GRANULAR BEDDING DETAIL UNLESS OTHERWISE NOTED.
- 7. GRANULAR BEDDING: 10mm SINGLE SIZED COARSE AGGREGATE SHALL BE USED ON PIPES
- NOT EXCEEDING 140mm DIAMETER. • 2-14mm WELL GRADED COARSE AGGREGATE MAY BE USED ON PIPES
- EXCEEDING 140mm BUT NOT EXCEEDING 400mm DIAMETER. • 4-20mm WELL GRADED COARSE AGGREGATE MAY BE USED ON PIPES EXCEEDING 400mm DIAMETER.
- THE DEPTH OF GRANULAR BEDDING UNDER THE PIPES SHALL BE X/6 OR 150mm, WHICHEVER IS GREATER, WHERE X=EXTERNAL DIAMETER OF THE PIPE.
- 8 ADOPTABLE PUBLIC SEWERS TO BE CONSTRUCTED IN ACCORDANCE WITH SEWERS FOR ADOPTION, 7th EDITION, SEPTEMBER 2012.
- 9. ALL PRIVATE DRAINAGE WORKS SHALL BE IN ACCORDANCE WITH "THE BUILDING REGULATIONS APPROVED DOCUMENT H" AND BRITISH STANDARD BS EN 752.
- 10. ALL NEW DRAINAGE TO BE TESTED PRIOR TO BACKFILL OF THE TRENCHES & PRIOR TO HANDOVER TO THE SATISFACTION OF THE BUILDING CONTROL INSPECTOR.
- 11. THE CONTRACTOR MUST LIAISE WITH THE LOCAL AUTHORITY MAIN DRAINAGE SECTION PRIOR TO COMMENCEMENT OF WORK ON PUBLIC DRAINAGE.
- 12. TRENCH BACKFILL SHALL BE COMPACTED IN LAYERS NOT EXCEEDING 250mm ONCE 300mm COVER HAS BEEN PROVIDED TO THE TOP OF PIPE.
- 13. THE CONTRACTOR SHALL ALLOW IN HIS RATES FOR MAINTAINING FLOW IN PUBLIC SEWERS AT ALL TIMES DURING DIVERSION WORKS INCLUDING TEMPORARY PUMPING AND ALSO KEEPING EXCAVATIONS FREE FROM GROUNDWATER INCLUDING PUMPING AND FORMATION OF TEMPORARY SUMPS.
- 14. THE CONTRACTOR SHALL MAKE PROVISIONS FOR AND LIAISE WITH ALL RELEVANT STATUTORY BODIES FOR THE MANAGEMENT OF TRAFFIC WHILE CARRYING OUT WORKS IN THE PUBLIC HIGHWAY.
- 15. THE CONTRACTOR IS TO SATISFY HIMSELF TO THE POSITION AND AND DEPTH OF THE PUBLIC UTILITIES AND ALLOW FOR TEMPORARY SUPPORT PROTECTION AND DIVERSION WORKS AS NECESSARY. THE CONTRACTOR SHALL ALSO INCLUDE FOR ANY TRIAL PIT EXCAVATIONS NECESSARY.
- 16. BACKFILL TO EXCAVATIONS IN PUBLIC HIGHWAYS TO BE WELL COMPACTED GRANULAR TYPE 1 TO CL.803 OF THE DTp SPECIFICATION FOR HIGHWAY WORKS 2009.
- 17. ALL EXTERNAL GULLIES TO BE 375mm DIA. MINIMUM, PRECAST CONCRETE, HEAVY DUTY, KITE MARKED & ANTI-THEFT.

P2	11.08.23	ISSUE	M.H	C.J.H							
P1	06/07/23	PREL	OJ								
Rev	Rev Date Comment										
Stat	tus Code S3		Drawing Status FOR APPROVAL								
TI	This drawing may only be used for construction/manufacture if status is CONSTRUCTION										
Furness Partnersnip Consulting Structural/Civil Engineers London 20 Britton Street, London, EC1M 5TX tel: 020 7490 4353 fax: 020 7490 4354 e-mail: info@furnesspartnership.com Bradford The Paper Hall, Anne Gate, Bradford, BD1 4EQ tel: 01274 392092 e-mail: mail@furnesspartnership.com											
Proj	<sub>ject</sub>	11	LOM LE	EISURE CENTRE							
Dra	wing Title										
PROPOSED FOUL WATER											

## DRAINAGE LAYOUT

FP Job No.		Drawn		Date	Date		Checked		Scale @ A1	
L2762 O.J		JUN '23		C.J.H		1:200				
PROJECT	OPERA	TOR	ZONE / VOLUME	LEVEL / LOCATION	FILE TYP	ΡĒ	ROLE	SHE	ET No.	Rev.
L2762	FL	JR	XX	XX	DR		D	09	911	P2

---- ABANDONED SEWER TO BE REMOVED