

OFF ARLECDON ROAD, CUMBRIA

Private Development

Proposed Equipment Schedule

01 April 2023

SHD961-SHD-HLG-ARLE-SH-EO-Lighting Schedule-R0



info@shdlighting.co.uk 07834 490 192 www.shdlighting.co.uk

Proposed Unit No.	Easting Coordinates	Northing Coordinates	Location	Unit Description	Service Connection Type	Primary Isolator Detail	Secondary Isolator / Termination Type Detail
PR01	N/A	N/A	Refer to 'SHD961-SHD-HLG-ARLE-DR-EO-Lighting Layout-R0' private lighting design drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base with glass flake root protection as supplied by Mallatle, CU Phosco, Valmont Stainton or equivalent. Column to be manufactured to EN 40, BS EN 1461 & BS 5649 standard and supplied in factory applied black (RAL 9005) paint finish. with post top mounted at 0° tilt, Acrospire Defender 8w 1.34km solar lighting unit.	None required - Solar Installation	N/A	N/A
PR02	N/A	N/A	Refer to 'SHD961-SHD-HLG-ARLE-DR-EO-Lighting Layout-R0' private lighting design drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base with glass flake root protection as supplied by Mallatle, CU Phosco, Valmont Stainton or equivalent. Column to be manufactured to EN 40, BS EN 1461 & BS 5649 standard and supplied in factory applied black (RAL 9005) paint finish. with post top mounted at 0° tilt, Acrospire Defender 8w 1.34km solar lighting unit.	None required - Solar Installation	N/A	N/A
PR03	N/A	N/A	Refer to 'SHD961-SHD-HLG-ARLE-DR-EO-Lighting Layout-R0' private lighting design drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base with glass flake root protection as supplied by Mallatle, CU Phosco, Valmont Stainton or equivalent. Column to be manufactured to EN 40, BS EN 1461 & BS 5649 standard and supplied in factory applied black (RAL 9005) paint finish. with post top mounted at 0° tilt, Acrospire Defender 8w 1.34km solar lighting unit.	None required - Solar Installation	N/A	N/A
PR04	N/A	N/A	Refer to 'SHD961-SHD-HLG-ARLE-DR-EO-Lighting Layout-R0' private lighting design drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base with glass flake root protection as supplied by Mallatle, CU Phosco, Valmont Stainton or equivalent. Column to be manufactured to EN 40, BS EN 1461 & BS 5649 standard and supplied in factory applied black (RAL 9005) paint finish. with post top mounted at 0° tilt, Acrospire Defender 8w 1.34km solar lighting unit.	None required - Solar Installation	N/A	N/A

NOTE: NUMBERS SHOWN ON THE SCHEDULE AND DESIGN DRAWING ARE FOR IDENTIFICATION PURPOSES ONLY - ACTUAL COLUMN NUMBERS TO BE SPECIFIED BY LOCAL AUTHORITY LIGHTING DEPARTMENT OR OVERSEEING ORGANISATION.