

WINDOW REVEAL



SOLID GROUND FLOOR



WINDOW SILL



PARAPET DETAIL



LINTEL AND CAVITY TRAY



PITCHED ROOF AND WALL ABUTMENT



PITCHED ROOF AND FLAT ROOF ABUTMENT



TRENCH FOUNDATION



WINDOW HEAD AND LINTEL



WELTED DRIP TO EXTERNAL GUTTER



COLD FLAT ROOF



FLAT ROOF / WALL ABUTMENT



EAVES DETAIL



Ridge Detail



ROOFLIGHT

1.The Conservation Rooflight, with Ironmongery Option fixed to structural rafter supports at jamb using coach bolts fitted through fixing rail
2. Structural rafter support at jamb and structural trimmer support at head and cill
3. Insulation fitted between structural supports.
4. Fix timber packers to structural support at the top and base of the roof build up. The cill timber packer 4b must be larger to provide a secure fixing point for the ironmongery. Fix 18mm ply packer 4c to the timber packers.
5. Fit insulation between the timber packers
6. Plasterboard lining with plasterboard stop to project the corner. Plasterboard fitted behind the thermoliner of the rooflight
7. Plaster skim
8. Timber reveal to align with rooflight linings
9. Head hardwood tilting fillet.
9b. Cill hardwood tilting fillet - to provide minimum 5 degree fall for shedding rain water.
10&10. Line of breathable membrane.Roofing membrane must be allowed to 'sag'between rafters. Wrap around batten ends where mortar bedding is used.
11. Softwood battens.
12. Code 3 (consider using code 4 and clipping down roof tiles in severer exposures) lead flashing at head.
13. Double eloonted slate undercoak course. At rooflight head only gives base for mortar bedding for pantiles.
14. Mortar bedding - Pantiles to be laid and set to a mortar bed as shown.
14b. Line of lead soaker if required
15. Roofing tiles15b Tile inserts reduce amount of visible mortar and give decorative effect.
16. Perimeter silicone seal . Seal perimeter of rooflight
17. Roofing membrane to rooflight head.
18. Vapour barrier (Blue).

PROJECT DETAILS
/scale 1:15/

mold+ designlab

MOLD ARCHITECTURAL DESIGN RESEARCH LAB.

Newcastle Brunch:
37 Side, 2nd Floor,
Newcastle Upon Tyne, NE13JE

Liverpool Brunch:
33 Princess Avenue, 3rd Floor,
Liverpool, L82UP

T. : +4407864642142
E. : info@moldconsultacy.co.uk
W. : www.moldconsultacny.co.uk

CLIENT
-

PROJECT
28 DUKE STREET, CA28 7EU
WHITEHAVEN, CUMBRIA UK

DRAWN BY
M.BURAK TOSUN
DILARA EFE

DATE
11/05/2022

NOTES

A4.0