

Cumberland Council (Whitehaven) -
Development Management
Market Place, Whitehaven, CA28 7JG

Reference: PA-0001524/01
Customer reference: 4/26/2097/0F1
16 April 2026

REPURPOSE THE DISUSED GARDEN AT THE REAR OF 14-15 MARKET PLACE INTO STAFF PARKING, WITH ONE DISABLED SPACE TWO EV SPACES, LED LIGHTING AND STANDARD CAR PARKING SPACES TO ACCOMMODATE OUR CURRENT STAFFING LEVELS

CA22 2AF

Dear Planning Officer,

Thank you for contacting us.

This is our response to your consultation 4/26/2097/0F1.

Environment Agency position

We have no objection to the proposed development but we wish to make the following comments:-

Environmental permit – Flood risk activities - advice to applicant

Skirting Beck is a designated 'Main River'. The Environmental Permitting (England and Wales) Regulations 2016 require a permit or exemption to be obtained for any of the following activities:

- erecting any temporary or permanent structure in, over or under a main river, such as a culvert, outfall, weir, dam, pipe crossing, erosion protection, scaffolding or bridge
- altering, repairing or maintaining any temporary or permanent structure in, over or under a main river, where the work could affect the flow of water in the river or affect any drainage work
- building or altering any permanent or temporary structure designed to contain or divert flood waters from a main river
- dredging, raising or removing any material from a main river, including when you are intending to improve flow in the river or use the materials removed

- diverting or impounding the flow of water or changing the level of water in a main river
- quarrying or excavation within 16 metres of any main river, flood defence (including a remote defence) or culvert
- any activity within 8 metres of the bank of a main river, or 16 metres if it is a tidal main river
- any activity within 8 metres of any flood defence structure or culvert on a main river, or 16 metres on a tidal river
- any activity within 16 metres of a sea defence structure
- activities carried out on the floodplain of a main river, more than 8 metres from the river bank, culvert or flood defence structure (or 16 metres if it is a tidal main river), if you do not have planning permission (you do not need permission to build agricultural hay stacks, straw stacks or manure clamps in these places)

For further guidance please visit Flood risk activities: environmental permits - GOV.UK or contact our National Customer Contact Centre on 03708 506 506 (Monday to Friday, 8am to 6pm) or by emailing enquiries@environment-agency.gov.uk.

The applicant should not assume that a permit will automatically be forthcoming once planning permission has been granted, and we advise them to consult with us at the earliest opportunity.

If you have any questions regarding our response, please contact clplanning@environment-agency.gov.uk.

Yours sincerely,

Hui Zhang, Planning Advisor – Sustainable Places
National Contact Centre: 03708 506 506
clplanning@environment-agency.gov.uk
Ghyll Mount, 40 Business Park, Gillan Way, Penrith CA11 9BP