

Copeland area Planning Department, Cumberland Council

For the attention of Sarah Papaleo

Date: 11 October 2024

Your reference: 4/24/2327/DOC

Dear Sarah Papaleo

CONSULTATION ON PLANNING APPLICATION

Appn: 4/24/2327/DOC
Site Address: LAND ADJACENT TO 6 ROSE GARDENS, GILGARRAN
Proposal: DISCHARGE OF CONDITION 4 OF PLANNING APPLICATION
4/22/2393/0R1

Thank you for your consultation on 1 October 2024 regarding the above Planning Application.

Cumberland Council as the Local Highway Authority (LHA) and Lead Local Flood Authority (LLFA) has reviewed the above planning reference and our findings are detailed below.

Condition 4 -

The LHA and LLFA welcome the additional drainage report and site block plan including aco drain submitted to LPA in support of discharging condition 4 of application 4/22/2393/0R1. we have no objection to the proposal in principle but would like the following point addressed before condition 4 can be discharged.

- The Aco Drain within plan shows no outfall, the LLFA would like see how the Aco Drain connects to the proposed surface water system within the development site.

In light to the above comments additional details are required from the applicant. Upon receipt of the amended plans I shall be better placed to provide full response.

Yours sincerely

June Farquharson
Assistant Development Management Officer