



Flood & Development Management  
Parkhouse Building  
Carlisle  
CA6 4SJ

cumberland.gov.uk

---

Copeland area Planning Department, Cumberland Council

For the attention of Planning Officer

Date: 1 April 2025

Your reference: 4/25/2073/0F1

Dear Planning Officer

### **CONSULTATION ON PLANNING APPLICATION**

**Appn:** 4/25/2073/0F1  
**Site Address:** HIGH WATH, CLEATOR  
**Proposal:** PROPOSED CONVERSION AND EXTENSION OF EXISTING  
GARAGE TO ANNEX

Thank you for your consultation on the above Planning Application.

The Local Highway Authority (LHA) and Lead Local Flood Authority (LLFA) can confirm as follows:

No objection in principal but would like more detail on where the proposed surface water system outfalls, we don't see on the plan where the drainage system finishes.

Yours sincerely

**June Farquharson**  
Assistant Development Management Officer