

Copeland area Planning Department, Cumberland Council

For the attention of Sarah Papaleo

Date: 15 January 2026
Your reference: 4/25/2148/DOC

Dear Sarah Papaleo

CONSULTATION ON PLANNING APPLICATION

Appn: 4/25/2148/DOC
Site Address: THE ROYAL BRITISH LEGION SITE, HILL TOP ROAD,
WHITEHAVEN
Proposal: DISCHARGE OF CONDITIONS 3, 5, 6 AND 8 OF PLANNING
APPLICATION 4/22/2127/0F1

Thank you for your consultation on the above Discharge of Conditions Application.

The Local Highway Authority (LHA) and Lead Local Flood Authority (LLFA) can confirm as follows:

Condition 3

The LHA are content with the information submitted to the LPA in support of condition 3. Therefore condition 3 can be discharged.

Condition 5

The LHA have no objection in principle. However, before the condition can be discharged, we require confirmation of where the ACO channel/drain at the boundary of the highway will discharge. Please provide a plan or details showing the proposed discharge point.

Condition 6

The above condition is not for the LHA/LLFA to discharge.

Condition 8

The above condition is not for the LHA/LLFA to discharge.

Yours sincerely

June Farquharson
Assistant Development Management Officer