

Flood & Development Management
Parkhouse Building
Carlisle
CA6 4SJ

cumberland.gov.uk

Copeland area Planning Department, Cumberland Council

## For the attention of Christie M Burns

Date: 6 June 2025

Your reference: 4/25/2186/0A1

Dear Christie M Burns

## **CONSULTATION ON PLANNING APPLICATION**

Appn: 4/25/2186/0A1

Site Address: 10/14 BRIDGE END INDUSTRIAL ESTATE, EGREMONT Proposal: APPLICATION FOR ADVERTISEMENT CONSENT FOR THE

**ERECTION OF FASCIA SIGNS AND TOTEM SIGNS** 

Thank you for your consultation on the above Planning Application.

The Local Highway Authority (LHA) and Lead Local Flood Authority (LLFA) can confirm that we have no objection to the proposed development as it is considered that it will not have a material effect on existing highway conditions nor will it increase the flood risk on the site or elsewhere.

The details provided for the internally illuminated signs are stated at <u>200cd/m2</u> which is below the maximum of <u>600cd/m2</u>

Yours sincerely

**Natalie Robinson** 

Planning Application Officer