



Flood & Development Management
Parkhouse Building
Carlisle
CA6 4SJ

cumberland.gov.uk

Copeland area Planning Department, Cumberland Council

For the attention of Heather Morrison

Date: 25 March 2026

Your reference: 4/26/2022/0F1

Dear Heather Morrison

CONSULTATION ON PLANNING APPLICATION

Appn: 4/26/2022/0F1
Site Address: WOODEND FARM, WOODEND, EGREMONT
Proposal: PROPOSED EXTENSION TO EXISTING BATTERY STORAGE FACILITY

Thank you for your consultation on the above Planning Application.

The Lead Local Flood Authority (LLFA) has reviewed the additional information on surface water drainage and flood risk (Drainage Assessment Report 16 March 2026) and can confirm as follows : (please note there is no change to the LHA response which was 'no objection')

Lead Local Flood Authority response:

I note from the Drainage Assessment Report:

- The works extend the fenced site area to the south, but still within the wider bunded compound area.
- A filter drain to intercept overland and shallow sub-surface flows is proposed along the perimeter of the proposed development. I am satisfied that this will control the risk of uncontrolled run-off from the site.

LLFA Recommendation

No objections. It is suggested that the Report is included in the list of approved documents and drawings to ensure the drainage system is constructed to the submitted details.

Yours sincerely

Shamus Giles

Lead Officer - Flood & Development Management