

**REF 4/26/2072/0F1 GOSPEL HALL FRIZINGTON RD FRIZINGTON
REPLY TO COMMENT MADE BY LLFA CONCERNING SURFACE WATER
DISPOSAL FROM PROPOSED CAR PARKING FOR THE SHOP**

The proposed car park for the shop is located on an existing hard surfaced part of the site adjacent to the car wash facility owned by the applicant.

No change to the surface water disposal will take place,

The existing hard surfaced ground on site discharges to existing drains on the site.

No new SW drains are required as no additional hard surfaced areas are proposed, the car park is simply on an existing hard surfaced area within the site boundaries.

Richard J. Lindsay
Calva Design Studio
5/4/26