

ESCAPE SIGNAGE KEY

1

2

3

4

5

6

PROGRESS FORWARD FROM HERE

PROGRESS TO THE RIGHT OF HERE

PROGRESS DOWN TO THE RIGHT OF HERE

IN THE EVENT OF A FIRE NOTICE TO BE POSITIONED NEXT TO ALL FIRE ALARM BREAK GLASS UNITS (SEE BELOW)

STATUTORY FIRE NOTICE (210x300mm)

FIRE ACTION

If you discover a fire

From the rear of a break glass unit

Break the glass and use the emergency protocol

Follow the instructions on the notice to the nearest safe exit

If you hear the fire bell

Follow the instructions on the notice to the nearest safe exit

Follow the instructions on the notice to the nearest safe exit

FOR ALL FIRE ALARMS, SOUNDERS, BREAK GLASS UNITS ETC REFER TO ENGINEERS FIRE ALARM DRAWINGS

FIRE ESCAPE SIGNAGE TO CONFORM TO BS 5499 PART 1. MAXIMUM VIEWING DISTANCE BETWEEN SIGNS TO BE 20m. SIGNS POSITIONED ON THE WALLS TO BE LOCATED BETWEEN 1.7 & 2.0m ABOVE FINISHED FLOOR LEVEL. SIGNS SUSPENDED FROM CEILINGS AND SIGNS ABOVE 2.0m HIGH ARE NOT TO BE OBTAINED AND INCONSPICUOUS. IF THIS IS THE CASE THERE ARE TO BE ADDITIONAL SIGNS PROVIDED TO ENSURE FULL AWARENESS OF ESCAPE ROUTES.

LEGEND

600x600 LED LIGHT

1200mm LED LIGHT

LED EXT ROUND BULKHEAD LIGHT

KEY SWITCH

LIGHT P.A.S.

2kW CONVECTOR HEATER

1kW DOWNFLOW HEATER

SINGLE SWITCHED SOCKET OUTLET

DOUBLE SWITCHED SOCKET OUTLET

FUSED SPUR

SWITCHED FUSED SPUR

FROST STAT

AIR CONVENTIONING EXTERNAL ISOLATOR

DOUBLE DATA POINT

DETRAIL/NOTION BOARD

REACTITE EXTRACT FAN

24V EXTRACT FAN

FIRE ALARM CONTROL PANEL

FIRE ALARM PUSH POINT

SMOKE DETECTOR

SMOKE DETECTOR + SOUNDER

SMOKE DETECTOR + SOUNDER + BEACON

5 LITRE WATER BOKER

10 LITRE UNVENTED WATER HEATER

5 LITRE UNVENTED WATER HEATER

15 LITRE MULTIPORT WATER HEATER

15 LITRE MULTIPORT WATER HEATER

SOIL VENT PIPE

TOILET ROLL HOLDER

RAINWATER DOWNSPE

DOOR CLOSER / HOLDER / STOP / VISION PANEL

VERTICAL BLIND

PARTITION KEY

TYPE 'A' 32dB ½Hr 114mm

(2x12.5mm Vinyl P'board + 89mm Stud)

TYPE 'B' 35dB 1Hr 119mm

(2x15mm Vinyl Megadeco + 89mm Stud)

TYPE 'C' 37dB ½Hr 114mm

(2x12.5mm Vinyl P'board + 89mm Stud + Insul)

TYPE 'D' 45dB 1Hr 139mm

(4x12.5mm Vinyl P'Board + 89mm Stud + Insul)

NOTE:
STEEL LINING TO WALLS AND CEILING IN
MALE & FEMALE CHANGING ROOMS

INTERNAL DOOR SCHEDULE

ID No.	Part No.	Description
D01	108339	926mm RH Oak Glazed Int D/Set 119
D02	108343	926mm RH Oak Solid Int D/Set 114
D03	108343	926mm RH Oak Solid Int D/Set 114
D04	108339	926mm RH Oak Glazed Int D/Set 114
D05	108398	926mm Swing Oak Glazed Int D/Set 139
D06	108341	926mm LH Oak Glazed Int D/Set 114
D07	108343	926mm RH Oak Solid Int D/Set 114
D08	108345	926mm RH Oak Solid Int D/Set 114
D09	108339	926mm RH Oak Glazed Int D/Set 114
D10	108339	926mm RH Oak Glazed Int D/Set 114
D11	108347	926mm RH Oak Solid Dis Wt Int D/Set 114

Build No. CKS18001

Electrical Load - 159A/Ph - Three Phase

F	Waste and Water from Male WCs	SRW	16.03.18	PAA	16.03.18
E	Moved to Gable Wall adjacent showers	SRW	26.02.18	PAA	26.02.18
D	Fire Alarm and PA System Added	SRW	09.02.18	PAA	09.02.18
C	Updated for Production	SRW	23.01.18	PAA	24.01.18
B	Updated in line with amendment	JB	09.08.17	BJP	11.08.17
A	First Issue	-	-	-	-
Rev	Description	By	Date	CHK	Date

General Notes:

- This drawing and any information or descriptive matter set hereon is the confidential property of Elliott, and must not be disclosed, copied, or used for manufacturing, tendering or any other purpose without the prior consent in writing of Elliott.
- Do not scale from this drawing, work to figured dimensions only.
- All dimensions are in millimetres.

elliott

An ALGECO SCOTSMAN Company

www.elliottuk.com

Elliott - Modular Buildings, Manor Drive, Peterborough, PE4 7AP

Tel: 01733 265700 - Fax: 01733 265709

Client:	Morgan Sindall						
Project:	CHP Plant Site Accommodation Sellafield Elliott Classic Multi						
Drawn By:	JPJ	Drawn Date:	10.05.17	Checked By:	EL	Checked Date:	10.05.17
Scale:	1:50	Sheet Size:	A1	Sheet Number:	1 of 1		
Drawing Title:	16 No.Bays 12.0x3.0m 2-Storey 2.4m Ceiling Height, 3kN Floor Loading Plan Layout (Ground Floor)						
Drawing Number:	S160388-101						
Rev:	F						

3509140-ELL-HRCP-GX-CA-X-80-21001