

Afternoon Tom,

I understand that you have previously been in contact with one of my colleagues [REDACTED] regarding the above site, i can confirm that [REDACTED] is no longer working for United Utilities and i have therefore picked this up.

I have received confirmation from the Construction Engineer and Developer Services Inspector that trial holes have taken place on site and the gang successfully exposed the main approximately 7m away from the original drawing at a depth of 1,200mm and therefore does not appear to cross the proposed football pitch. The main looked to be follow the bottom of the slope, away from the pitch.

Kind Regards