



Proposed Luminaire Schedule
West Cumberland Phase 2 Hospital External Lighting Scheme

Area:	Luminaire Symbol	Image	Description
Car Parks	1A		WHITECROFT LIGHTING LEVANTER LED LAMP POST TOP LUMINAIRE FOR OUTDOOR APPLICATIONS, 5725 mm, 65W, WIDE FLOOD DISTRIBUTION, IP66 MOUNTED ON 6M COLUMN, 'CCTV' DENOTES LAMP POST MOUNTED EXTERNAL CCTV CAMERA.
Street Lighting Drop off area	1B		WHITECROFT LIGHTING LEVANTER LED LAMP POST TOP LUMINAIRE FOR OUTDOOR APPLICATIONS, 4669 mm, 42W, WIDE ROAD DISTRIBUTION, IP66, MOUNTED ON 6M COLUMN, 'CCTV' DENOTES LAMP POST MOUNTED EXTERNAL CCTV CAMERA.
Walkways	1C		WHITECROFT LIGHTING KOLA BOLLARD, BLACK, Robust and Weatherproof Illuminated LED Bollard, post mounted, symmetric, 3000K, 998mm high, 410mm, 4.2W, IP66.
Lighting Outside entrances	1F		WHITECROFT LIGHTING SPECTRE WX, Wall Mounted conical luminaire for outdoor applications, IP65, 4000K, 1119mm, 9W, 3H integrated emergency.
Covered Walkway Lighting	1D		WHITECROFT LIGHTING STARLINE FIXED IP67 surface opt 4000K, 635mm x 297 mm; 5.7 W; 1xLED
Main Entrance Courtyard	1G		WHITECROFT LIGHTING MARINE LF IN GROUND RECESSED FIXED UPLIGHTER (464 mm; 4W; 1xLED)

DO NOT SCALE

NOTES

- LIGHTING LEVELS REQUIRED ARE IN ACCORDANCE WITH CIBSE LG2 AND SSL LIGHTING GUIDE 6.
- EXTERNAL LIGHTING TO BE CONTROLLED BASED ON EXTERNAL AMBIENT LIGHT, TIME AND MOVEMENT. EACH EXTERNAL LUMINAIRE TO BE COMPLETE WITH SMART SENSORS WHICH CAN BE WIRELESSLY LINKED TO CREATE A INTELLIGENT NETWORK WITH WEB-BASED SOFTWARE AND GRAPHIC USER INTERFACE LOCATED ON ESTATES PC.
- ALLOWANCE TO BE MADE FOR A FEEDER PILLAR FOR CARPARK LIGHTING DISTRIBUTION BOARD AND CONTROLS
- ALL EXTERNAL LIGHTING, BRACKETS AND COLUMNS TO BE FINISHED SUITABLE FOR USE IN A COASTAL CORROSIVE ENVIRONMENT.
- POSITION OF EXTERNAL CCTV CAMERAS TO BE REVIEWED WITH TRUST.
- COURTYARD LIGHTING TO BE PHOTOCELL AND TIME SWITCH CONTROLLED TO MEET TRUST PATIENT SECURITY REQUIREMENTS.

EXTERNAL CCTV CAMERA, HIGH DEFINITION, PAN/TILT/ZOOM, IP65 MINIMUM, 'CCTV' BY LAMP POST DENOTES LAMP POST MOUNTED EXTERNAL CCTV CAMERA.

POWER SUPPLY UNIT

ISOLATOR

GRP ENCLOSURE DETAILS:
1400mm W x 660 D x 1515 H
REMOVABLE FLOOR
18mm PLY BACKBOARD
HI/LOW VENTILATION
IP65 MIN
INTERNAL LIGHTING
LOOK TO MATCH HOSPITAL STANDARD

FOR LIGHT COMPARISON
WCH-DSSR
DRAWING
WCHPH2-

REV	DATE	BY	DESCRIPTION
P3	MAR 22	BH	INCLUSION OF CIRCUIT REFERENCES
P2	MAR 22	BH	ISSUED FOR STAGE 4, INCORPORATED CHANGES FROM STAGE 3 ISSUE AND CHANGES TO GROUND WORKS AND LANDSCAPING LAYOUTS
P1	JUL 21	SR	ISSUED FOR STAGE 3, LIGHTING CONTROL NOTES UPDATED, FEEDER PILLAR DETAILS ADDED.
PO	MAY 21	MP	FIRST ISSUE

DRAWING STATUS

STAGE 4 ISSUE

SAFETY, HEALTH AND ENVIRONMENTAL INFORMATION

IT IS ASSUMED THAT A COMPETENT MAIN CONTRACTOR OR USER WILL BE AWARE OF THE STANDARD POSSIBLE RISKS ASSOCIATED WITH WORKING WITH THE TYPE OF SERVICES DETAILED ON THIS DRAWING.

DSSR | CONSULTING ENGINEERS
Glasgow Harrogate London Manchester

Manchester Office
Trafford House
Chester Road
Bradford
Manchester
M32 0PS
Tel: +44 (0)161 872 4811
manchester@dssr.co.uk
www.dssr.co.uk

GRAHAM **PROCURE**

PROJECT
West Cumberland Hospital Phase 2

TITLE
EXTERNAL LIGHTING, POWER & CCTV LAYOUT
NEW BUILT
SHEET 1 OF 2

Drawn	Check	Date	Drawn	Check	Date
MP	SR	MAY21	MP	SR	MAY 21
MP	AD	MAY21	MP	AD	1:250

CDW File: WCHPH2-DSSR-V7-SL-DR-E-90001-2.dwg

COUNTRY No: WCHPH2-DSSR-V7-SL-DR-E-90001

REV: P3