



DO NOT SCALE

- NOTES
1. LIGHTING LEVELS REQUIRED ARE IN ACCORDANCE WITH CIBSE LG2 AND SSL LIGHTING GUIDE 6.
  2. EXACT CONTROL METHODOLOGY TO BE AGREED
  3. GENERALLY ALL EXTERNAL LIGHTING WILL BE CONTROLLED BY SOLAR DIAL TIMELOCK / ASTROTIMER, PHOTOCCELL AND MOVEMENT SENSING.
  4. ALL TO PROVIDE TIMELOCKS AT EACH ORIGIN OF SUPPLY. (PROVISIONALLY 4No. TIMELOCKS TO BE ALLOWED)
  5. ALLOWANCE TO BE MADE FOR A FEEDER PILLAR FOR CARPARK LIGHTING DISTRIBUTION BOARD AND CONTROLS
  6. ALL EXTERNAL LIGHTING, BRACKETS AND COLUMNS TO BE FINISHED SUITABLE FOR USE IN A COASTAL CORROSIVE ENVIRONMENT.



P1	MAR 22	BH	ISSUED FOR STAGE 4, INCORPORATED CHANGES TO GROUND WORKS AND LANDSCAPING LAYOUTS
PO	JUN 21	MP	FIRST ISSUE
REV	DATE	BY	DESCRIPTION

DRAWING STATUS: **STAGE 4 ISSUE**

SAFETY, HEALTH AND ENVIRONMENTAL INFORMATION

RECORDS OF THIS DRAWING

ALL EFFORTS HAVE BEEN TAKEN BY DSSR TO DESIGN OUT SIGNIFICANT HAZARDS WITHIN THE DESIGN RISK ASSESSMENT PROCESS. IT IS OUR OPINION THAT THE HAZARDS STATED BELOW CANNOT BE DESIGNED OUT BY US GIVEN THE CONSTRAINTS OF THE BRIEF AND ARE HIGHLIGHTED SO THAT OTHER MAKERS CAN BE DEVELOPED TO MITIGATE THE RESIDUAL RISKS IDENTIFIED. MORE DETAIL AVAILABLE IN THE PROJECT SPECIFIC RISK REGISTER.

IT IS ASSUMED THAT A COMPETENT NME CONTRACTOR OR USER WILL BE AWARE OF THE STANDARD FORESEEABLE RISKS ASSOCIATED WITH WORKING WITH THE TYPE OF SERVICES DETAILED ON THIS DRAWING.

**DSSR | CONSULTING ENGINEERS**  
Glasgow Harrogate London Manchester

Manchester Office  
Trafford House  
Chester Road  
Bradford  
Manchester  
M32 0PS  
Tel: +44 (0)161 872 4811  
manchester@dssr.co.uk  
www.dssr.co.uk

**GRAHAM** **PROCURE**

PROJECT: **West Cumberland Hospital Phase 2**

TITLE: **EXTERNAL LIGHTING LUX LEVEL PLOT NEW BUILT SHEET 1 OF 2**

Drawn	MP	Check	JUN 21	Issue	SR	Date	JUN 21
Scale	MP	Date	JUN 21	Sheet Size	A0	Scale	1:250
CDW File	WCHPH2-DSSR-V7-SL-DR-E-90005-6.dwg						
Drawing No.	WCHPH2-DSSR-V7-SL-DR-E-90005						
REV	P1						