



DO NOT SCALE

- NOTES**
1. LIGHTING LEVELS REQUIRED ARE IN SLL ACCORDANCE WITH CIBSE LG2 AND SLL LIGHTING GUIDE 6.
 2. EXACT CONTROL METHODOLOGY TO BE DETERMINED AT A LATER DATE.
 3. GENERALLY ALL SYSTEM LIGHTING WILL BE CONTROLLED BY SQUARE DIAL TIMELOCK / ASTRONOMER, PHOTOCELL AND MOVEMENT SENSING.
 4. ALL TO PROVIDE TIMELOCKS AT EACH ORIGIN OF SUPPLY (PROVISIONALLY 400V TIMELOCKS TO BE ALLOWED).
 5. ALLOWANCE TO BE MADE FOR A FEWER PILLAR FOR CARPARK LIGHTING DISTRIBUTION BOARD AND CONTROLS.
 6. ALL EXTERNAL LIGHTING, BRACKETS AND FIXINGS TO BE CASTALUMINUM FOR USE IN A CORROSION RESISTANT ENVIRONMENT.



REV	DATE	BY	DESCRIPTION
001	JUN 21	WPE	CONSTRUCTION ISSUE
P1	WPE 22	BH	ISSUED FOR STAGE 4 UNBARRICADED LANDSCAPING LAYOUTS
PO	JUN 21	WPE	FIRST ISSUE

CONSTRUCTION

CONSTRUCTION METHAD ENVIRONMENTAL REGULATION

ALL WORKS SHALL BE CONDUCTED IN ACCORDANCE WITH THE CONSTRUCTION METHAD ENVIRONMENTAL REGULATION (CMER) 2017. THE CMER 2017 IS A LEGISLATIVE INSTRUMENT WHICH IS PART OF THE ENVIRONMENTAL REGULATION 2017. THE CMER 2017 IS A LEGISLATIVE INSTRUMENT WHICH IS PART OF THE ENVIRONMENTAL REGULATION 2017. THE CMER 2017 IS A LEGISLATIVE INSTRUMENT WHICH IS PART OF THE ENVIRONMENTAL REGULATION 2017.

DSR CONSULTING ENGINEERS
 Group: Strategic Urban Movement

PRO-CURE

14, 448 O'Brien Street
 Melbourne, VIC 3000
 Tel: +61 (0)3 9271 8111
 www.dsrengineers.com.au

GRAHAM

14, 448 O'Brien Street
 Melbourne, VIC 3000
 Tel: +61 (0)3 9271 8111
 www.dsrengineers.com.au

PROJECT
 West Cumberland Hospital Phase 2

TITLE
 EXTERNAL LIGHTING
 LUX LEVEL PLOT
 NEW BUILT
 SHEET 1 OF 2

DATE
 JUN 21

SCALE
 1:250

PROJECT NO
 WCHPH2.DSSR-VJ-SL-DR-E-9005-6-049

PROJECT NO
 WCHPH2.DSSR-VJ-SL-DR-E-9005

SHEET NO
 011